Test Software P/N 4102483

Tested Part Number 1040000



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

ln lr	D 14	T 1			
Pass F	Results	Limits	Units	Description	Step
✓	1671	LE 1816	ADC Cnts	0021.0570 02 Positive Flow Cal: dP1 at 64,3 (SP 65 @78,8P	36
✓	1817	LE 1956	ADC Cnts	0021.0580 O2 Positive Flow Cal: dP1 at 73,9 (SP 75 @78,2P)	37
✓	1957	LE 2078	ADC Cnts	0021.0590 02 Positive Flow Cal: dP1 at 84,3 (SP 85 @77,6P	38
✓	2079	LE 2204	ADC Cnts	0021.0600 02 Positive Flow Cal: dP1 at 94,5 (SP 95 @77,2P)	39
✓	2206	LE 2314	ADC Cnts	0021.0610 02 Positive Flow Cal: dP1 at 104,7 (SP 105 @76,	40
✓	2315	LE 2420	ADC Cnts	0021.0620 02 Positive Flow Cal: dP1 at 114,7 (SP 115 @75,	41
✓	2420	LE 2513	ADC Cnts	0021.0630 02 Positive Flow Cal: dP1 at 124,0 (SP 125 @75,	42
✓	2514	LE 2621	ADC Cnts	0021.0640 02 Positive Flow Cal: dPl at 133,8 (SP 135 @74,	43
✓	2622	LE 2878	ADC Cnts	0021.0650 02 Positive Flow Cal: dPl at 145,2 (SP 145 @73,	44
✓	2879	LE 3008	ADC Cnts	0021.0660 02 Positive Flow Cal: dP1 at 174,5 (SP 175 @71,	45
✓	3009	LE 3999	ADC Cnts	0021.0670 02 Positive Flow Cal: dPl at 189,2 (SP 190 @69,	46
	FALSE	Pass	N/A	0021.0880 02 Sensor Cal (RANGE_FAILURE): 3 mV at ambient	47
	FALSE	Pass	N/A	0021.0930 Write OBM Sensors Cal Table [14m 16s]	48
\dashv					
\dashv					
+					
++					
+					
++			 		
+			 		
+		-	+		
_ _ _ _					

Test Started On 08/22/24 01:10:17

Serial Number TV016031626 Elapsed Test Time 14m 16s

Page 2 **of** 2