

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [26m	SLPM	42,6 to 53,4	47,2	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,8 (Setpoint 40) [26m	SLPM	32,8 to 42,8	37,5	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [26m	SLPM	23,4 to 32,6	27,4	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [26m	SLPM	15,0 to 25,0	19,0	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [26m	SLPM	5,5 to 14,5	9,3	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [26m 3	SLPM	1,2 to 8,8	4,6	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [26m	SLPM	-2,0 to 2,0	-0,3	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,5 (Setpoint 140) [	SLPM	-147,5 to -129,5	-134,1	✓	
44	0030.0560 Neg Flow Verify: dP2 at -128,5 (Setpoint 130) [	SLPM	-137,1 to -119,9	-124,0	✓	
45	0030.0570 Neg Flow Verify: dP2 at -117,8 (Setpoint 120) [	SLPM	-126,0 to -109,6	-114,8	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,8 (Setpoint 110) [	SLPM	-116,7 to -101,0	-105,8	✓	
47	0030.0590 Neg Flow Verify: dP2 at -99,0 (Setpoint 100) [3	SLPM	-106,5 to -91,5	-96,1	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,3 (Setpoint 90) [32m	SLPM	-95,4 to -81,3	-85,0	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,7 (Setpoint 80) [32m	SLPM	-84,3 to -71,1	-74,4	✓	
50	0030.0620 Neg Flow Verify: dP2 at -68,0 (Setpoint 70) [32m	SLPM	-74,2 to -61,8	-67,1	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,2 (Setpoint 60) [32m	SLPM	-63,0 to -51,4	-56,6	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,2 (Setpoint 50) [32m	SLPM	-53,6 to -42,7	-47,5	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [32m	SLPM	-43,0 to -33,0	-37,6	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [32m	SLPM	-32,6 to -23,4	-27,8	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,8 (Setpoint 20) [32m	SLPM	-24,8 to -14,8	-20,1	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [32m	SLPM	-14,5 to -5,5	-9,8	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [32m	SLPM	-8,8 to -1,2	-4,8	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [32m	SLPM	-2,0 to 2,0	-0,3	✓	
59	0030.0950 Contr.Press.Ver.(7562): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
60	0030.0960 Monit.Press.Ver.(4009): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,11	✓	
61	0030.0160 Pprox Press. Ver.(8292): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,17	✓	
62	0030.0970 Contr.Press.Ver.(10158): P1 at 4,26 (SP 4, 1, 1)	cmH2O	3,26 to 5,26	3,99	✓	
63	0030.0980 Monit.Press.Ver.(7004): P2 at 4,26 (SP 4, 1, 1)	cmH2O	3,26 to 5,26	4,37	✓	
64	0030.0161 Pprox Press. Ver.(10859): P2 at 4,26 (SP 4, 1,	cmH2O	3,26 to 5,26	4,42	✓	
65	0030.0990 Contr.Press.Ver.(18656): P1 at 18,32 (SP 18, 1,	cmH2O	17,32 to 19,32	17,98	✓	
66	0030.1000 Monit.Press.Ver.(16825): P2 at 18,32 (SP 18, 1,	cmH2O	17,32 to 19,32	18,31	✓	
67	0030.0162 Pprox Press. Ver.(19289): P2 at 18,32 (SP 18, 1	cmH2O	17,32 to 19,32	18,32	✓	
68	0030.1010 Contr.Press.Ver.(27146): P1 at 32,30 (SP 32, 1,	cmH2O	31,30 to 33,30	32,00	✓	
69	0030.1020 Monit.Press.Ver.(26619): P2 at 32,30 (SP 32, 1,	cmH2O	31,30 to 33,30	32,24	✓	
70	0030.0163 Pprox Press. Ver.(27738): P2 at 32,30 (SP 32, 1	cmH2O	31,30 to 33,30	32,26	✓	

Test Started On 01/16/24 02:52:59Serial Number TV116080284Elapsed Test Time 2 hr 9m 39sStatus **PASS**

Page 2 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20