

Test Software P/N 4102483Tested Part Number 1040000Test Software Name Trilogy FSA (REPAIR TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
1	0020.0001 Ambient Air: RH=38,70%; T=23,30Cdeg [14s]	N/A	Pass	TRUE	✓	
2	0020.0010 O2 Sensor Heater On (not attempted for SW ver.1)	N/A	None	None	✓	
3	0020.0010 Press Sensors Cal P1@4,09&50,02cmH2O/10047&3376	20/ADC C	0,00151 to 0,0018	0,00165	✓	
4	0020.0020 Press Sensors Cal P1@4,09&50,02cmH2O/10047&3376	cmH2O	-18,22 to -9,05	-13,50	✓	
5	0020.0030 Press Sensors Cal P1@4,09&50,02cmH2O/10047&3376	ADC Cnts	5994 to 9998	8211	✓	
6	0020.0040 Press Sensors Cal P2@4,09&50,02cmH2O/10047&3376	20/ADC C	0,00114 to 0,0018	0,00143	✓	
7	0020.0050 Press Sensors Cal P2@4,09&50,02cmH2O/10047&3376	cmH2O	-19,53 to 0,00	-5,70	✓	
8	0020.0060 Press Sensors Cal P2@4,09&50,02cmH2O/10047&3376	ADC Cnts	0 to 10399	3970	✓	
9	0020.0950 Press Sensors Cal Pprox@4,09&50,02cmH2O/10047&3	20/ADC C	0,00151 to 0,0018	0,00165	✓	
10	0020.0960 Press Sensors Cal Pprox@4,09&50,02cmH2O/10047&3	cmH2O	-18,22 to -9,05	-13,72	✓	
11	0020.0970 Press Sensors Cal Pprox@4,09&50,02cmH2O/10047&3	ADC Cnts	5994 to 9998	8325	✓	
12	0020.0120 Neg Flow Cal: dP2 at -145,8 (Setpoint 145) [9m	ADC Cnts	GE 101	13947	✓	
13	0020.0130 Neg Flow Cal: dP2 at -132,7 (Setpoint 135) [9m	ADC Cnts	GE 13948	14824	✓	
14	0020.0140 Neg Flow Cal: dP2 at -123,3 (Setpoint 125) [9m	ADC Cnts	GE 14825	15488	✓	
15	0020.0150 Neg Flow Cal: dP2 at -113,0 (Setpoint 115) [9m	ADC Cnts	GE 15489	16269	✓	
16	0020.0160 Neg Flow Cal: dP2 at -103,5 (Setpoint 105) [9m	ADC Cnts	GE 16270	17143	✓	
17	0020.0170 Neg Flow Cal: dP2 at -94,2 (Setpoint 95) [9m 9s	ADC Cnts	GE 17144	18126	✓	
18	0020.0180 Neg Flow Cal: dP2 at -83,0 (Setpoint 85) [9m 9s	ADC Cnts	GE 18127	19193	✓	
19	0020.0190 Neg Flow Cal: dP2 at -73,0 (Setpoint 75) [9m 9s	ADC Cnts	GE 19194	20224	✓	
20	0020.0200 Neg Flow Cal: dP2 at -64,0 (Setpoint 65) [9m 9s	ADC Cnts	GE 20225	21274	✓	
21	0020.0210 Neg Flow Cal: dP2 at -53,0 (Setpoint 55) [9m 9s	ADC Cnts	GE 21275	22565	✓	
22	0020.0220 Neg Flow Cal: dP2 at -43,0 (Setpoint 45) [9m 9s	ADC Cnts	GE 22566	24005	✓	
23	0020.0230 Neg Flow Cal: dP2 at -33,5 (Setpoint 35) [9m 9s	ADC Cnts	GE 24006	25491	✓	
24	0020.0240 Neg Flow Cal: dP2 at -23,0 (Setpoint 25) [9m 9s	ADC Cnts	GE 25492	27184	✓	
25	0020.0250 Neg Flow Cal: dP2 at -14,3 (Setpoint 15) [9m 9s	ADC Cnts	GE 27185	28896	✓	
26	0020.0260 Neg Flow Cal: dP2 at -4,3 (Setpoint 5) [9m 9s]	ADC Cnts	GE 28897	32060	✓	
27	0020.0270 Neg Flow Cal: dP2 at -0,0 (Setpoint 0) [9m 9s]	ADC Cnts	GE 32062	33490	✓	
28	0020.0450 Raw Zero Flow: dP2 at 0,0 (Setpoint 0) [9m 9s]	ADC Cnts	GE 0	33490	✓	
29	0020.0500 Pos Flow Cal: dP2 at 5,0 (Setpoint 5) [14m 1s]	ADC Cnts	LE 38276	35130	✓	
30	0020.0510 Pos Flow Cal: dP2 at 15,0 (Setpoint 15) [14m 1s]	ADC Cnts	LE 39784	38277	✓	
31	0020.0520 Pos Flow Cal: dP2 at 22,0 (Setpoint 25) [14m 1s]	ADC Cnts	LE 41803	39785	✓	
32	0020.0530 Pos Flow Cal: dP2 at 34,0 (Setpoint 35) [14m 1s]	ADC Cnts	LE 43656	41804	✓	
33	0020.0540 Pos Flow Cal: dP2 at 48,0 (Setpoint 45) [14m 1s]	ADC Cnts	LE 44820	43657	✓	
34	0020.0550 Pos Flow Cal: dP2 at 56,7 (Setpoint 55) [14m 1s]	ADC Cnts	LE 46154	44821	✓	
35	0020.0560 Pos Flow Cal: dP2 at 67,6 (Setpoint 65) [14m 1s]	ADC Cnts	LE 47257	46155	✓	

Test Started On 03/08/24 10:34:22Serial Number TV018021907Elapsed Test Time 18m 45sStatus **PASS**

Page 1 of 2

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 77D6, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20