Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 65,0 (SP 65 @77,6P	ADC Cnts	LE 1934	1781	√	
37	0021.0580 02 Positive Flow Cal: dP1 at 74,7 (SP 75 @76,7P	ADC Cnts	LE 2063	1935	√	
38	0021.0590 O2 Positive Flow Cal: dPl at 84,0 (SP 85 @75,8P	ADC Cnts	LE 2194	2064	√	
39	0021.0600 02 Positive Flow Cal: dP1 at 94,3 (SP 95 @74,7P	ADC Cnts	LE 2329	2195	√	
40	0021.0610 02 Positive Flow Cal: dP1 at 99,5 (SP 105 @73,6	ADC Cnts	LE 2494	2330	√	
41	0021.0620 02 Positive Flow Cal: dPl at 114,7 (SP 115 @71,	ADC Cnts	LE 2613	2495	√	
42	0021.0630 O2 Positive Flow Cal: dP1 at 125,3 (SP 125 @70,	ADC Cnts	LE 2702	2614	✓	
43	0021.0640 O2 Positive Flow Cal: dPl at 134,3 (SP 135 @68,	ADC Cnts	LE 2793	2703	✓	
44	0021.0650 O2 Positive Flow Cal: dPl at 143,3 (SP 145 @67,	ADC Cnts	LE 3081	2794	√	
45	0021.0660 O2 Positive Flow Cal: dPl at 176,2 (SP 175 @61,	ADC Cnts	LE 3036	3082		×
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,8 (SP 190 @62,	ADC Cnts	LE 3999	3037	√	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 2 mV at ambient	N/A	Pass	FALSE		×
48	0021.0930 Write OBM Sensors Cal Table [18m 26s]	N/A	Pass	FALSE		×
						
						<u> </u>
					-	
						_
						
						
						
						<u> </u>
						<u> </u>

Test Started On 02/02/24 12:59:00

Serial Number TV015092406

Elapsed Test Time 18m 26s

Status FAIL

Page 2 **of** 2