

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,5 (Setpoint 50) [12m	SLPM	42,1 to 52,9	49,5	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,5 (Setpoint 40) [12m	SLPM	32,5 to 42,5	39,0	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [12m	SLPM	23,4 to 32,6	29,2	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [12m	SLPM	15,0 to 25,0	20,2	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [12m	SLPM	5,5 to 14,5	11,0	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [12m 2	SLPM	1,2 to 8,8	5,3	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [12m	SLPM	-2,0 to 2,0	0,2	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,9 (Setpoint 140) [	SLPM	-147,9 to -129,8	-143,2	✓	
44	0030.0560 Neg Flow Verify: dP2 at -128,0 (Setpoint 130) [	SLPM	-136,6 to -119,4	-131,8	✓	
45	0030.0570 Neg Flow Verify: dP2 at -117,7 (Setpoint 120) [	SLPM	-125,9 to -109,5	-122,0	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,5 (Setpoint 110) [	SLPM	-116,3 to -100,7	-111,8	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,2 (Setpoint 100) [1	SLPM	-105,6 to -90,7	-101,4	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,9 (Setpoint 90) [16	SLPM	-95,9 to -81,8	-91,3	✓	
49	0030.0610 Neg Flow Verify: dP2 at -78,0 (Setpoint 80) [16	SLPM	-84,6 to -71,4	-80,8	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,8 (Setpoint 70) [16	SLPM	-74,0 to -61,6	-70,8	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,3 (Setpoint 60) [16	SLPM	-63,1 to -51,5	-60,7	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [16	SLPM	-53,4 to -42,6	-49,8	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [16	SLPM	-43,0 to -33,0	-39,7	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [16	SLPM	-32,6 to -23,4	-29,3	✓	
55	0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [16	SLPM	-25,0 to -15,0	-21,2	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [16	SLPM	-14,5 to -5,5	-10,0	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [16m	SLPM	-8,8 to -1,2	-5,1	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [16m	SLPM	-2,0 to 2,0	0,1	✓	
59	0030.0950 Contr.Press.Ver.(8315): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
60	0030.0960 Monit.Press.Ver.(3790): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
61	0030.0160 Pprox Press. Ver.(8546): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
62	0030.0970 Contr.Press.Ver.(10939): P1 at 4,28 (SP 4, 1, 1)	cmH2O	3,28 to 5,28	4,00	✓	
63	0030.0980 Monit.Press.Ver.(6799): P2 at 4,28 (SP 4, 1, 1)	cmH2O	3,28 to 5,28	4,29	✓	
64	0030.0161 Pprox Press. Ver.(11155): P2 at 4,28 (SP 4, 1,	cmH2O	3,28 to 5,28	4,29	✓	
65	0030.0990 Contr.Press.Ver.(19406): P1 at 18,33 (SP 18, 1,	cmH2O	17,33 to 19,33	18,00	✓	
66	0030.1000 Monit.Press.Ver.(16518): P2 at 18,33 (SP 18, 1,	cmH2O	17,33 to 19,33	18,29	✓	
67	0030.0162 Pprox Press. Ver.(19613): P2 at 18,33 (SP 18, 1	cmH2O	17,33 to 19,33	18,42	✓	
68	0030.1010 Contr.Press.Ver.(27866): P1 at 32,35 (SP 32, 1,	cmH2O	31,35 to 33,35	32,00	✓	
69	0030.1020 Monit.Press.Ver.(26234): P2 at 32,35 (SP 32, 1,	cmH2O	31,35 to 33,35	32,28	✓	
70	0030.0163 Pprox Press. Ver.(27984): P2 at 32,35 (SP 32, 1	cmH2O	31,35 to 33,35	32,37	✓	

Test Started On 06/12/24 09:12:02Serial Number TV112010980Elapsed Test Time 51m 33sStatus **PASS**

Page 2 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20