

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,7 (Setpoint 50) [10m	SLPM	42,3 to 53,1	47,0	✓	
37	0030.0290 Pos Flow Verify: dP2 at 38,0 (Setpoint 40) [10m	SLPM	33,0 to 43,0	37,7	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [10m	SLPM	23,4 to 32,6	28,6	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [10m	SLPM	15,0 to 25,0	20,0	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [10m	SLPM	5,5 to 14,5	10,5	✓	
41	0030.0330 Pos Flow Verify: dP2 at 4,8 (Setpoint 5) [10m 3	SLPM	1,1 to 8,6	5,0	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [10m	SLPM	-2,0 to 2,0	0,1	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,8 (Setpoint 140) [	SLPM	-147,9 to -129,8	-126,2		✗
44	0030.0560 Neg Flow Verify: dP2 at -128,3 (Setpoint 130) [	SLPM	-137,0 to -119,7	-117,0		✗
45	0030.0570 Neg Flow Verify: dP2 at -117,8 (Setpoint 120) [	SLPM	-126,0 to -109,6	-108,3		✗
46	0030.0580 Neg Flow Verify: dP2 at -108,0 (Setpoint 110) [	SLPM	-115,8 to -100,2	-100,0		✗
47	0030.0590 Neg Flow Verify: dP2 at -98,2 (Setpoint 100) [1	SLPM	-105,6 to -90,7	-91,5	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,7 (Setpoint 90) [15	SLPM	-95,7 to -81,6	-81,7	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,8 (Setpoint 80) [15	SLPM	-84,4 to -71,2	-70,9		✗
50	0030.0620 Neg Flow Verify: dP2 at -67,8 (Setpoint 70) [15	SLPM	-74,0 to -61,6	-62,2	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,7 (Setpoint 60) [15	SLPM	-63,5 to -51,9	-53,7	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [15	SLPM	-53,4 to -42,6	-44,8	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [15	SLPM	-43,0 to -33,0	-35,5	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [15	SLPM	-32,6 to -23,4	-26,4	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,7 (Setpoint 20) [15	SLPM	-24,7 to -14,7	-18,6	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [15	SLPM	-14,5 to -5,5	-9,2	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [15m	SLPM	-8,8 to -1,2	-4,7	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [15m	SLPM	-2,0 to 2,0	0,2	✓	
59	0030.0950 Contr.Press.Ver.(7949): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,21	✓	
60	0030.0960 Monit.Press.Ver.(4256): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
61	0030.0160 Pprox Press. Ver.(8778): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
62	0030.0970 Contr.Press.Ver.(10230): P1 at 3,68 (SP 4, 1, 1)	cmH2O	2,68 to 4,68	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6881): P2 at 3,68 (SP 4, 1, 1)	cmH2O	2,68 to 4,68	3,76	✓	
64	0030.0161 Pprox Press. Ver.(11038): P2 at 3,68 (SP 4, 1,	cmH2O	2,68 to 4,68	3,78	✓	
65	0030.0990 Contr.Press.Ver.(18652): P1 at 17,69 (SP 18, 1,	cmH2O	16,69 to 18,69	17,99	✓	
66	0030.1000 Monit.Press.Ver.(16594): P2 at 17,69 (SP 18, 1,	cmH2O	16,69 to 18,69	17,73	✓	
67	0030.0162 Pprox Press. Ver.(19379): P2 at 17,69 (SP 18, 1	cmH2O	16,69 to 18,69	17,73	✓	
68	0030.1010 Contr.Press.Ver.(27085): P1 at 31,66 (SP 32, 1,	cmH2O	30,66 to 32,66	32,00	✓	
69	0030.1020 Monit.Press.Ver.(26298): P2 at 31,66 (SP 32, 1,	cmH2O	30,66 to 32,66	31,71	✓	
70	0030.0163 Pprox Press. Ver.(27735): P2 at 31,66 (SP 32, 1	cmH2O	30,66 to 32,66	31,78	✓	

Test Started On 01/10/24 04:41:18Serial Number TV109120118Elapsed Test Time 34m 3sStatus **FAIL**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20