Test Software P/N 4102483

**Tested Part Number** 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



**Software Revision** 24.0.0.0

Prepared By P. Pascal

## Test Report

Step	Description	Units	Limits	Results	Pass	Fail
	•					T 411
36	0021.0570 02 Positive Flow Cal: dP1 at 64,8 (SP 65 @77,1P			1707	<b>√</b>	
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,2 (SP 75 @76,5P			1859	✓	
38	0021.0590 02 Positive Flow Cal: dP1 at 84,2 (SP 85 @76,0P			1994	✓	
3 9	0021.0600 02 Positive Flow Cal: dP1 at 94,0 (SP 95 @75,3P			2123	✓	
40	0021.0610 O2 Positive Flow Cal: dP1 at 105,0 (SP 105 @74,	ADC Cnts	LE 2355	2251	✓	
41	0021.0620 O2 Positive Flow Cal: dP1 at 114,8 (SP 115 @73,	ADC Cnts	LE 2454	2356	✓	
42	0021.0630 O2 Positive Flow Cal: dP1 at 123,7 (SP 125 @73,	ADC Cnts	LE 2545	2455	✓	
43	0021.0640 O2 Positive Flow Cal: dP1 at 133,8 (SP 135 @72,	ADC Cnts	LE 2645	2546	✓	
44	0021.0650 02 Positive Flow Cal: dPl at 144,3 (SP 145 @70,	ADC Cnts	LE 2917	2646	✓	
45	0021.0660 02 Positive Flow Cal: dP1 at 175,2 (SP 175 @67,	ADC Cnts	LE 3034	2918	✓	
46	0021.0670 02 Positive Flow Cal: dP1 at 190,0 (SP 190 @65,	ADC Cnts	LE 3999	3035	<b>√</b>	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 2 mV at ambient	N/A	Pass	FALSE		×
48	0021.0930 Write OBM Sensors Cal Table [18m 39s]	N/A	Pass	FALSE		<u>×</u>
				ļ		

**Test Started On** 02/02/24 01:21:28

Serial Number TV015092406

Elapsed Test Time 18m 39s

Status FAIL

Page 2 **of** 2