Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 64,5 (SP 65 @80,1P	ADC Cnts	LE 1788	1654	√	
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,3 (SP 75 @79,5P	ADC Cnts	LE 1922	1789	√	
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,3 (SP 85 @78,8P	ADC Cnts	LE 2052	1923	√	
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,0 (SP 95 @78,1P	ADC Cnts	LE 2176	2053	√	
40	0021.0610 O2 Positive Flow Cal: dP1 at 104,3 (SP 105 @77,	ADC Cnts	LE 2289	2177	√	
41	0021.0620 O2 Positive Flow Cal: dP1 at 115,0 (SP 115 @76,	ADC Cnts	LE 2389	2290	√	
42	0021.0630 O2 Positive Flow Cal: dP1 at 124,2 (SP 125 @75,	ADC Cnts	LE 2496	2390	√	
43	0021.0640 O2 Positive Flow Cal: dP1 at 134,9 (SP 135 @74,	ADC Cnts	LE 2582	2497	√	
44	0021.0650 O2 Positive Flow Cal: dP1 at 144,9 (SP 145 @73,	ADC Cnts	LE 2839	2583	√	
45	0021.0660 O2 Positive Flow Cal: dP1 at 174,3 (SP 175 @71,	ADC Cnts	LE 2968	2840	1	
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,8 (SP 190 @69,	ADC Cnts	LE 3999	2969	√	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 4 mV at ambient	N/A	Pass	FALSE		×
48	0021.0930 Write OBM Sensors Cal Table [36m 58s]	N/A	Pass	FALSE		×

Test Started On 02/06/24 03:49:11

Serial Number TV02001060E Elapsed Test Time 36m 58s

Status FAIL

Page 2 **of** 2