

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,8 (Setpoint 50) [11m	SLPM	42,4 to 53,2	49,0	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,2 (Setpoint 40) [11m	SLPM	32,2 to 42,2	38,5	✓	
38	0030.0300 Pos Flow Verify: dP2 at 27,7 (Setpoint 30) [11m	SLPM	23,1 to 32,3	28,4	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [11m	SLPM	15,0 to 25,0	19,7	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [11m	SLPM	5,5 to 14,5	9,9	✓	
41	0030.0330 Pos Flow Verify: dP2 at 4,8 (Setpoint 5) [11m 2	SLPM	1,1 to 8,6	4,4	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [11m	SLPM	-2,0 to 2,0	-0,3	✓	
43	0030.0550 Neg Flow Verify: dP2 at -139,0 (Setpoint 140) [	SLPM	-148,1 to -129,9	-139,9	✓	
44	0030.0560 Neg Flow Verify: dP2 at -128,0 (Setpoint 130) [	SLPM	-136,6 to -119,4	-130,0	✓	
45	0030.0570 Neg Flow Verify: dP2 at -118,2 (Setpoint 120) [	SLPM	-126,4 to -109,9	-120,3	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,2 (Setpoint 110) [	SLPM	-116,0 to -100,3	-110,4	✓	
47	0030.0590 Neg Flow Verify: dP2 at -99,0 (Setpoint 100) [1	SLPM	-106,5 to -91,5	-100,2	✓	
48	0030.0600 Neg Flow Verify: dP2 at -87,8 (Setpoint 90) [15	SLPM	-94,8 to -80,8	-88,5	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,7 (Setpoint 80) [15	SLPM	-84,3 to -71,1	-78,4	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,7 (Setpoint 70) [15	SLPM	-73,9 to -61,5	-69,3	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [15	SLPM	-63,8 to -52,2	-60,0	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [15	SLPM	-53,4 to -42,6	-50,3	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [15	SLPM	-43,0 to -33,0	-40,2	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [15	SLPM	-32,6 to -23,4	-30,0	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,5 (Setpoint 20) [15	SLPM	-24,5 to -14,5	-21,1	✓	
56	0030.0680 Neg Flow Verify: dP2 at -9,3 (Setpoint 10) [15m	SLPM	-13,8 to -4,8	-10,0	✓	
57	0030.0690 Neg Flow Verify: dP2 at -4,8 (Setpoint 5) [15m	SLPM	-8,6 to -1,1	-4,7	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [15m	SLPM	-2,0 to 2,0	-0,3	✓	
59	0030.0950 Contr.Press.Ver.(8194): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,02	✓	
60	0030.0960 Monit.Press.Ver.(4460): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,08	✓	
61	0030.0160 Pprox Press. Ver.(7957): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,06	✓	
62	0030.0970 Contr.Press.Ver.(10611): P1 at 3,96 (SP 4, 1, 1)	cmH2O	2,96 to 4,96	3,99	✓	
63	0030.0980 Monit.Press.Ver.(7268): P2 at 3,96 (SP 4, 1, 1)	cmH2O	2,96 to 4,96	4,06	✓	
64	0030.0161 Pprox Press. Ver.(10384): P2 at 3,96 (SP 4, 1,	cmH2O	2,96 to 4,96	4,01	✓	
65	0030.0990 Contr.Press.Ver.(19130): P1 at 18,04 (SP 18, 1,	cmH2O	17,04 to 19,04	18,00	✓	
66	0030.1000 Monit.Press.Ver.(17132): P2 at 18,04 (SP 18, 1,	cmH2O	17,04 to 19,04	18,06	✓	
67	0030.0162 Pprox Press. Ver.(18934): P2 at 18,04 (SP 18, 1	cmH2O	17,04 to 19,04	18,05	✓	
68	0030.1010 Contr.Press.Ver.(27644): P1 at 32,02 (SP 32, 1,	cmH2O	31,02 to 33,02	32,00	✓	
69	0030.1020 Monit.Press.Ver.(26946): P2 at 32,02 (SP 32, 1,	cmH2O	31,02 to 33,02	31,98	✓	
70	0030.0163 Pprox Press. Ver.(27473): P2 at 32,02 (SP 32, 1	cmH2O	31,02 to 33,02	32,03	✓	

Test Started On 12/21/23 09:20:36Serial Number TV119092629Elapsed Test Time 1 hr 5m 5sStatus **PASS**

Page 2 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.  
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20