ANDOVER 06-06-2024

Fluke Biomedical Ansur Test and Inspection Procedure

Copyright © 2000 - 2014 Fluke Biomedical

Test record

TEST PASSED

Test performed Components used

 Date:
 06-06-2024

 Record:
 IEC 60601-1 - CL2.mtr

 Template:
 IEC 60601-1 - CL2.mtt

Ansur Version 3.1.4 Plug-In: ESA612 Version 1.1.3

Test setup

Selections

Service events performed	Standards performed
	IEC 60601

Device under test

Número de serie	TV019020104	Modelo	TRILOGY 202
Estado	OPERATIVO	Localización	ANDOVER ALIANZA MEDICA S. A.
Fabricante	PHILIPS	Dirección 1	SALAR DE HUASCO 795, PUDAHUEL
Tipo	VENTILADOR MECANICO	Dirección 2	LABORATORIO

MTI Data

Test instrument	Serial number	Firmware version
FSA612B	6035002	v3 01

Signatures

IEC 60601-1 - CL2.mtr Página 1 de 2

Test result

Test element		Test ty	pe		F	Fail
IEC 60601-1 - CL2		Auto Se				
Procedure:	a tha ESA4	12 ac indi	catad in th	o operators man	ual	
(1) Connect the DUT to the ESA612 as indicated in the operators manual.(2) Ensure that DUT power is On.						
(3) Click module setup			ont loads t	hat are to be too	tod	
(4) Connect patient lea				nat are to be tes	ieu.	
(5) Click Start Test to						
(3) GHER Start rest to	periorii ti	ile salety	test.			
Configuration						
Polarity Switching Delay:3(s)						
Mains Voltage		Mains V	oltage			
Live to Neutral		Mains V				
Result:	1/0/	Live to N		l au limit	Ctamaland	
Live to Neutral	Value 219,6	Unit ∨	High limit	Low limit	Standard IEC 60601	
	,-	•				
Enclosure Leakage Current		Enclosui	re Leakage Curi	rent		
Configuration			· ·			
Unused Applied						
Parts:Floating						
		Fnclosu	re Leakage Curi	rent		
Normal Condition			Condition	. •		
Result:	Value	Unit	High limit	Low limit	Standard	
Normal Condition	0,5	uA	100		IEC 60601	
Open Neutral			re Leakage Curi	rent		
Result:	Value	Open Ne Unit	eutral High limit	Low limit	Standard	
Open Neutral	0,6	uA	500	LOW IIIIII	IEC 60601	
5	-,-					
Normal Condition, Reversed mains			re Leakage Curi			
	Value		Condition, Reve		Ctonde ::-	
Result: Normal Condition,	Value	Unit	High limit	Low limit	Standard	
Reversed mains	0,4	uA	100		IEC 60601	
Open Neutral, Reversed Mains			re Leakage Curi			
Result:	Value	Open Ne Unit	Open Neutral, Reversed Mains Unit High limit Low limit Standard			
Open Neutral,			Ū	LOW IIIIII		
Reversed Mains	0,6	uA	500		IEC 60601	

IEC 60601-1 - CL2.mtr Página 2 de 2