Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 64,0 (SP 65 @79,0P:	ADC Cnts	LE 1981	1822	√
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,5 (SP 75 @78,1P:	ADC Cnts	LE 2118	1982	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 83,2 (SP 85 @77,3P:	ADC Cnts	LE 2271	2120	√
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,9 (SP 95 @76,3P:	ADC Cnts	LE 2395	2272	√
40	0021.0610 02 Positive Flow Cal: dP1 at 104,8 (SP 105 @75,	ADC Cnts	LE 2517	2396	√
41	0021.0620 02 Positive Flow Cal: dPl at 114,5 (SP 115 @74,	ADC Cnts	LE 2625	2518	√
42	0021.0630 O2 Positive Flow Cal: dPl at 124,3 (SP 125 @73,	ADC Cnts	LE 2721	2626	√
43	0021.0640 O2 Positive Flow Cal: dPl at 134,0 (SP 135 @72,	ADC Cnts	LE 2818	2722	√
44	0021.0650 O2 Positive Flow Cal: dPl at 144,2 (SP 145 @71,	ADC Cnts	LE 3088	2819	
45	0021.0660 O2 Positive Flow Cal: dP1 at 174,8 (SP 175 @66,	ADC Cnts	LE 3212	3089	│
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,8 (SP 190 @64,	ADC Cnts	LE 3999	3213	→
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 663 mV at ambient a	N/A	Pass	TRUE	1
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	

Test Started On 06/25/24 04:56:16

Serial Number TV010110111 Elapsed Test Time 14m 57s

Status PASS

Page 2 **of** 2