Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 O2 Positive Flow Cal: dPl at 63,8 (SP 65 @76,1P)	ADC Cnts	LE 1829	1683	
37	0021.0580 O2 Positive Flow Cal: dPl at 74,3 (SP 75 @75,2P)	ADC Cnts	LE 1961	1830	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,2 (SP 85 @74,3P)	ADC Cnts	LE 2085	1962	√
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,4 (SP 95 @73,3P)	ADC Cnts	LE 2206	2086	√
40	0021.0610 O2 Positive Flow Cal: dP1 at 104,3 (SP 105 @72,	ADC Cnts	LE 2318	2207	√
41	0021.0620 O2 Positive Flow Cal: dPl at 114,3 (SP 115 @71,	ADC Cnts	LE 2431	2320	√
42	0021.0630 O2 Positive Flow Cal: dP1 at 124,0 (SP 125 @70,	ADC Cnts	LE 2531	2432	√
43	0021.0640 O2 Positive Flow Cal: dP1 at 134,3 (SP 135 @69,	ADC Cnts	LE 2623	2532	
44	0021.0650 O2 Positive Flow Cal: dP1 at 144,2 (SP 145 @67,	ADC Cnts	LE 2870	2624	
45	0021.0660 O2 Positive Flow Cal: dP1 at 173,1 (SP 175 @64,	ADC Cnts	LE 3004	2871	│
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,3 (SP 190 @61,	ADC Cnts	LE 3999	3006	
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 622 mV at ambient	N/A	Pass	TRUE	│
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	
					\bot

Test Started On 03/26/24 08:33:57

Elapsed Test Time 17m 29s

Serial Number TV016072711

Status PASS

Page 2 **of** 2