Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0021.0570 02 Positive Flow Cal: dP1 at 64,3 (SP 65 @76,9P	ADC Cnts	LE 1818	1668	√	
37	0021.0580 02 Positive Flow Cal: dP1 at 74,0 (SP 75 @76,2P	ADC Cnts	LE 1945	1819	√	
38	0021.0590 O2 Positive Flow Cal: dP1 at 83,5 (SP 85 @75,6P	ADC Cnts	LE 2078	1946	√	
39	0021.0600 02 Positive Flow Cal: dP1 at 94,3 (SP 95 @74,8P	ADC Cnts	LE 2201	2079	√	
40	0021.0610 02 Positive Flow Cal: dP1 at 104,0 (SP 105 @74,	ADC Cnts	LE 2324	2202	√	
41	0021.0620 02 Positive Flow Cal: dP1 at 114,5 (SP 115 @73,	ADC Cnts	LE 2428	2325	√	
42	0021.0630 02 Positive Flow Cal: dP1 at 124,7 (SP 125 @72,	ADC Cnts	LE 2528	2429	√	
43	0021.0640 O2 Positive Flow Cal: dP1 at 134,8 (SP 135 @71,	ADC Cnts	LE 2616	2528	√	
44	0021.0650 02 Positive Flow Cal: dP1 at 144,8 (SP 145 @70,	ADC Cnts	LE 2876	2617	√	
45	0021.0660 02 Positive Flow Cal: dP1 at 174,7 (SP 175 @68,	ADC Cnts	LE 3019	2877	√	
46	0021.0670 O2 Positive Flow Cal: dP1 at 191,0 (SP 190 @66,	ADC Cnts	LE 3999	3020	√	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 4 mV at ambient	N/A	Pass	FALSE		×
48	0021.0930 Write OBM Sensors Cal Table [15m 20s]	N/A	Pass	FALSE		×
						\vdash
						\vdash
					+	\vdash
						\vdash
						\vdash
						
					-	\vdash
					-	\vdash
					_	├─
					-	├
						—
						—
					_	├
						<u> </u>
						—
						<u> </u>
						<u> </u>
						Щ
						<u> </u>

Test Started On 08/16/24 10:13:49

Serial Number TV019041211 Elapsed Test Time 15m 20s

Status FAIL

Page 2 **of** 2