Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 O2 Positive Flow Cal: dPl at 64,9 (SP 65 @81,9P)	ADC Cnts	LE 1910	1772	→
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,8 (SP 75 @81,5P)	ADC Cnts	LE 2037	1911	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,0 (SP 85 @80,9P:	ADC Cnts	LE 2180	2038	√
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,8 (SP 95 @80,2P:	ADC Cnts	LE 2304	2181	√
40	0021.0610 O2 Positive Flow Cal: dP1 at 104,3 (SP 105 @79,	ADC Cnts	LE 2428	2305	√
41	0021.0620 02 Positive Flow Cal: dPl at 114,8 (SP 115 @78,	ADC Cnts	LE 2521	2430	√
42	0021.0630 02 Positive Flow Cal: dPl at 124,6 (SP 125 @77,	ADC Cnts	LE 2619	2522	√
43	0021.0640 O2 Positive Flow Cal: dP1 at 135,2 (SP 135 @76,	ADC Cnts	LE 2708	2620	
44	0021.0650 O2 Positive Flow Cal: dP1 at 144,5 (SP 145 @75,	ADC Cnts	LE 2958	2709	
45	0021.0660 O2 Positive Flow Cal: dP1 at 174,5 (SP 175 @72,	ADC Cnts	LE 3096	2959	→
46	0021.0670 O2 Positive Flow Cal: dP1 at 190,5 (SP 190 @70,	ADC Cnts	LE 3999	3097	
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 571 mV at ambient a	N/A	Pass	TRUE	→
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	→

Test Started On 06/07/24 12:59:58

Serial Number TV014121023 Elapsed Test Time 16m 30s

Status PASS

Page 2 **of** 2