Test Software P/N 4102483

**Tested Part Number** 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



**Software Revision** 24.0.0.0

Prepared By P. Pascal

## Test Report

Description			L COULTS	I Dogg I	النمتا
	Units	Limits	Results	Pass I	- ali
0021.0570 02 Positive Flow Cal: dP1 at 65,0 (SP 65 @78,1P:			1897	✓	
0021.0580 O2 Positive Flow Cal: dP1 at 75,0 (SP 75 @77,4P)	ADC Cnts		2035	✓	
0021.0590 O2 Positive Flow Cal: dP1 at 84,0 (SP 85 @76,6P:	ADC Cnts	LE 2295	2166	✓	
0021.0600 02 Positive Flow Cal: dP1 at 94,2 (SP 95 @75,8P	ADC Cnts	LE 2424	2296	✓	
0021.0610 02 Positive Flow Cal: dP1 at 104,4 (SP 105 @74,	ADC Cnts	LE 2534	2425	✓	
0021.0620 02 Positive Flow Cal: dP1 at 115,3 (SP 115 @73,	ADC Cnts	LE 2640	2535	✓	_
0021.0630 02 Positive Flow Cal: dP1 at 125,3 (SP 125 @72,	ADC Cnts	LE 2730	2640	✓	-
0021.0640 02 Positive Flow Cal: dPl at 136,0 (SP 135 @71,	ADC Cnts	LE 2811	2731	✓	- $ $
0021.0650 02 Positive Flow Cal: dPl at 145,3 (SP 145 @70,	ADC Cnts	LE 3076	2812	<b>√</b>	- $ $
0021.0660 02 Positive Flow Cal: dPl at 175,5 (SP 175 @67,	ADC Cnts	LE 3207	3077	<b>√</b>	-
0021.0670 02 Positive Flow Cal: dPl at 191,0 (SP 190 @65,	ADC Cnts	LE 3999	3208	<b>√</b>	-
0021.0880 02 Sensor Cal (NO_O2_ERROR): 553 mV at ambient	N/A	Pass	TRUE	<b>√</b>	-
0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	<b>√</b>	-
					-
					—
					-
					—
					—
					—
					—
					—
					—
					—
					—
					—
					_
	0021.0590 O2 Positive Flow Cal: dP1 at 84,0 (SP 85 @76,6P3 @7021.0600 O2 Positive Flow Cal: dP1 at 94,2 (SP 95 @75,8P3 @7021.0610 O2 Positive Flow Cal: dP1 at 104,4 (SP 105 @74,80021.0620 O2 Positive Flow Cal: dP1 at 115,3 (SP 115 @73,80021.0630 O2 Positive Flow Cal: dP1 at 125,3 (SP 125 @72,80021.0640 O2 Positive Flow Cal: dP1 at 136,0 (SP 135 @71,80021.0650 O2 Positive Flow Cal: dP1 at 136,0 (SP 135 @71,80021.0660 O2 Positive Flow Cal: dP1 at 145,3 (SP 145 @70,80021.0660 O2 Positive Flow Cal: dP1 at 175,5 (SP 175 @67,80021.0670 O2 Positive Flow Cal: dP1 at 191,0 (SP 190 @65,80021.0670 O2 Positive Flow Cal: dP1 at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 191,0 (SP 190 @65,80021.0880 O2 Sensor Cal (NO_O2_ERROR): 553 mV at ambient at 1	0021.0590 02 Positive Flow Cal: dP1 at 84,0 (SP 85 @76,6P; ADC Cnts 0021.0600 02 Positive Flow Cal: dP1 at 94,2 (SP 95 @75,8P; ADC Cnts 0021.0610 02 Positive Flow Cal: dP1 at 104,4 (SP 105 @74, ADC Cnts 0021.0620 02 Positive Flow Cal: dP1 at 115,3 (SP 115 @73, ADC Cnts 0021.0630 02 Positive Flow Cal: dP1 at 125,3 (SP 125 @72, ADC Cnts 0021.0640 02 Positive Flow Cal: dP1 at 136,0 (SP 135 @71, ADC Cnts 0021.0650 02 Positive Flow Cal: dP1 at 145,3 (SP 145 @70, ADC Cnts 0021.0660 02 Positive Flow Cal: dP1 at 175,5 (SP 175 @67, ADC Cnts 0021.0660 02 Positive Flow Cal: dP1 at 175,5 (SP 175 @67, ADC Cnts 0021.0670 02 Positive Flow Cal: dP1 at 191,0 (SP 190 @65, ADC Cnts 0021.0880 02 Sensor Cal (NO_O2_ERROR): 553 mV at ambient : N/A	0021.0590 02 Positive Flow Cal: dP1 at 84,0 (SP 85 @76,6P; DC Cnts LE 2295 0021.0600 02 Positive Flow Cal: dP1 at 94,2 (SP 95 @75,8P; DC Cnts LE 2424 0021.0610 02 Positive Flow Cal: dP1 at 104,4 (SP 105 @74, DC Cnts LE 2534 0021.0620 02 Positive Flow Cal: dP1 at 115,3 (SP 115 @73, DC Cnts LE 2640 0021.0630 02 Positive Flow Cal: dP1 at 125,3 (SP 125 @72, DC Cnts LE 2730 0021.0640 02 Positive Flow Cal: dP1 at 136,0 (SP 135 @71, DC Cnts LE 2811 0021.0650 02 Positive Flow Cal: dP1 at 145,3 (SP 145 @70, DC Cnts LE 3076 0021.0660 02 Positive Flow Cal: dP1 at 175,5 (SP 175 @67, DC Cnts LE 3207 0021.0670 02 Positive Flow Cal: dP1 at 191,0 (SP 190 @65, DC Cnts LE 3999 0021.0880 02 Sensor Cal (NO_O2_ERROR): 553 mV at ambient N/A Pass	0021.0590 02 Positive Flow Cal: dP1 at 84,0 (SP 85 @76,6P;DC Cnts LE 2295 2166 0021.0600 02 Positive Flow Cal: dP1 at 94,2 (SP 95 @75,8P;DC Cnts LE 2424 2296 0021.0610 02 Positive Flow Cal: dP1 at 104,4 (SP 105 @74, DC Cnts LE 2534 2425 0021.0620 02 Positive Flow Cal: dP1 at 115,3 (SP 115 @73, DC Cnts LE 2640 2535 0021.0630 02 Positive Flow Cal: dP1 at 125,3 (SP 125 @72, DC Cnts LE 2730 2640 0021.0640 02 Positive Flow Cal: dP1 at 136,0 (SP 135 @71, DC Cnts LE 2811 2731 0021.0650 02 Positive Flow Cal: dP1 at 145,3 (SP 145 @70, DC Cnts LE 3076 2812 0021.0660 02 Positive Flow Cal: dP1 at 175,5 (SP 175 @67, DC Cnts LE 3207 3077 0021.0670 02 Positive Flow Cal: dP1 at 191,0 (SP 190 @65, DC Cnts LE 3999 3208 0021.0880 02 Sensor Cal (NO_O2_ERROR): 553 mV at ambient : N/A Pass TRUE	0021.0590 02 Positive Flow Cal: dPl at 84,0 (SP 85 @76,6P, NDC Cnts

**Test Started On** 02/29/24 04:55:42

Serial Number TV016072707 Elapsed Test Time 15m 22s

Status PASS

Page 2 **of** 2