Test Software P/N 4102483

Tested Part Number LA1054096

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0020.0570 Pos Flow Cal: dP2 at 77,5 (Setpoint 75) [14m 13	ADC Cnts	LE 46930	45975	 ✓
37	0020.0580 Pos Flow Cal: dP2 at 87,2 (Setpoint 85) [14m 13	ADC Cnts	LE 47843	46931	√
38	0020.0590 Pos Flow Cal: dP2 at 96,8 (Setpoint 95) [14m 13	ADC Cnts	LE 48714	47844	√
39	0020.0600 Pos Flow Cal: dP2 at 107,2 (Setpoint 105) [14m	ADC Cnts	LE 49194	48715	√
40	0020.0610 Pos Flow Cal: dP2 at 113,7 (Setpoint 115) [14m	ADC Cnts	LE 49939	49195	√
41	0020.0620 Pos Flow Cal: dP2 at 123,5 (Setpoint 125) [14m	ADC Cnts	LE 50971	49940	√
42	0020.0630 Pos Flow Cal: dP2 at 137,7 (Setpoint 135) [14m	ADC Cnts	LE 51513	50972	√
43	0020.0640 Pos Flow Cal: dP2 at 147,7 (Setpoint 145) [14m	ADC Cnts	LE 52699	51514	√
44	0020.0650 Pos Flow Cal: dP2 at 167,0 (Setpoint 170) [14m	ADC Cnts	LE 53902	52700	√
45	0020.0660 Pos Flow Cal: dP2 at 188,3 (Setpoint 190) [14m	ADC Cnts	LE 65435	53903	√
46	0020.0900 Atmospheric Press Sensors Cal Patm: Slope (m) [lnHg/ADC	EQ 0,000517	0,000517	√
47	0020.0910 Atmospheric Press Sensors Cal Patm: Intercept (linHg	1,91 to 4,09	2,77	√
48	0020.0920 Write Sensors Cal Table [14m 36s]	N/A	Pass	TRUE	√
49	0020.0970 Write Pprox Cal Table [14m 53s]	N/A	Pass	TRUE	√
50	0020.0935 02 Sensor Cal (not attempted for SW ver.14.2.05	N/A	None	None	√
51	0020.1030 Write Image Table [15m 14s]	N/A	Pass	TRUE	√
					+
					+
					+
					+
		ldot			

Test Started On 07/19/24 02:42:17

Serial Number TV119091017 Elapsed Test Time 15m 14s

Status PASS

Page 2 **of** 2