

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0570 Neg Flow Verify: dP2 at -118,7 (Setpoint 120) [28m]	SLPM	-126,9 to -110,4	-119,7	✓	
37	0030.0580 Neg Flow Verify: dP2 at -108,8 (Setpoint 110) [28m]	SLPM	-116,7 to -101,0	-109,6	✓	
38	0030.0590 Neg Flow Verify: dP2 at -98,8 (Setpoint 100) [28m]	SLPM	-106,3 to -91,4	-99,5	✓	
39	0030.0600 Neg Flow Verify: dP2 at -88,8 (Setpoint 90) [28m]	SLPM	-95,9 to -81,8	-89,3	✓	
40	0030.0610 Neg Flow Verify: dP2 at -78,0 (Setpoint 80) [28m]	SLPM	-84,6 to -71,4	-79,0	✓	
41	0030.0620 Neg Flow Verify: dP2 at -68,0 (Setpoint 70) [28m]	SLPM	-74,2 to -61,8	-69,0	✓	
42	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [28m]	SLPM	-63,8 to -52,2	-59,2	✓	
43	0030.0640 Neg Flow Verify: dP2 at -48,3 (Setpoint 50) [28m]	SLPM	-53,8 to -42,9	-48,6	✓	
44	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [28m]	SLPM	-43,0 to -33,0	-38,5	✓	
45	0030.0660 Neg Flow Verify: dP2 at -28,8 (Setpoint 30) [28m]	SLPM	-33,5 to -24,2	-28,9	✓	
46	0030.0670 Neg Flow Verify: dP2 at -19,5 (Setpoint 20) [28m]	SLPM	-24,5 to -14,5	-19,6	✓	
47	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [28m]	SLPM	-14,5 to -5,5	-9,8	✓	
48	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [28m]	SLPM	-8,8 to -1,2	-5,0	✓	
49	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [28m]	SLPM	-2,0 to 2,0	-0,0	✓	
50	0030.0950 Contr.Press.Ver.(8074): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,11	✓	
51	0030.0960 Monit.Press.Ver.(4067): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
52	0030.0160 Pprox Press. Ver.(8106): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,07	✓	
53	0030.0970 Contr.Press.Ver.(10431): P1 at 3,86 (SP 4, 1, 1)	cmH2O	2,86 to 4,86	4,00	✓	
54	0030.0980 Monit.Press.Ver.(6775): P2 at 3,86 (SP 4, 1, 1)	cmH2O	2,86 to 4,86	3,76	✓	
55	0030.0161 Pprox Press. Ver.(10459): P2 at 3,86 (SP 4, 1, 1)	cmH2O	2,86 to 4,86	3,95	✓	
56	0030.0990 Contr.Press.Ver.(18907): P1 at 17,88 (SP 18, 1, 1)	cmH2O	16,88 to 18,88	18,00	✓	
57	0030.1000 Monit.Press.Ver.(16538): P2 at 17,88 (SP 18, 1, 1)	cmH2O	16,88 to 18,88	17,76	✓	
58	0030.0162 Pprox Press. Ver.(18891): P2 at 17,88 (SP 18, 1, 1)	cmH2O	16,88 to 18,88	17,92	✓	
59	0030.1010 Contr.Press.Ver.(27383): P1 at 31,86 (SP 32, 1, 1)	cmH2O	30,86 to 32,86	31,98	✓	
60	0030.1020 Monit.Press.Ver.(26290): P2 at 31,86 (SP 32, 1, 1)	cmH2O	30,86 to 32,86	31,72	✓	
61	0030.0163 Pprox Press. Ver.(27335): P2 at 31,86 (SP 32, 1, 1)	cmH2O	30,86 to 32,86	31,91	✓	
62	0030.1030 Contr.Press.Ver.(35870): P1 at 45,87 (SP 46, 1, 1)	cmH2O	44,87 to 46,87	45,98	✓	
63	0030.1040 Monit.Press.Ver.(36073): P2 at 45,87 (SP 46, 1, 1)	cmH2O	44,87 to 46,87	45,76	✓	
64	0030.0164 Pprox Press. Ver.(35815): P2 at 45,87 (SP 46, 1, 1)	cmH2O	44,87 to 46,87	45,95	✓	
65	0030.1050 Contr.Press.Ver.(38290): P1 at 49,88 (SP 50, 1, 1)	cmH2O	48,88 to 50,88	50,00	✓	
66	0030.1060 Monit.Press.Ver.(38867): P2 at 49,88 (SP 50, 1, 1)	cmH2O	48,88 to 50,88	49,76	✓	
67	0030.0165 Pprox Press. Ver.(38224): P2 at 49,88 (SP 50, 1, 1)	cmH2O	48,88 to 50,88	49,87	✓	
68	0030.1070 Contr.Press.Ver.(45910): P1 at 62,42 (SP 65, 1, 1)	cmH2O	61,42 to 63,42	62,54	✓	
69	0030.1080 Monit.Press.Ver.(47599): P2 at 62,42 (SP 65, 1, 1)	cmH2O	61,42 to 63,42	62,30	✓	
70	0030.0166 Pprox Press. Ver.(45816): P2 at 62,42 (SP 65, 1, 1)	cmH2O	61,42 to 63,42	62,49	✓	

Test Started On 02/02/24 09:14:05Serial Number TV018100939Elapsed Test Time 32m 50sStatus **PASS**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20