

Test Software P/N 4102483Tested Part Number LA1054096Test Software Name Trilogy FSA (PM TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

| Step | Description | Units | Limits | Results | Pass | Fail |
|------|--|-------|------------------|---------|------|------|
| 36 | 0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [10m | SLPM | 42,6 to 53,4 | 52,3 | ✓ | |
| 37 | 0030.0290 Pos Flow Verify: dP2 at 37,0 (Setpoint 40) [10m | SLPM | 32,0 to 42,0 | 41,6 | ✓ | |
| 38 | 0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [10m | SLPM | 23,4 to 32,6 | 31,3 | ✓ | |
| 39 | 0030.0310 Pos Flow Verify: dP2 at 19,7 (Setpoint 20) [10m | SLPM | 14,7 to 24,7 | 22,1 | ✓ | |
| 40 | 0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [10m | SLPM | 5,5 to 14,5 | 11,6 | ✓ | |
| 41 | 0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [10m 6 | SLPM | 1,2 to 8,8 | 6,6 | ✓ | |
| 42 | 0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [10m | SLPM | -2,0 to 2,0 | 1,6 | ✓ | |
| 43 | 0030.0550 Neg Flow Verify: dP2 at -138,5 (Setpoint 140) [| SLPM | -147,5 to -129,5 | -139,8 | ✓ | |
| 44 | 0030.0560 Neg Flow Verify: dP2 at -127,8 (Setpoint 130) [| SLPM | -136,4 to -119,2 | -129,5 | ✓ | |
| 45 | 0030.0570 Neg Flow Verify: dP2 at -118,2 (Setpoint 120) [| SLPM | -126,4 to -109,9 | -119,8 | ✓ | |
| 46 | 0030.0580 Neg Flow Verify: dP2 at -108,3 (Setpoint 110) [| SLPM | -116,1 to -100,5 | -109,4 | ✓ | |
| 47 | 0030.0590 Neg Flow Verify: dP2 at -97,8 (Setpoint 100) [1 | SLPM | -105,2 to -90,4 | -98,4 | ✓ | |
| 48 | 0030.0600 Neg Flow Verify: dP2 at -88,7 (Setpoint 90) [13 | SLPM | -95,7 to -81,6 | -87,8 | ✓ | |
| 49 | 0030.0610 Neg Flow Verify: dP2 at -78,0 (Setpoint 80) [13 | SLPM | -84,6 to -71,4 | -78,1 | ✓ | |
| 50 | 0030.0620 Neg Flow Verify: dP2 at -67,3 (Setpoint 70) [13 | SLPM | -73,5 to -61,1 | -69,5 | ✓ | |
| 51 | 0030.0630 Neg Flow Verify: dP2 at -57,2 (Setpoint 60) [13 | SLPM | -63,0 to -51,4 | -60,8 | ✓ | |
| 52 | 0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [13 | SLPM | -53,4 to -42,6 | -50,9 | ✓ | |
| 53 | 0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [13 | SLPM | -43,0 to -33,0 | -38,9 | ✓ | |
| 54 | 0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [13 | SLPM | -32,6 to -23,4 | -28,5 | ✓ | |
| 55 | 0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [13 | SLPM | -25,0 to -15,0 | -20,4 | ✓ | |
| 56 | 0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [13 | SLPM | -14,5 to -5,5 | -8,9 | ✓ | |
| 57 | 0030.0690 Neg Flow Verify: dP2 at -4,8 (Setpoint 5) [13m | SLPM | -8,6 to -1,1 | -3,4 | ✓ | |
| 58 | 0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [13m | SLPM | -2,0 to 2,0 | 1,6 | ✓ | |
| 59 | 0030.0950 Contr.Press.Ver.(9222): P1 at 0,00 (SP 0, 1, 1) | cmH2O | -1,00 to 1,00 | 0,00 | ✓ | |
| 60 | 0030.0960 Monit.Press.Ver.(4012): P2 at 0,00 (SP 0, 1, 1) | cmH2O | -1,00 to 1,00 | 0,00 | ✓ | |
| 61 | 0030.0160 Pprox Press. Ver.(8507): P2 at 0,00 (SP 0, 1, 1) | cmH2O | -1,00 to 1,00 | 0,00 | ✓ | |
| 62 | 0030.0970 Contr.Press.Ver.(11622): P1 at 3,96 (SP 4, 1, 1) | cmH2O | 2,96 to 4,96 | 3,99 | ✓ | |
| 63 | 0030.0980 Monit.Press.Ver.(6791): P2 at 3,96 (SP 4, 1, 1) | cmH2O | 2,96 to 4,96 | 3,93 | ✓ | |
| 64 | 0030.0161 Pprox Press. Ver.(10920): P2 at 3,96 (SP 4, 1, | cmH2O | 2,96 to 4,96 | 4,00 | ✓ | |
| 65 | 0030.0990 Contr.Press.Ver.(20027): P1 at 17,80 (SP 18, 1, | cmH2O | 16,80 to 18,80 | 18,00 | ✓ | |
| 66 | 0030.1000 Monit.Press.Ver.(16392): P2 at 17,80 (SP 18, 1, | cmH2O | 16,80 to 18,80 | 17,81 | ✓ | |
| 67 | 0030.0162 Pprox Press. Ver.(19182): P2 at 17,80 (SP 18, 1 | cmH2O | 16,80 to 18,80 | 17,84 | ✓ | |
| 68 | 0030.1010 Contr.Press.Ver.(28436): P1 at 31,74 (SP 32, 1, | cmH2O | 30,74 to 32,74 | 31,99 | ✓ | |
| 69 | 0030.1020 Monit.Press.Ver.(26075): P2 at 31,74 (SP 32, 1, | cmH2O | 30,74 to 32,74 | 31,80 | ✓ | |
| 70 | 0030.0163 Pprox Press. Ver.(27555): P2 at 31,74 (SP 32, 1 | cmH2O | 30,74 to 32,74 | 31,86 | ✓ | |

Test Started On 04/03/24 09:28:47Serial Number TV113021326Elapsed Test Time 48m 32sStatus **PASS**

Page 2 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20