Test Software P/N 4102483

**Tested Part Number** 1040000



**Software Revision** 24.0.0.0

Prepared By P. Pascal

## **Test Report**

36 37 38 39 40 41 42 43 44	Description  0021.0570 02 Positive Flow Cal: dP1 at 64,9 (SP 65 @80,5P3 021.0580 02 Positive Flow Cal: dP1 at 74,3 (SP 75 @79,7P3 0021.0590 02 Positive Flow Cal: dP1 at 84,0 (SP 85 @79,0P3 0021.0600 02 Positive Flow Cal: dP1 at 84,0 (SP 85 @79,0P3 0021.0610 02 Positive Flow Cal: dP1 at 94,0 (SP 95 @78,2P3 0021.0610 02 Positive Flow Cal: dP1 at 104,0 (SP 105 @77, 0021.0620 02 Positive Flow Cal: dP1 at 114,8 (SP 115 @76,0P3 0021.0620 02 Positive Flow Cal: dP	ADC Cnts ADC Cnts ADC Cnts ADC Cnts	LE 2050 LE 2186 LE 2300	1778 1921 2051 2187	Pass Fail
37 38 39 40 41 42 43	0021.0580 02 Positive Flow Cal: dPl at 74,3 (SP 75 @79,7P: 0021.0590 02 Positive Flow Cal: dPl at 84,0 (SP 85 @79,0P: 0021.0600 02 Positive Flow Cal: dPl at 94,0 (SP 95 @78,2P: 0021.0610 02 Positive Flow Cal: dPl at 104,0 (SP 105 @77, 0021.0620 02 Positive Flow Cal: dPl at 114,8 (SP 115 @76,	ADC Cnts ADC Cnts ADC Cnts ADC Cnts	LE 2050 LE 2186 LE 2300	1921 2051	<b>√</b>
38 39 40 41 42 43	0021.0590 02 Positive Flow Cal: dPl at 84,0 (SP 85 @79,0P: 0021.0600 02 Positive Flow Cal: dPl at 94,0 (SP 95 @78,2P: 0021.0610 02 Positive Flow Cal: dPl at 104,0 (SP 105 @77, 0021.0620 02 Positive Flow Cal: dPl at 114,8 (SP 115 @76,	ADC Cnts ADC Cnts	LE 2186 LE 2300	2051	<del>-   -   -  </del>
39 40 41 42 43 44	0021.0600 02 Positive Flow Cal: dPl at 94,0 (SP 95 @78,2P: 0021.0610 02 Positive Flow Cal: dPl at 104,0 (SP 105 @77, 0021.0620 02 Positive Flow Cal: dPl at 114,8 (SP 115 @76,	ADC Cnts	LE 2300		✓
40 41 42 43 44	0021.0610 02 Positive Flow Cal: dPl at 104,0 (SP 105 @77, 0021.0620 02 Positive Flow Cal: dPl at 114,8 (SP 115 @76,	ADC Cnts		2187	
41 42 43 44	0021.0620 02 Positive Flow Cal: dPl at 114,8 (SP 115 @76,		T TO 0410		✓
42 43 44			LE 2412	2300	✓
43	0001 0000 00 Desition Bloom Gal. 4D1 at 104 0 (GD 105 075	ADC Cnts	LE 2503	2413	✓
44	0021.0630 O2 Positive Flow Cal: dP1 at 124,2 (SP 125 @75,	ADC Cnts	LE 2607	2504	✓
	0021.0640 02 Positive Flow Cal: dP1 at 134,5 (SP 135 @74,	ADC Cnts	LE 2699	2608	✓
45	0021.0650 02 Positive Flow Cal: dP1 at 144,2 (SP 145 @73,	ADC Cnts	LE 2961	2700	✓
	0021.0660 O2 Positive Flow Cal: dPl at 174,5 (SP 175 @70,	ADC Cnts	LE 3087	2962	✓
46	0021.0670 02 Positive Flow Cal: dPl at 189,3 (SP 190 @69,	ADC Cnts	LE 3999	3088	✓
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 562 mV at ambient a	N/A	Pass	TRUE	<b>√</b>
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	✓
+					
+					
+					

**Test Started On** 02/13/24 10:51:01

Elapsed Test Time 20m 33s

Status PASS

Serial Number TV02001060E

Page 2 **of** 2