

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
71	0030.1030 Contr.Press.Ver.(35989): P1 at 45,97 (SP 46, 1,	cmH2O	44,97 to 46,97	45,98	✓	
72	0030.1040 Monit.Press.Ver.(36200): P2 at 45,97 (SP 46, 1,	cmH2O	44,97 to 46,97	45,88	✓	
73	0030.0164 Pprox Press. Ver.(35818): P2 at 45,97 (SP 46, 1	cmH2O	44,97 to 46,97	45,94	✓	
74	0030.1050 Contr.Press.Ver.(38404): P1 at 49,99 (SP 50, 1,	cmH2O	48,99 to 50,99	50,00	✓	
75	0030.1060 Monit.Press.Ver.(39003): P2 at 49,99 (SP 50, 1,	cmH2O	48,99 to 50,99	49,93	✓	
76	0030.0165 Pprox Press. Ver.(38235): P2 at 49,99 (SP 50, 1	cmH2O	48,99 to 50,99	49,95	✓	
77	0030.1070 Contr.Press.Ver.(46059): P1 at 62,71 (SP 65, 1,	cmH2O	61,71 to 63,71	62,66	✓	
78	0030.1080 Monit.Press.Ver.(47852): P2 at 62,71 (SP 65, 1,	cmH2O	61,71 to 63,71	62,65	✓	
79	0030.0166 Pprox Press. Ver.(45826): P2 at 62,71 (SP 65, 1	cmH2O	61,71 to 63,71	62,61	✓	
80	0030.1150 Atmospheric Pressure Verify: Patm at 28,05,28,0	inHg	27,45 to 28,65	28,05	✓	
81	0030.1250 Airstream Temperature (Tair) at 26,00 [20m 56s]	C deg	21,00 to 41,00	30,54	✓	
82	0040.0010 Keypad Backlight Test [21m 15s]	N/A	Pass	TRUE	✓	
83	0040.0020 LCD Backlight Test [21m 16s]	N/A	Pass	TRUE	✓	
84	0040.0030 Primary Audible Alarm Soft [21m 23s]	N/A	Pass	TRUE	✓	
85	0040.0040 Primary Audible Alarm Soft heard by HW (1) [21m	N/A	Pass	TRUE	✓	
86	0040.0050 Primary Audible Alarm Loud [21m 23s]	N/A	Pass	TRUE	✓	
87	0040.0060 Primary Audible Alarm Loud heard by HW (1) [21m	N/A	Pass	TRUE	✓	
88	0040.0070 Red Alarm LED [21m 25s]	N/A	Pass	TRUE	✓	
89	0040.0080 Yellow Alarm LED [21m 25s]	N/A	Pass	TRUE	✓	
90	0040.0090 Secondary Audible Alarm Soft [21m 33s]	N/A	Pass	TRUE	✓	
91	0040.0100 Secondary Audible Alarm Soft heard by HW (1) [2	N/A	Pass	TRUE	✓	
92	0040.0110 Secondary Audible Alarm Loud [21m 33s]	N/A	Pass	TRUE	✓	
93	0040.0120 Secondary Audible Alarm Loud heard by HW (1) [2	N/A	Pass	TRUE	✓	
94	0040.0130 LCD Brightness [21m 39s]	N/A	Pass	TRUE	✓	
95	0040.0140 LCD screen test [21m 40s]	N/A	Pass	TRUE	✓	
96	0040.0150 120 VAC Power Source EPAP Current (1) [26m 22s]	A	0,15 to 1,30	0,29	✓	
97	0040.0160 120 VAC Power Source IPAP Current (1) [26m 22s]	A	0,25 to 1,60	0,39	✓	
98	0040.0170 Detach. Li-Ion Batt. Charge (at 52% Cap.) (1)	mA	GE 250,00	1834,00	✓	
99	0040.0180 Uninterrupted Operation (1) [26m 22s]	N/A	Pass	TRUE	✓	
100	0040.0190 AC Power Source Recognition (1) [26m 22s]	N/A	EQ 120V AC Power	120V AC Power	✓	
101	0040.0200 AC Power Source LED ON (1) [26m 22s]	N/A	Pass	TRUE	✓	
102	0040.0210 240 VAC Power Source EPAP Current (1) [26m 42s]	A	0,07 to 0,80	0,29	✓	
103	0040.0220 240 VAC Power Source IPAP Current (1) [26m 42s]	A	0,12 to 1,00	0,38	✓	
104	0040.0230 Uninterrupted Operation (1) [26m 42s]	N/A	Pass	TRUE	✓	
105	0040.0240 AC Power Source Recognition (1) [26m 42s]	N/A	EQ 120V AC Power	120V AC Power	✓	

Test Started On 08/28/24 11:15:30Serial Number TV118091513Elapsed Test Time 58m 2sStatus **PASS**

Page 3 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20