

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [9m	SLPM	42,6 to 53,4	44,4	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,8 (Setpoint 40) [9m	SLPM	32,8 to 42,8	34,7	✓	
38	0030.0300 Pos Flow Verify: dP2 at 27,2 (Setpoint 30) [9m	SLPM	22,6 to 31,8	24,1	✓	
39	0030.0310 Pos Flow Verify: dP2 at 19,9 (Setpoint 20) [9m	SLPM	14,9 to 24,9	15,5	✓	
40	0030.0320 Pos Flow Verify: dP2 at 9,8 (Setpoint 10) [9m 1	SLPM	5,3 to 14,3	5,8	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [9m 13	SLPM	1,2 to 8,8	0,2		✗
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [9m 2	SLPM	-2,0 to 2,0	-4,9		✗
43	0030.0550 Neg Flow Verify: dP2 at -139,3 (Setpoint 140) [SLPM	-148,4 to -130,3	-140,8	✓	
44	0030.0560 Neg Flow Verify: dP2 at -127,8 (Setpoint 130) [SLPM	-136,4 to -119,2	-128,8	✓	
45	0030.0570 Neg Flow Verify: dP2 at -118,0 (Setpoint 120) [SLPM	-126,2 to -109,8	-119,5	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,1 (Setpoint 110) [SLPM	-116,0 to -100,3	-109,3	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,3 (Setpoint 100) [1	SLPM	-105,8 to -90,9	-98,3	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,5 (Setpoint 90) [13	SLPM	-95,5 to -81,5	-87,8	✓	
49	0030.0610 Neg Flow Verify: dP2 at -78,0 (Setpoint 80) [13	SLPM	-84,6 to -71,4	-77,8	✓	
50	0030.0620 Neg Flow Verify: dP2 at -68,0 (Setpoint 70) [13	SLPM	-74,2 to -61,8	-68,8	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [13	SLPM	-63,8 to -52,2	-59,6	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [13	SLPM	-53,4 to -42,6	-49,4	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [13	SLPM	-43,0 to -33,0	-40,2	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [13	SLPM	-32,6 to -23,4	-30,9	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,7 (Setpoint 20) [13	SLPM	-24,7 to -14,7	-23,2	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [13	SLPM	-14,5 to -5,5	-14,4	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [13m	SLPM	-8,8 to -1,2	-9,6		✗
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [13m	SLPM	-2,0 to 2,0	-4,9		✗
59	0030.0950 Contr.Press.Ver.(8638): P1 at 0,00 (SP 0, 1, 2)	cmH2O	-1,00 to 1,00	0,06	✓	
60	0030.0960 Monit.Press.Ver.(3749): P2 at 0,00 (SP 0, 1, 2)	cmH2O	-1,00 to 1,00	0,04	✓	
61	0030.0160 Pprox Press. Ver.(8672): P2 at 0,00 (SP 0, 1, 2)	cmH2O	-1,00 to 1,00	0,00	✓	
62	0030.0970 Contr.Press.Ver.(11010): P1 at 3,94 (SP 4, 1, 2)	cmH2O	2,94 to 4,94	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6499): P2 at 3,94 (SP 4, 1, 2)	cmH2O	2,94 to 4,94	3,98	✓	
64	0030.0161 Pprox Press. Ver.(8668): P2 at 3,94 (SP 4, 1, 2)	cmH2O	2,94 to 4,94	0,00		✗
65	0030.0990 Contr.Press.Ver.(19452): P1 at 17,97 (SP 18, 1,	cmH2O	16,97 to 18,97	18,00	✓	
66	0030.1000 Monit.Press.Ver.(16284): P2 at 17,97 (SP 18, 1,	cmH2O	16,97 to 18,97	18,01	✓	
67	0030.0162 Pprox Press. Ver.(8663): P2 at 17,97 (SP 18, 1,	cmH2O	16,97 to 18,97	0,00		✗
68	0030.1010 Contr.Press.Ver.(27882): P1 at 32,02 (SP 32, 1,	cmH2O	31,02 to 33,02	31,99	✓	
69	0030.1020 Monit.Press.Ver.(26113): P2 at 32,02 (SP 32, 1,	cmH2O	31,02 to 33,02	32,08	✓	
70	0030.0163 Pprox Press. Ver.(8660): P2 at 32,02 (SP 32, 1,	cmH2O	31,02 to 33,02	0,00		✗

Test Started On 03/27/24 11:12:19Serial Number TV112010957Elapsed Test Time 17m 15sStatus **FAIL**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20