Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 02 Positive Flow Cal: dP1 at 64,0 (SP 65 @80,1P	ADC Cnts	LE 1871	1733	<u> </u>
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,0 (SP 75 @79,2P	ADC Cnts	LE 2000	1872	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,2 (SP 85 @78,2P	ADC Cnts	LE 2126	2001	√
39	0021.0600 02 Positive Flow Cal: dP1 at 94,3 (SP 95 @77,2P	ADC Cnts	LE 2255	2127	√
40	0021.0610 02 Positive Flow Cal: dP1 at 104,5 (SP 105 @76,	ADC Cnts	LE 2360	2256	√
41	0021.0620 O2 Positive Flow Cal: dP1 at 115,5 (SP 115 @74,	ADC Cnts	LE 2454	2361	√
42	0021.0630 O2 Positive Flow Cal: dP1 at 125,3 (SP 125 @73,	ADC Cnts	LE 2562	2455	√
43	0021.0640 02 Positive Flow Cal: dP1 at 135,5 (SP 135 @72,	ADC Cnts	LE 2640	2564	√
44	0021.0650 02 Positive Flow Cal: dP1 at 145,8 (SP 145 @71,	ADC Cnts	LE 2887	2641	√
45	0021.0660 02 Positive Flow Cal: dP1 at 174,8 (SP 175 @69,	ADC Cnts	LE 3014	2888	√
46	0021.0670 O2 Positive Flow Cal: dP1 at 190,7 (SP 190 @67,	ADC Cnts	LE 3999	3015	√
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 589 mV at ambient	N/A	Pass	TRUE	√
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	√
					+
					+
					+
					+
					+
					
					++-
					- - -
					+
					+
					+

Test Started On 02/27/24 09:45:45

Serial Number TV011062408 Elapsed Test Time 15m 9s

Page 2 **of** 2