

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,7 (Setpoint 50) [11m	SLPM	42,3 to 53,1	53,7		✗
37	0030.0290 Pos Flow Verify: dP2 at 37,0 (Setpoint 40) [11m	SLPM	32,0 to 42,0	42,0	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [11m	SLPM	23,4 to 32,6	31,4	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [11m	SLPM	15,0 to 25,0	21,5	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [11m	SLPM	5,5 to 14,5	11,0	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [11m 3	SLPM	1,2 to 8,8	5,6	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [11m	SLPM	-2,0 to 2,0	0,6	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,8 (Setpoint 140) [SLPM	-147,9 to -129,8	-122,6		✗
44	0030.0560 Neg Flow Verify: dP2 at -127,7 (Setpoint 130) [SLPM	-136,3 to -119,1	-113,8		✗
45	0030.0570 Neg Flow Verify: dP2 at -117,8 (Setpoint 120) [SLPM	-126,0 to -109,6	-105,4		✗
46	0030.0580 Neg Flow Verify: dP2 at -108,3 (Setpoint 110) [SLPM	-116,2 to -100,5	-96,6		✗
47	0030.0590 Neg Flow Verify: dP2 at -98,2 (Setpoint 100) [1	SLPM	-105,6 to -90,7	-87,9		✗
48	0030.0600 Neg Flow Verify: dP2 at -88,2 (Setpoint 90) [15	SLPM	-95,2 to -81,1	-78,2		✗
49	0030.0610 Neg Flow Verify: dP2 at -77,9 (Setpoint 80) [15	SLPM	-84,5 to -71,2	-69,4		✗
50	0030.0620 Neg Flow Verify: dP2 at -67,5 (Setpoint 70) [15	SLPM	-73,7 to -61,3	-61,8	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,8 (Setpoint 60) [15	SLPM	-63,6 to -52,0	-52,6	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [15	SLPM	-53,4 to -42,6	-44,3	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [15	SLPM	-43,0 to -33,0	-35,5	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [15	SLPM	-32,6 to -23,4	-26,9	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,7 (Setpoint 20) [15	SLPM	-24,7 to -14,7	-19,1	✓	
56	0030.0680 Neg Flow Verify: dP2 at -9,7 (Setpoint 10) [15m	SLPM	-14,2 to -5,2	-8,9	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [15m	SLPM	-8,8 to -1,2	-4,2	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [15m	SLPM	-2,0 to 2,0	0,6	✓	
59	0030.0950 Contr.Press.Ver.(8898): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,08	✓	
60	0030.0960 Monit.Press.Ver.(3502): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,08	✓	
61	0030.0160 Pprox Press. Ver.(9132): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,02	✓	
62	0030.0970 Contr.Press.Ver.(11258): P1 at 3,91 (SP 4, 1, 1)	cmH2O	2,91 to 4,91	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6251): P2 at 3,91 (SP 4, 1, 1)	cmH2O	2,91 to 4,91	3,99	✓	
64	0030.0161 Pprox Press. Ver.(11538): P2 at 3,91 (SP 4, 1,	cmH2O	2,91 to 4,91	4,00	✓	
65	0030.0990 Contr.Press.Ver.(19694): P1 at 18,00 (SP 18, 1,	cmH2O	17,00 to 19,00	18,00	✓	
66	0030.1000 Monit.Press.Ver.(16105): P2 at 18,00 (SP 18, 1,	cmH2O	17,00 to 19,00	18,04	✓	
67	0030.0162 Pprox Press. Ver.(20040): P2 at 18,00 (SP 18, 1	cmH2O	17,00 to 19,00	18,11	✓	
68	0030.1010 Contr.Press.Ver.(28142): P1 at 31,98 (SP 32, 1,	cmH2O	30,98 to 32,98	32,00	✓	
69	0030.1020 Monit.Press.Ver.(25911): P2 at 31,98 (SP 32, 1,	cmH2O	30,98 to 32,98	32,03	✓	
70	0030.0163 Pprox Press. Ver.(28471): P2 at 31,98 (SP 32, 1	cmH2O	30,98 to 32,98	32,14	✓	

Test Started On 01/08/24 01:04:42Serial Number TV110052651Elapsed Test Time 20m 6sStatus **TERMINATED**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 1FF8, 05/05/23 08:20