Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

	Tost Report						
Step	Description	Units	Limits	Results	Pass	Fail	
36	0021.0570 O2 Positive Flow Cal: dP1 at 64,7 (SP 65 @80,9P	ADC Cnts	LE 1895	1759	√		
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,3 (SP 75 @80,1P	ADC Cnts	LE 2022	1896	√		
38	0021.0590 O2 Positive Flow Cal: dP1 at 83,3 (SP 85 @79,4P	ADC Cnts	LE 2157	2023	√		
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,3 (SP 95 @78,6P	ADC Cnts	LE 2273	2158	√	_	
40	0021.0610 02 Positive Flow Cal: dP1 at 103,8 (SP 105 @77,	ADC Cnts	LE 2389	2274	√		
41	0021.0620 02 Positive Flow Cal: dP1 at 114,5 (SP 115 @76,	ADC Cnts	LE 2490	2390	√		
42	0021.0630 O2 Positive Flow Cal: dP1 at 123,8 (SP 125 @76,	ADC Cnts	LE 2586	2491	√		
43	0021.0640 O2 Positive Flow Cal: dP1 at 134,7 (SP 135 @75,	ADC Cnts	LE 2670	2587	√		
44	0021.0650 O2 Positive Flow Cal: dP1 at 143,5 (SP 145 @74,	ADC Cnts	LE 2917	2671	√	_	
45	0021.0660 O2 Positive Flow Cal: dP1 at 173,3 (SP 175 @71,	ADC Cnts	LE 3040	2918	√	_	
46	0021.0670 O2 Positive Flow Cal: dP1 at 188,8 (SP 190 @69,	ADC Cnts	LE 3999	3041	√	_	
47	0021.0880 02 Sensor Cal (NO_02_ERROR): 541 mV at ambient	N/A	Pass	TRUE	√	_	
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	√	_	
						_	
						_	
						_	
						_	
					+++		
					+		
-							
					-		
					-		
					+		
					+		
						—	
					+	—	
					+		
		<u> </u>					

Test Started On 03/18/24 11:04:40

Serial Number TV011062402 Elapsed Test Time 17m 9s

Status PASS

Page 2 **of** 2