Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 64,0 (SP 65 @81,6P	\DC Cnts	LE 1912	1758	√	
37	0021.0580 02 Positive Flow Cal: dP1 at 75,5 (SP 75 @80,6P	ADC Cnts	LE 2030	1913	✓	
38	0021.0590 02 Positive Flow Cal: dP1 at 84,7 (SP 85 @79,9P	ADC Cnts	LE 2148	2031	✓	
39	0021.0600 02 Positive Flow Cal: dP1 at 94,2 (SP 95 @79,0P	ADC Cnts	LE 2278	2149	✓	
40	0021.0610 02 Positive Flow Cal: dP1 at 104,7 (SP 105 @77,	ADC Cnts	LE 2389	2280	✓	
41	0021.0620 02 Positive Flow Cal: dP1 at 113,8 (SP 115 @76,	ADC Cnts	LE 2493	2390	✓	
42	0021.0630 O2 Positive Flow Cal: dP1 at 123,5 (SP 125 @75,	ADC Cnts	LE 2597	2494	✓	
43	0021.0640 02 Positive Flow Cal: dP1 at 134,7 (SP 135 @74,	ADC Cnts	LE 2688	2598	✓	
44	0021.0650 02 Positive Flow Cal: dP1 at 144,5 (SP 145 @73,	ADC Cnts	LE 2948	2690	✓	
45	0021.0660 02 Positive Flow Cal: dP1 at 174,2 (SP 175 @69,	ADC Cnts	LE 3084	2949	✓	
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,2 (SP 190 @67,	ADC Cnts	LE 3999	3085	✓	
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 3 mV at ambient	N/A	Pass	FALSE		×
48	0021.0930 Write OBM Sensors Cal Table [19m 2s]	N/A	Pass	FALSE		×
					-	

Test Started On 04/08/24 10:19:47

Serial Number TV01602190B Elapsed Test Time 19m 2s

Page 2 **of** 2