

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [13m	SLPM	42,6 to 53,4	36,2		✗
37	0030.0290 Pos Flow Verify: dP2 at 37,9 (Setpoint 40) [13m	SLPM	32,8 to 42,9	27,7		✗
38	0030.0300 Pos Flow Verify: dP2 at 27,8 (Setpoint 30) [13m	SLPM	23,2 to 32,4	19,1		✗
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [13m	SLPM	15,0 to 25,0	10,8		✗
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [13m	SLPM	5,5 to 14,5	2,3		✗
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [13m 3	SLPM	1,2 to 8,8	-2,2		✗
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [13m	SLPM	-2,0 to 2,0	-6,3		✗
43	0030.0550 Neg Flow Verify: dP2 at -139,0 (Setpoint 140) [SLPM	-148,1 to -129,9	-78,5		✗
44	0030.0560 Neg Flow Verify: dP2 at -127,8 (Setpoint 130) [SLPM	-136,4 to -119,2	-74,7		✗
45	0030.0570 Neg Flow Verify: dP2 at -117,9 (Setpoint 120) [SLPM	-126,1 to -109,6	-71,5		✗
46	0030.0580 Neg Flow Verify: dP2 at -107,7 (Setpoint 110) [SLPM	-115,5 to -99,9	-67,8		✗
47	0030.0590 Neg Flow Verify: dP2 at -98,4 (Setpoint 100) [1	SLPM	-105,9 to -91,0	-64,1		✗
48	0030.0600 Neg Flow Verify: dP2 at -88,0 (Setpoint 90) [16	SLPM	-95,0 to -81,0	-59,1		✗
49	0030.0610 Neg Flow Verify: dP2 at -77,8 (Setpoint 80) [16	SLPM	-84,4 to -71,2	-54,5		✗
50	0030.0620 Neg Flow Verify: dP2 at -68,0 (Setpoint 70) [16	SLPM	-74,2 to -61,8	-50,1		✗
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [16	SLPM	-63,8 to -52,2	-45,2		✗
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [16	SLPM	-53,4 to -42,6	-39,4		✗
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [16	SLPM	-43,0 to -33,0	-32,7		✗
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [16	SLPM	-32,6 to -23,4	-25,7	✓	
55	0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [16	SLPM	-25,0 to -15,0	-19,9	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [16	SLPM	-14,5 to -5,5	-12,6	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [16m	SLPM	-8,8 to -1,2	-9,1		✗
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [16m	SLPM	-2,0 to 2,0	-6,3		✗
59	0030.0950 Contr.Press.Ver.(8582): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,07	✓	
60	0030.0960 Monit.Press.Ver.(3851): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
61	0030.0160 Pprox Press. Ver.(9100): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,03	✓	
62	0030.0970 Contr.Press.Ver.(10939): P1 at 3,91 (SP 4, 1, 1)	cmH2O	2,91 to 4,91	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6565): P2 at 3,91 (SP 4, 1, 1)	cmH2O	2,91 to 4,91	3,89	✓	
64	0030.0161 Pprox Press. Ver.(11449): P2 at 3,91 (SP 4, 1,	cmH2O	2,91 to 4,91	3,95	✓	
65	0030.0990 Contr.Press.Ver.(19342): P1 at 17,92 (SP 18, 1,	cmH2O	16,92 to 18,92	17,98	✓	
66	0030.1000 Monit.Press.Ver.(16324): P2 at 17,92 (SP 18, 1,	cmH2O	16,92 to 18,92	17,91	✓	
67	0030.0162 Pprox Press. Ver.(19872): P2 at 17,92 (SP 18, 1	cmH2O	16,92 to 18,92	17,97	✓	
68	0030.1010 Contr.Press.Ver.(27749): P1 at 31,88 (SP 32, 1,	cmH2O	30,88 to 32,88	31,99	✓	
69	0030.1020 Monit.Press.Ver.(26069): P2 at 31,88 (SP 32, 1,	cmH2O	30,88 to 32,88	31,90	✓	
70	0030.0163 Pprox Press. Ver.(28268): P2 at 31,88 (SP 32, 1	cmH2O	30,88 to 32,88	32,04	✓	

Test Started On 01/12/24 10:02:54Serial Number TV11412164BElapsed Test Time 20m 47sStatus **FAIL**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20