

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,5 (Setpoint 50) [12m	SLPM	42,1 to 52,9	51,3	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,8 (Setpoint 40) [12m	SLPM	32,8 to 42,8	40,4	✓	
38	0030.0300 Pos Flow Verify: dP2 at 27,7 (Setpoint 30) [12m	SLPM	23,1 to 32,3	28,9	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [12m	SLPM	15,0 to 25,0	20,5	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [12m	SLPM	5,5 to 14,5	10,4	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [12m 2	SLPM	1,2 to 8,8	5,5	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [12m	SLPM	-2,0 to 2,0	0,6	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,8 (Setpoint 140) [	SLPM	-147,9 to -129,8	-126,8		✗
44	0030.0560 Neg Flow Verify: dP2 at -128,2 (Setpoint 130) [	SLPM	-136,8 to -119,5	-117,8		✗
45	0030.0570 Neg Flow Verify: dP2 at -117,8 (Setpoint 120) [	SLPM	-126,0 to -109,6	-108,8		✗
46	0030.0580 Neg Flow Verify: dP2 at -107,8 (Setpoint 110) [	SLPM	-115,6 to -100,0	-99,6		✗
47	0030.0590 Neg Flow Verify: dP2 at -98,7 (Setpoint 100) [1	SLPM	-106,1 to -91,2	-90,7		✗
48	0030.0600 Neg Flow Verify: dP2 at -88,5 (Setpoint 90) [18	SLPM	-95,5 to -81,5	-80,9		✗
49	0030.0610 Neg Flow Verify: dP2 at -77,7 (Setpoint 80) [18	SLPM	-84,3 to -71,1	-71,2	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,3 (Setpoint 70) [18	SLPM	-73,5 to -61,1	-63,8	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,3 (Setpoint 60) [18	SLPM	-63,1 to -51,5	-54,3	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [18	SLPM	-53,4 to -42,6	-45,7	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [18	SLPM	-43,0 to -33,0	-36,7	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [18	SLPM	-32,6 to -23,4	-28,1	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,7 (Setpoint 20) [18	SLPM	-24,7 to -14,7	-20,1	✓	
56	0030.0680 Neg Flow Verify: dP2 at -9,7 (Setpoint 10) [18m	SLPM	-14,2 to -5,2	-9,0	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [18m	SLPM	-8,8 to -1,2	-4,4	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [18m	SLPM	-2,0 to 2,0	0,6	✓	
59	0030.0950 Contr.Press.Ver.(8896): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,09	✓	
60	0030.0960 Monit.Press.Ver.(3501): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,10	✓	
61	0030.0160 Pprox Press. Ver.(9133): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,04	✓	
62	0030.0970 Contr.Press.Ver.(11249): P1 at 3,87 (SP 4, 1, 1)	cmH2O	2,87 to 4,87	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6244): P2 at 3,87 (SP 4, 1, 1)	cmH2O	2,87 to 4,87	4,00	✓	
64	0030.0161 Pprox Press. Ver.(11524): P2 at 3,87 (SP 4, 1,	cmH2O	2,87 to 4,87	4,01	✓	
65	0030.0990 Contr.Press.Ver.(19689): P1 at 17,94 (SP 18, 1,	cmH2O	16,94 to 18,94	18,00	✓	
66	0030.1000 Monit.Press.Ver.(16094): P2 at 17,94 (SP 18, 1,	cmH2O	16,94 to 18,94	18,05	✓	
67	0030.0162 Pprox Press. Ver.(20020): P2 at 17,94 (SP 18, 1	cmH2O	16,94 to 18,94	18,09	✓	
68	0030.1010 Contr.Press.Ver.(28131): P1 at 31,93 (SP 32, 1,	cmH2O	30,93 to 32,93	32,00	✓	
69	0030.1020 Monit.Press.Ver.(25906): P2 at 31,93 (SP 32, 1,	cmH2O	30,93 to 32,93	32,05	✓	
70	0030.0163 Pprox Press. Ver.(28489): P2 at 31,93 (SP 32, 1	cmH2O	30,93 to 32,93	32,09	✓	

Test Started On 01/08/24 03:24:42Serial Number TV110052651Elapsed Test Time 24m 4sStatus **FAIL**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.  
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20