

Test Software P/N 4102483Tested Part Number 1040000Test Software Name Trilogy FSA (REPAIR TEST)Software Revision 24.0.0.0Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
1	0021.0007 OBM O2 Sensor Heater On (NO_O2_ERROR) [0s]	N/A	Pass	TRUE	✓	
2	0021.0010 O2 Press Sensor Cal P1@ 25,10 & 75,30 PSI: Slope	ADC Cnts	0,03010 to 0,0510	0,03318	✓	
3	0021.0020 O2 Press Sensor Cal P1@ 25,10 & 75,30 PSI: Inter	PSI	-25,00 to -10,00	-13,20	✓	
4	0021.0030 O2 Press Sensor Cal P1@ 25,10 & 75,30 PSI: Zero	ADC Cnts	320 to 490	404	✓	
5	0021.0120 Neg Flow Cal: dP2 at -44,0 (Setpoint 45) [4m 21s]	ADC Cnts	GE 101	307	✓	
6	0021.0130 Neg Flow Cal: dP2 at -33,0 (Setpoint 35) [4m 21s]	ADC Cnts	GE 308	472	✓	
7	0021.0140 Neg Flow Cal: dP2 at -23,0 (Setpoint 25) [4m 21s]	ADC Cnts	GE 473	657	✓	
8	0021.0150 Neg Flow Cal: dP2 at -14,7 (Setpoint 15) [4m 21s]	ADC Cnts	GE 658	872	✓	
9	0021.0160 Neg Flow Cal: dP2 at -5,0 (Setpoint 5) [4m 21s]	ADC Cnts	GE 873	1043	✓	
10	0021.0170 Neg Flow Cal: dP2 at -0,0 (Setpoint 0) [4m 21s]	ADC Cnts	GE 1044	1149	✓	
11	0021.0250 Raw Zero Flow: dP2 at 0,0 (Setpoint 0) [4m 21s]	ADC Cnts	GE 0	1149	✓	
12	0021.0300 Pos Flow Cal: dP2 at 5,0 (Setpoint 5) [8m 24s]	ADC Cnts	LE 1685	1414	✓	
13	0021.0310 Pos Flow Cal: dP2 at 15,0 (Setpoint 15) [8m 24s]	ADC Cnts	LE 1914	1686	✓	
14	0021.0320 Pos Flow Cal: dP2 at 27,8 (Setpoint 25) [8m 24s]	ADC Cnts	LE 2082	1914	✓	
15	0021.0330 Pos Flow Cal: dP2 at 37,0 (Setpoint 35) [8m 24s]	ADC Cnts	LE 2236	2083	✓	
16	0021.0340 Pos Flow Cal: dP2 at 47,3 (Setpoint 45) [8m 24s]	ADC Cnts	LE 2376	2236	✓	
17	0021.0350 Pos Flow Cal: dP2 at 57,0 (Setpoint 55) [8m 24s]	ADC Cnts	LE 2510	2376	✓	
18	0021.0360 Pos Flow Cal: dP2 at 67,0 (Setpoint 65) [8m 24s]	ADC Cnts	LE 2633	2511	✓	
19	0021.0370 Pos Flow Cal: dP2 at 77,2 (Setpoint 75) [8m 24s]	ADC Cnts	LE 2747	2634	✓	
20	0021.0380 Pos Flow Cal: dP2 at 87,7 (Setpoint 85) [8m 24s]	ADC Cnts	LE 2846	2748	✓	
21	0021.0390 Pos Flow Cal: dP2 at 97,0 (Setpoint 95) [8m 24s]	ADC Cnts	LE 2936	2847	✓	
22	0021.0400 Pos Flow Cal: dP2 at 106,7 (Setpoint 105) [8m 24s]	ADC Cnts	LE 3030	2937	✓	
23	0021.0410 Pos Flow Cal: dP2 at 118,2 (Setpoint 115) [8m 24s]	ADC Cnts	LE 3098	3031	✓	
24	0021.0420 Pos Flow Cal: dP2 at 127,5 (Setpoint 125) [8m 24s]	ADC Cnts	LE 3177	3098	✓	
25	0021.0430 Pos Flow Cal: dP2 at 137,5 (Setpoint 135) [8m 24s]	ADC Cnts	LE 3242	3178	✓	
26	0021.0440 Pos Flow Cal: dP2 at 146,3 (Setpoint 145) [8m 24s]	ADC Cnts	LE 3413	3243	✓	
27	0021.0450 Pos Flow Cal: dP2 at 172,5 (Setpoint 175) [8m 24s]	ADC Cnts	LE 3504	3414	✓	
28	0021.0460 Pos Flow Cal: dP2 at 188,5 (Setpoint 190) [8m 24s]	ADC Cnts	LE 3999	3505	✓	
29	0021.0500 O2 Positive Flow Cal: dP1 at 0,0 (SP 0 @80,5PSI)	ADC Cnts	LE 390	238	✓	
30	0021.0510 O2 Positive Flow Cal: dP1 at 4,0 (SP 5 @86,8PSI)	ADC Cnts	LE 771	391	✓	
31	0021.0520 O2 Positive Flow Cal: dP1 at 14,7 (SP 15 @85,8PSI)	ADC Cnts	LE 1028	772	✓	
32	0021.0530 O2 Positive Flow Cal: dP1 at 24,3 (SP 25 @84,9PSI)	ADC Cnts	LE 1225	1029	✓	
33	0021.0540 O2 Positive Flow Cal: dP1 at 34,0 (SP 35 @83,8PSI)	ADC Cnts	LE 1400	1226	✓	
34	0021.0550 O2 Positive Flow Cal: dP1 at 44,0 (SP 45 @82,9PSI)	ADC Cnts	LE 1570	1401	✓	
35	0021.0560 O2 Positive Flow Cal: dP1 at 54,0 (SP 55 @81,9PSI)	ADC Cnts	LE 1727	1571	✓	

Test Started On 02/27/24 03:15:14Serial Number TV018021912Elapsed Test Time 15m 14sStatus **PASS**

Page 1 of 2

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Troubleshooting: Group Level mode.
File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 77D6, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20