Test Software P/N 4102483

Tested Part Number 1040000



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass Fail
36	0021.0570 O2 Positive Flow Cal: dP1 at 65,0 (SP 65 @76,2P	ADC Cnts	LE 1940	1792	─
37	0021.0580 O2 Positive Flow Cal: dP1 at 75,2 (SP 75 @75,8P	ADC Cnts	LE 2063	1941	√
38	0021.0590 O2 Positive Flow Cal: dP1 at 84,8 (SP 85 @75,5P	ADC Cnts	LE 2200	2064	√
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,5 (SP 95 @75,1P	ADC Cnts	LE 2337	2201	√
40	0021.0610 O2 Positive Flow Cal: dP1 at 104,7 (SP 105 @74,	ADC Cnts	LE 2458	2338	√
41	0021.0620 O2 Positive Flow Cal: dP1 at 114,7 (SP 115 @74,	ADC Cnts	LE 2565	2459	√
42	0021.0630 O2 Positive Flow Cal: dP1 at 125,0 (SP 125 @73,	ADC Cnts	LE 2662	2566	√
43	0021.0640 O2 Positive Flow Cal: dP1 at 135,3 (SP 135 @72,	ADC Cnts	LE 2758	2663	√
44	0021.0650 O2 Positive Flow Cal: dP1 at 145,7 (SP 145 @72,	ADC Cnts	LE 3031	2759	√
45	0021.0660 O2 Positive Flow Cal: dP1 at 175,2 (SP 175 @69,	ADC Cnts	LE 3142	3032	√
46	0021.0670 O2 Positive Flow Cal: dP1 at 191,0 (SP 190 @68,	ADC Cnts	LE 3999	3143	√
47	0021.0880 02 Sensor Cal (NO_02_ERROR): 601 mV at ambient	N/A	Pass	TRUE	√
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	√
					$\overline{}$
		<u> </u>		Ļ	

Test Started On 09/04/24 11:00:08

Elapsed Test Time 25m 17s

Serial Number TV013091702

Status PASS

Page 2 **of** 2