

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 47,8 (Setpoint 50) [10m	SLPM	42,4 to 53,2	49,6	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,9 (Setpoint 40) [10m	SLPM	32,8 to 42,9	39,7	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [10m	SLPM	23,4 to 32,6	29,3	✓	
39	0030.0310 Pos Flow Verify: dP2 at 19,8 (Setpoint 20) [10m	SLPM	14,8 to 24,8	20,4	✓	
40	0030.0320 Pos Flow Verify: dP2 at 9,8 (Setpoint 10) [10m	SLPM	5,3 to 14,3	10,2	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [10m 4	SLPM	1,2 to 8,8	5,0	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [10m	SLPM	-2,0 to 2,0	-0,0	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,9 (Setpoint 140) [	SLPM	-147,9 to -129,8	-140,8	✓	
44	0030.0560 Neg Flow Verify: dP2 at -127,7 (Setpoint 130) [	SLPM	-136,3 to -119,1	-129,9	✓	
45	0030.0570 Neg Flow Verify: dP2 at -117,7 (Setpoint 120) [	SLPM	-125,9 to -109,5	-119,7	✓	
46	0030.0580 Neg Flow Verify: dP2 at -107,8 (Setpoint 110) [	SLPM	-115,6 to -100,0	-110,5	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,2 (Setpoint 100) [1	SLPM	-105,6 to -90,7	-99,7	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,9 (Setpoint 90) [15	SLPM	-95,9 to -81,8	-89,1	✓	
49	0030.0610 Neg Flow Verify: dP2 at -78,0 (Setpoint 80) [15	SLPM	-84,6 to -71,4	-79,0	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,7 (Setpoint 70) [15	SLPM	-73,9 to -61,5	-69,5	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [15	SLPM	-63,8 to -52,2	-59,8	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [15	SLPM	-53,4 to -42,6	-49,6	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [15	SLPM	-43,0 to -33,0	-40,1	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [15	SLPM	-32,6 to -23,4	-29,7	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,7 (Setpoint 20) [15	SLPM	-24,7 to -14,7	-21,8	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [15	SLPM	-14,5 to -5,5	-10,5	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [15m	SLPM	-8,8 to -1,2	-4,9	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [15m	SLPM	-2,0 to 2,0	-0,0	✓	
59	0030.0950 Contr.Press.Ver.(8091): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,09	✓	
60	0030.0960 Monit.Press.Ver.(3824): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,16	✓	
61	0030.0160 Pprox Press. Ver.(7908): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
62	0030.0970 Contr.Press.Ver.(10458): P1 at 3,83 (SP 4, 1, 1)	cmH2O	2,83 to 4,83	4,00	✓	
63	0030.0980 Monit.Press.Ver.(6556): P2 at 3,83 (SP 4, 1, 1)	cmH2O	2,83 to 4,83	4,06	✓	
64	0030.0161 Pprox Press. Ver.(10300): P2 at 3,83 (SP 4, 1,	cmH2O	2,83 to 4,83	3,94	✓	
65	0030.0990 Contr.Press.Ver.(18939): P1 at 17,81 (SP 18, 1,	cmH2O	16,81 to 18,81	17,99	✓	
66	0030.1000 Monit.Press.Ver.(16349): P2 at 17,81 (SP 18, 1,	cmH2O	16,81 to 18,81	18,02	✓	
67	0030.0162 Pprox Press. Ver.(18830): P2 at 17,81 (SP 18, 1	cmH2O	16,81 to 18,81	18,04	✓	
68	0030.1010 Contr.Press.Ver.(27423): P1 at 31,71 (SP 32, 1,	cmH2O	30,71 to 32,71	31,99	✓	
69	0030.1020 Monit.Press.Ver.(26106): P2 at 31,71 (SP 32, 1,	cmH2O	30,71 to 32,71	31,94	✓	
70	0030.0163 Pprox Press. Ver.(27290): P2 at 31,71 (SP 32, 1	cmH2O	30,71 to 32,71	31,98	✓	

Test Started On 04/01/24 07:39:12Serial Number TV120092328Elapsed Test Time 48m 58sStatus **PASS**

Page 2 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.  
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20