Test Software P/N 4102483

Tested Part Number 1040000

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	- 0021.0570 O2 Positive Flow Cal: dP1 at 64,0 (SP 65 @81,5P;	ADC Cnts	LE 1888	1745		
37	0021.0580 O2 Positive Flow Cal: dPl at 74,3 (SP 75 @80,8P;	ADC Cnts	LE 2024	1889	→	
38	0021.0590 O2 Positive Flow Cal: dPl at 84,5 (SP 85 @80,0P;	ADC Cnts	LE 2150	2025	1	
39	0021.0600 O2 Positive Flow Cal: dPl at 94,0 (SP 95 @79,3P;	ADC Cnts	LE 2262	2151	· /	
40	0021.0610 02 Positive Flow Cal: dP1 at 104,3 (SP 105 @78,	ADC Cnts	LE 2373	2263	· /	
41	0021.0620 02 Positive Flow Cal: dP1 at 114,2 (SP 115 @77,	ADC Cnts	LE 2478	2374	√	
42	0021.0630 O2 Positive Flow Cal: dP1 at 124,7 (SP 125 @76,	ADC Cnts	LE 2567	2479	√	
43	0021.0640 O2 Positive Flow Cal: dP1 at 133,8 (SP 135 @76,	ADC Cnts	LE 2663	2568	√	
44	0021.0650 O2 Positive Flow Cal: dP1 at 146,0 (SP 145 @75,	ADC Cnts	LE 2904	2664	✓	
45	0021.0660 02 Positive Flow Cal: dP1 at 174,5 (SP 175 @72,	ADC Cnts	LE 3022	2905	√	
46	0021.0670 O2 Positive Flow Cal: dP1 at 189,8 (SP 190 @70,	ADC Cnts	LE 3999	3023	√	
47	0021.0880 02 Sensor Cal (NO_O2_ERROR): 557 mV at ambient;	N/A	Pass	TRUE	√	
48	0021.0930 Write OBM Sensors Cal Table (V: TRUE, A: TRUE)	N/A	Pass	TRUE	✓	
						L
						L
						<u> </u>
						<u> </u>
						<u> </u>
						<u> </u>

Test Started On 03/06/24 03:31:27

Serial Number TV017111508 Elapsed Test Time 16m 35s

Status PASS

Page 2 **of** 2