

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [11m	SLPM	42,6 to 53,4	49,5	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,7 (Setpoint 40) [11m	SLPM	32,7 to 42,7	38,4	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [11m	SLPM	23,4 to 32,6	28,8	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [11m	SLPM	15,0 to 25,0	20,3	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [11m	SLPM	5,5 to 14,5	10,6	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [11m 4	SLPM	1,2 to 8,8	5,2	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [11m	SLPM	-2,0 to 2,0	-0,0	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,8 (Setpoint 140) [	SLPM	-147,9 to -129,8	-141,5	✓	
44	0030.0560 Neg Flow Verify: dP2 at -128,0 (Setpoint 130) [	SLPM	-136,6 to -119,4	-130,6	✓	
45	0030.0570 Neg Flow Verify: dP2 at -117,8 (Setpoint 120) [	SLPM	-126,0 to -109,6	-120,2	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,2 (Setpoint 110) [	SLPM	-116,0 to -100,3	-110,1	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,0 (Setpoint 100) [1	SLPM	-105,4 to -90,6	-99,9	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,8 (Setpoint 90) [16	SLPM	-95,9 to -81,8	-89,5	✓	
49	0030.0610 Neg Flow Verify: dP2 at -77,5 (Setpoint 80) [16	SLPM	-84,1 to -70,9	-78,4	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,5 (Setpoint 70) [16	SLPM	-73,7 to -61,3	-68,6	✓	
51	0030.0630 Neg Flow Verify: dP2 at -58,0 (Setpoint 60) [16	SLPM	-63,8 to -52,2	-59,1	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,0 (Setpoint 50) [16	SLPM	-53,4 to -42,6	-48,0	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [16	SLPM	-43,0 to -33,0	-38,1	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [16	SLPM	-32,6 to -23,4	-28,1	✓	
55	0030.0670 Neg Flow Verify: dP2 at -19,8 (Setpoint 20) [16	SLPM	-24,8 to -14,8	-20,6	✓	
56	0030.0680 Neg Flow Verify: dP2 at -10,0 (Setpoint 10) [16	SLPM	-14,5 to -5,5	-11,0	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [16m	SLPM	-8,8 to -1,2	-4,9	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [16m	SLPM	-2,0 to 2,0	-0,0	✓	
59	0030.0950 Contr.Press.Ver.(8282): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,04	✓	
60	0030.0960 Monit.Press.Ver.(3980): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,04	✓	
61	0030.0160 Pprox Press. Ver.(8060): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,00	✓	
62	0030.0970 Contr.Press.Ver.(10684): P1 at 4,01 (SP 4, 1, 1)	cmH2O	3,01 to 5,01	4,00	✓	
63	0030.0980 Monit.Press.Ver.(6768): P2 at 4,01 (SP 4, 1, 1)	cmH2O	3,01 to 5,01	4,03	✓	
64	0030.0161 Pprox Press. Ver.(10491): P2 at 4,01 (SP 4, 1,	cmH2O	3,01 to 5,01	3,93	✓	
65	0030.0990 Contr.Press.Ver.(19198): P1 at 17,99 (SP 18, 1,	cmH2O	16,99 to 18,99	17,99	✓	
66	0030.1000 Monit.Press.Ver.(16535): P2 at 17,99 (SP 18, 1,	cmH2O	16,99 to 18,99	17,96	✓	
67	0030.0162 Pprox Press. Ver.(18988): P2 at 17,99 (SP 18, 1	cmH2O	16,99 to 18,99	17,92	✓	
68	0030.1010 Contr.Press.Ver.(27687): P1 at 31,98 (SP 32, 1,	cmH2O	30,98 to 32,98	31,99	✓	
69	0030.1020 Monit.Press.Ver.(26331): P2 at 31,98 (SP 32, 1,	cmH2O	30,98 to 32,98	31,93	✓	
70	0030.0163 Pprox Press. Ver.(27479): P2 at 31,98 (SP 32, 1	cmH2O	30,98 to 32,98	31,90	✓	

Test Started On 06/06/24 09:37:49Serial Number TV11909271CElapsed Test Time 48m 50sStatus **FAIL**

Page 2 of 5

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.  
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20