ANDOVER 20-02-2024

Fluke Biomedical Ansur Test and Inspection Procedure

Copyright © 2000 - 2014 Fluke Biomedical

Test Record

TEST PASSED

Test Performed Ansur Components Used

 Date:
 20-02-2024

 Record:
 IEC 60601-1 - CL2.mtr

 Template:
 IEC 60601-1 - CL2.mtt

Ansur Version 3.1.4 Plug-In: ESA612 Version 1.1.3

Test Setup

Selections

Service Events Performed	Standards Performed
	IFC 60601

Device under test

Serial Number	TV012043013	Туре	Ventilador
Appliance Code	1040000	Model	202
Group	Trilogy	Location	Andover Alianza Médica S. A.
Status	Revisión	Address 1	Salar de Huaco 795, Pudahuel
Manufacturer	Philips Respironics	Address 2	Laboratorio

MTI Data

Test Instrument	Serial Number	Firmware Version
ESA612B	6370086	v3.01

Signatures

IEC 60601-1 - CL2.mtr Page 1 of 2

Test Result

Test Element		Test Ty	/pe			Fail
IEC 60601-1 - CL2		Auto Se	quence			
Procedure:	o +b o FC / 4	10 oc ind	icated in th	a aparatora man	uol	
(1) Connect the DUT to the ESA612 as indicated in the operators manual.						
(2) Ensure that DUT po				h . t t . h . t	k1	
(3) Click module setup				nat are to be tes	tea.	
(4) Connect patient lea						
(5) Click Start Test to	perform ti	ne safety	test.			
Configuration:						
Polarity Switching Delay:3(s)						
3 0 3 1.						
Mains Voltage		Mains V	'oltage			
Live to Neutral		Mains V Live to I				
Result:	Value	Unit	High Limit	Low Limit	Standard	
Live to Neutral	228,3	V	Ū		IEC 60601	
Enclosure Leakage Current		Enclosu	re Leakage Cur	rent		
Configuration:			J			
Unused Applied						
Parts:Floating						
		Footoo				
Normal Condition		Enclosure Leakage Current Normal Condition				
Result:	Value	Unit	High Limit	Low Limit	Standard	
Normal Condition	0,5	uA	100		IEC 60601	
Open Neutral			re Leakage Cur	rent		
Result:	Value	Open N Unit	eutral High Limit	Low Limit	Standard	
Open Neutral	varue 0,6	uA	500	LOW LITTIE	IEC 60601	
opon would	0,0	u, (000		120 00001	
N 10 III 5		Enclosu	re Leakage Cur	rent		
Normal Condition, Reversed mains		Normal	Condition, Reve	ersed mains		
Result:	Value	Unit	High Limit	Low Limit	Standard	
Normal Condition, Reversed mains	0,4	uA	100		IEC 60601	
Neverseu mains						
On an Nautral Days and Mains		Enclosu	re Leakage Cur	rent		
Open Neutral, Reversed Mains		Open Neutral, Reversed Mains				
Result:	Value	Unit	High Limit	Low Limit	Standard	
Open Neutral, Reversed Mains	0,6	uA	500		IEC 60601	
Meneraen inigilia						

IEC 60601-1 - CL2.mtr Page 2 of 2