Test Software P/N 4102483

Tested Part Number LA1054096

Test Software Name Trilogy FSA (REPAIR TEST)



Software Revision 24.0.0.0

Prepared By P. Pascal

Test Report

C4	Description	TIm.º4	T :	Da14	Dogal Earl
Step	Description	Units	Limits	Results	Pass Fail
36	0020.0570 Pos Flow Cal: dP2 at 77,5 (Setpoint 75) [15m 27	ADC Cnts	LE 47467	46476	✓ _
37	0020.0580 Pos Flow Cal: dP2 at 87,5 (Setpoint 85) [15m 27	ADC Cnts	LE 48446	47468	✓ _
38	0020.0590 Pos Flow Cal: dP2 at 97,2 (Setpoint 95) [15m 27	ADC Cnts	LE 49322	48447	✓
39	0020.0600 Pos Flow Cal: dP2 at 107,3 (Setpoint 105) [15m	ADC Cnts	LE 50145	49323	✓
40	0020.0610 Pos Flow Cal: dP2 at 117,3 (Setpoint 115) [15m	ADC Cnts	LE 50894	50146	✓
41	0020.0620 Pos Flow Cal: dP2 at 127,7 (Setpoint 125) [15m	ADC Cnts	LE 51543	50895	✓
42	0020.0630 Pos Flow Cal: dP2 at 136,8 (Setpoint 135) [15m	ADC Cnts	LE 52315	51544	√
43	0020.0640 Pos Flow Cal: dP2 at 148,5 (Setpoint 145) [15m	ADC Cnts	LE 53500	52316	√
44	0020.0650 Pos Flow Cal: dP2 at 167,0 (Setpoint 170) [15m	ADC Cnts	LE 54759	53501	√
45	0020.0660 Pos Flow Cal: dP2 at 187,7 (Setpoint 190) [15m	ADC Cnts	LE 65435	54760	√
46	0020.0900 Atmospheric Press Sensors Cal Patm: Slope (m) [lnHg/ADC	EQ 0,000517	0,000517	√
47	0020.0910 Atmospheric Press Sensors Cal Patm: Intercept (inHg	1,91 to 4,09	2,45	√
48	0020.0920 Write Sensors Cal Table [16m 3s]	N/A	Pass	TRUE	√
49	0020.0970 Write Pprox Cal Table [16m 22s]	N/A	Pass	TRUE	√
50	0020.0935 02 Sensor Cal (not attempted for SW ver.14.2.05	N/A	None	None	√
51	0020.1030 Write Image Table [16m 42s]	N/A	Pass	TRUE	√
					++-
					++-
					++-
					
					++-
					++-
					++-
					+
		\Box			

Test Started On 08/28/24 09:00:53

Serial Number TV119091016 Elapsed Test Time 16m 42s

Status PASS

Page 2 **of** 2