Test Software P/N 4102483

**Tested Part Number** 1040000



**Software Revision** 24.0.0.0

Prepared By P. Pascal

## **Test Report**

	Tost Report						
Step	Description	Units	Limits	Results	Pass	Fail	
36	0021.0570 O2 Positive Flow Cal: dP1 at 64,9 (SP 65 @81,1P	ADC Cnts	LE 1816	1682	✓		
37	0021.0580 O2 Positive Flow Cal: dP1 at 74,0 (SP 75 @80,5P	ADC Cnts	LE 1940	1816	✓		
38	0021.0590 O2 Positive Flow Cal: dP1 at 83,0 (SP 85 @79,8P	ADC Cnts	LE 2076	1941	✓		
39	0021.0600 O2 Positive Flow Cal: dP1 at 94,5 (SP 95 @78,9P	ADC Cnts	LE 2208	2077	✓		
40	0021.0610 O2 Positive Flow Cal: dP1 at 105,0 (SP 105 @78,	ADC Cnts	LE 2321	2209	✓		
41	0021.0620 O2 Positive Flow Cal: dP1 at 115,0 (SP 115 @77,	ADC Cnts	LE 2423	2322	✓		
42	0021.0630 O2 Positive Flow Cal: dP1 at 124,5 (SP 125 @76,	ADC Cnts	LE 2532	2424	✓		
43	0021.0640 O2 Positive Flow Cal: dP1 at 134,5 (SP 135 @75,	ADC Cnts	LE 2626	2532	✓		
44	0021.0650 O2 Positive Flow Cal: dP1 at 144,9 (SP 145 @74,	ADC Cnts	LE 2887	2627	✓		
45	0021.0660 O2 Positive Flow Cal: dP1 at 174,7 (SP 175 @71,	ADC Cnts	LE 3008	2888	<b>√</b>		
46	0021.0670 02 Positive Flow Cal: dP1 at 189,8 (SP 190 @70,	ADC Cnts	LE 3999	3009	<b>√</b>		
47	0021.0880 02 Sensor Cal (RANGE_FAILURE): 4 mV at ambient	N/A	Pass	FALSE		×	
48	0021.0930 Write OBM Sensors Cal Table [14m 15s]	N/A	Pass	FALSE		×	
					+++		
					++		
					$\perp \downarrow \perp \downarrow$		

**Test Started On** 02/06/24 05:22:32

Elapsed Test Time 14m 15s

Serial Number TV02001060E

Page 2 **of** 2