

Test Report

Step	Description	Units	Limits	Results	Pass	Fail
71	0030.1030 Contr.Press.Ver.(36460): P1 at 45,94 (SP 46, 1,	cmH2O	44,94 to 46,94	45,98	✓	
72	0030.1040 Monit.Press.Ver.(34163): P2 at 45,94 (SP 46, 1,	cmH2O	44,94 to 46,94	45,96	✓	
73	0030.0164 Pprox Press. Ver.(36958): P2 at 45,94 (SP 46, 1	cmH2O	44,94 to 46,94	45,97	✓	
74	0030.1050 Contr.Press.Ver.(38870): P1 at 49,94 (SP 50, 1,	cmH2O	48,94 to 50,94	49,99	✓	
75	0030.1060 Monit.Press.Ver.(36953): P2 at 49,94 (SP 50, 1,	cmH2O	48,94 to 50,94	49,95	✓	
76	0030.0165 Pprox Press. Ver.(39375): P2 at 49,94 (SP 50, 1	cmH2O	48,94 to 50,94	49,95	✓	
77	0030.1070 Contr.Press.Ver.(47519): P1 at 64,33 (SP 65, 1,	cmH2O	63,33 to 65,33	64,39	✓	
78	0030.1080 Monit.Press.Ver.(46961): P2 at 64,33 (SP 65, 1,	cmH2O	63,33 to 65,33	64,38	✓	
79	0030.0166 Pprox Press. Ver.(48007): P2 at 64,33 (SP 65, 1	cmH2O	63,33 to 65,33	64,29	✓	
80	0030.1150 Atmospheric Pressure Verify: Patm at 28,05,28,0	inHg	27,45 to 28,65	28,03	✓	
81	0030.1250 Airstream Temperature (Tair) at 27,00 [16m 22s]	C deg	22,00 to 42,00	30,36	✓	
82	0040.0010 Keypad Backlight Test [16m 27s]	N/A	Pass	TRUE	✓	
83	0040.0020 LCD Backlight Test [16m 29s]	N/A	Pass	TRUE	✓	
84	0040.0030 Primary Audible Alarm Soft [16m 36s]	N/A	Pass	TRUE	✓	
85	0040.0040 Primary Audible Alarm Soft heard by HW (1) [16m	N/A	Pass	TRUE	✓	
86	0040.0050 Primary Audible Alarm Loud [16m 36s]	N/A	Pass	TRUE	✓	
87	0040.0060 Primary Audible Alarm Loud heard by HW (1) [16m	N/A	Pass	TRUE	✓	
88	0040.0070 Red Alarm LED [16m 38s]	N/A	Pass	TRUE	✓	
89	0040.0080 Yellow Alarm LED [16m 38s]	N/A	Pass	TRUE	✓	
90	0040.0090 Secondary Audible Alarm Soft [16m 45s]	N/A	Pass	TRUE	✓	
91	0040.0100 Secondary Audible Alarm Soft heard by HW (1) [1	N/A	Pass	TRUE	✓	
92	0040.0110 Secondary Audible Alarm Loud [16m 45s]	N/A	Pass	TRUE	✓	
93	0040.0120 Secondary Audible Alarm Loud heard by HW (1) [1	N/A	Pass	TRUE	✓	
94	0040.0130 LCD Brightness [16m 53s]	N/A	Pass	TRUE	✓	
95	0040.0140 LCD screen test [16m 54s]	N/A	Pass	TRUE	✓	
96	0040.0150 120 VAC Power Source EPAP Current (1) [20m 0s]	A	0,15 to 1,30	0,44	✓	
97	0040.0160 120 VAC Power Source IPAP Current (1) [20m 0s]	A	0,25 to 1,60	0,59	✓	
98	0040.0170 Detach. Li-Ion Batt. Charge (at 74% Cap.) (1)	mA	GE 250,00	2001,00	✓	
99	0040.0180 Uninterrupted Operation (1) [20m 0s]	N/A	Pass	TRUE	✓	
100	0040.0190 AC Power Source Recognition (1) [20m 0s]	N/A	EQ 120V AC Power	120V AC Power	✓	
101	0040.0200 AC Power Source LED ON (1) [20m 0s]	N/A	Pass	TRUE	✓	
102	0040.0210 240 VAC Power Source EPAP Current (1) [20m 23s]	A	0,07 to 0,80	0,18	✓	
103	0040.0220 240 VAC Power Source IPAP Current (1) [20m 23s]	A	0,12 to 1,00	0,33	✓	
104	0040.0230 Uninterrupted Operation (1) [20m 23s]	N/A	Pass	TRUE	✓	
105	0040.0240 AC Power Source Recognition (1) [20m 23s]	N/A	EQ 120V AC Power	120V AC Power	✓	

Test Started On 04/03/24 02:26:25Serial Number TV113102307Elapsed Test Time 46m 8sStatus **PASS**

Page 3 of 6

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.
 File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38
 Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20