

# Test Report

Step	Description	Units	Limits	Results	Pass	Fail
36	0030.0280 Pos Flow Verify: dP2 at 48,0 (Setpoint 50) [11m	SLPM	42,6 to 53,4	50,5	✓	
37	0030.0290 Pos Flow Verify: dP2 at 37,8 (Setpoint 40) [11m	SLPM	32,8 to 42,8	39,0	✓	
38	0030.0300 Pos Flow Verify: dP2 at 28,0 (Setpoint 30) [11m	SLPM	23,4 to 32,6	28,8	✓	
39	0030.0310 Pos Flow Verify: dP2 at 20,0 (Setpoint 20) [11m	SLPM	15,0 to 25,0	19,2	✓	
40	0030.0320 Pos Flow Verify: dP2 at 10,0 (Setpoint 10) [11m	SLPM	5,5 to 14,5	9,5	✓	
41	0030.0330 Pos Flow Verify: dP2 at 5,0 (Setpoint 5) [11m 1	SLPM	1,2 to 8,8	3,7	✓	
42	0030.0510 Zero Flow Verify: dP2 at 0,0 (Setpoint 0) [11m	SLPM	-2,0 to 2,0	-1,6	✓	
43	0030.0550 Neg Flow Verify: dP2 at -138,8 (Setpoint 140) [	SLPM	-147,9 to -129,8	-143,9	✓	
44	0030.0560 Neg Flow Verify: dP2 at -127,7 (Setpoint 130) [	SLPM	-136,3 to -119,1	-132,9	✓	
45	0030.0570 Neg Flow Verify: dP2 at -117,9 (Setpoint 120) [	SLPM	-126,1 to -109,6	-123,5	✓	
46	0030.0580 Neg Flow Verify: dP2 at -108,0 (Setpoint 110) [	SLPM	-115,8 to -100,2	-112,7	✓	
47	0030.0590 Neg Flow Verify: dP2 at -98,5 (Setpoint 100) [1	SLPM	-105,9 to -91,1	-103,0	✓	
48	0030.0600 Neg Flow Verify: dP2 at -88,5 (Setpoint 90) [17	SLPM	-95,5 to -81,5	-92,2	✓	
49	0030.0610 Neg Flow Verify: dP2 at -78,2 (Setpoint 80) [17	SLPM	-84,8 to -71,5	-81,6	✓	
50	0030.0620 Neg Flow Verify: dP2 at -67,3 (Setpoint 70) [17	SLPM	-73,5 to -61,1	-70,3	✓	
51	0030.0630 Neg Flow Verify: dP2 at -57,5 (Setpoint 60) [17	SLPM	-63,3 to -51,7	-59,7	✓	
52	0030.0640 Neg Flow Verify: dP2 at -48,2 (Setpoint 50) [17	SLPM	-53,6 to -42,7	-50,1	✓	
53	0030.0650 Neg Flow Verify: dP2 at -38,0 (Setpoint 40) [17	SLPM	-43,0 to -33,0	-39,5	✓	
54	0030.0660 Neg Flow Verify: dP2 at -28,0 (Setpoint 30) [17	SLPM	-32,6 to -23,4	-29,7	✓	
55	0030.0670 Neg Flow Verify: dP2 at -20,0 (Setpoint 20) [17	SLPM	-25,0 to -15,0	-21,9	✓	
56	0030.0680 Neg Flow Verify: dP2 at -9,8 (Setpoint 10) [17m	SLPM	-14,3 to -5,3	-11,0	✓	
57	0030.0690 Neg Flow Verify: dP2 at -5,0 (Setpoint 5) [17m	SLPM	-8,8 to -1,2	-6,3	✓	
58	0030.0700 Neg Flow Verify: dP2 at -0,0 (Setpoint 0) [17m	SLPM	-2,0 to 2,0	-1,6	✓	
59	0030.0950 Contr.Press.Ver.(9562): P1 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,16	✓	
60	0030.0960 Monit.Press.Ver.(3468): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,11	✓	
61	0030.0160 Pprox Press. Ver.(9309): P2 at 0,00 (SP 0, 1, 1)	cmH2O	-1,00 to 1,00	0,07	✓	
62	0030.0970 Contr.Press.Ver.(11868): P1 at 3,85 (SP 4, 1, 1)	cmH2O	2,85 to 4,85	3,99	✓	
63	0030.0980 Monit.Press.Ver.(6129): P2 at 3,85 (SP 4, 1, 1)	cmH2O	2,85 to 4,85	3,92	✓	
64	0030.0161 Pprox Press. Ver.(11603): P2 at 3,85 (SP 4, 1,	cmH2O	2,85 to 4,85	3,91	✓	
65	0030.0990 Contr.Press.Ver.(20288): P1 at 17,85 (SP 18, 1,	cmH2O	16,85 to 18,85	17,99	✓	
66	0030.1000 Monit.Press.Ver.(15918): P2 at 17,85 (SP 18, 1,	cmH2O	16,85 to 18,85	17,92	✓	
67	0030.0162 Pprox Press. Ver.(19959): P2 at 17,85 (SP 18, 1	cmH2O	16,85 to 18,85	17,86	✓	
68	0030.1010 Contr.Press.Ver.(28710): P1 at 31,82 (SP 32, 1,	cmH2O	30,82 to 32,82	32,00	✓	
69	0030.1020 Monit.Press.Ver.(25684): P2 at 31,82 (SP 32, 1,	cmH2O	30,82 to 32,82	31,91	✓	
70	0030.0163 Pprox Press. Ver.(28346): P2 at 31,82 (SP 32, 1	cmH2O	30,82 to 32,82	31,85	✓	

Test Started On 01/17/24 02:57:24Serial Number TV110051733Elapsed Test Time 20m 40sStatus **FAIL**

Page 2 of 3

Audit Info Printed to:doPDF v7 from RESPIRONICS-PC in Production mode.

File: C:\Program Files\Trilogy Service Cal And Test\Trilogy Repair\_PM Cal And Test.exe, Size: 8674304, 05/09/23 10:38  
Station Cfg CRC: 5219, 09/01/21 01:39, Test Cfg CRC: 94CF, 09/01/21 01:39, Models Cfg CRC: 2F86, 05/05/23 08:20