

Engine No: 1234
Station No: 30
Model: 3G_Genset
Result_ID: 1234_30
Operator:
Emp ID: 11
Status: Passed
Timestamp: 2024-06-15T08:16:50Z

Checkpoint Data			
Seq	Checkpoint	Unit	Checkpoint Status
1	Check rust preventive oil (AXXANOL 34 CD) is applied on machined surfaces, fuel pump, charging alternator, fuel filter etc.	Na	True
2	Confirm lub oil pressure & water temperature sensors & gauges are ok as per BOM/Make.	Na	True
3	Check fan size model wise as per BOM.	Inch 32	
4	Check lub oil is removed from the sump after engine testing cycle completion.	Na	True
5	Check Aluminium radiator & Pre-Mix coolant instructions sticker is pasted on the radiator near to coolant filling inlet for aluminium radiators only. Mention Radiator Serial No.	Na	Ok
6	Confirm seaworthy packing for export engines only.	Na	Yes
7	Confirm, antirust pouch is kept on the engine.	Na	True
Comment: Ok			



