

RECOMMENDED PRACTICE:
DIMMING AND CONTROL
METHOD DESIGNATIONS
AN AMERICAN NATIONAL STANDARD

ANSI/IES RP-42-26

**RECOMMENDED PRACTICE:
DIMMING AND CONTROL METHOD DESIGNATIONS
AN AMERICAN NATIONAL STANDARD**

Publication of this Recommended Practice
has been approved by IES.
Suggestions for revisions
should be directed to IES.

**Prepared by the IES
Lighting Control Systems Committee**



Copyright 2026 by the Illuminating Engineering Society.

Approved by the IES Standards Committee December 5, 2025, as a Transaction of the Illuminating Engineering Society.

Approved March 16, 2026, as an American National Standard.

All rights reserved. No part of this publication may be reproduced in any form, in any electronic retrieval system or otherwise, without prior written permission of the IES.

Published by the Illuminating Engineering Society, 85 Broad Street, Floor 17, New York, NY 10004.

IES Standards are developed through committee consensus and produced by the IES Office in New York. Careful attention is given to style and accuracy. If any errors are noted in this document, please forward them to the IES Director of Standards, at standards@ies.org or the above address, for verification and correction. The IES welcomes and urges feedback and comments.

ISBN 978-0-87995-509-0

Printed in the United States of America.

DISCLAIMER

IES publications are developed through the consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on lighting recommendations. While the IES administers the process and establishes policies and procedures to promote fairness in the development of consensus, it makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

The IES disclaims liability for any injury to persons or property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document.

In issuing and making this document available, the IES is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the IES undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The IES has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the IES list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or statement of compliance with the requirements of this document shall not be attributable to the IES and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether that person has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation to any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Prepared by the IES Lighting Control Systems Committee.

Mitchell Hefter, *Chair*

Yoelit H. Hiebert, *Vice Chair*

Harold Jepsen, *Secretary*

Members

Catherine Barnes

Casey Diers

Nicholas Downham

Lauren Morlino Eagan

Bill Ellis

Paul Ericson

Lyn Gomes

Melissa Goren

Roy Harvey

Kyle Hemmi

Raymond Janik

Carol C. Jones

Richard Miller

Michael Myer

Kurt Nielsen

Levin Nock

Steven Pay

Todd Reemtsma

Shoshanna Segal

Howard Wolfman

James Yorgey

Yukiko Yoshida

CONTENTS

Preface.....1

1.0 Introduction and Scope1

1.1 Introduction..... 1

1.2 Scope..... 2

2.0 Concepts2

2.1 Multiple Protocols and Control Methods in One System 2

2.2 Open Versus Proprietary Protocols 2

3.0 Control Methods and Open Protocols3

4.0 Protocols That Are Not Fully Interoperable4

Annex A – Sample Luminaire and Control Schedules8

Annex B – Sample Data Sheets..... 10

References 13

Preface

This preface is not part of ANSI/IES RP-42-25. It is provided for informational purposes only.

This Recommended Practice (RP) does not provide general lighting information that is included in other IES documents. If the reader does not already have this information, it may be obtained as needed from the following IES Standards:

The Lighting Science Series:

- *ANSI/IES LS-1-25, Lighting Science: Nomenclature and Definitions for Illuminating Engineering*
- *ANSI/IES LS-2-20(R23), Lighting Science: Concepts and Language of Lighting*
- *ANSI/IES LS-3-20(R23), Lighting Science: Physics and Optics of Radiant Power*
- *ANSI/IES LS-4-20(R23), Lighting Science: Measurement of Light – The Science of Photometry*
- *ANSI/IES LS-5-25, Lighting Science: Color*
- *ANSI/IES LS-6-20(R25), Lighting Science: Calculation of Light and Its Effects*
- *ANSI/IES LS-7-20, Lighting Science: Vision – Eye and Brain*
- *ANSI/IES LS-8-25: Lighting Science: Vision – Perceptions and Performance*

The Lighting Practice Series:

- *ANSI/IES LP-1-24, Lighting Practice: Designing Quality Lighting for People and Buildings*
- *ANSI/IES LP-3-20, Lighting Practice: Designing and Specifying Daylighting for Buildings*
- *ANSI/IES LP-4-20, Lighting Practice: Electric Light Sources – Properties, Selection, and Specification*
- *ANSI/IES LP-6-25, Lighting Practice: Lighting Control Systems – Properties, Selection, and Specification*
- *ANSI/IES LP-8-20, Lighting Practice: The Commissioning Process Applied to Lighting and Control Systems*
- *ANSI/IES LP-9-25, Lighting Practice: Upgrading Lighting Systems in Nonresidential Spaces*
- *ANSI/IES LP-10-20, Lighting Practice: Sustainable*

Lighting: An Introduction to the Environmental Impacts of Lighting

- *ANSI/IES LP-12-21, Lighting Practice: IoT Connected Lighting*
- *ANSI/IES LP-13-21, Lighting Practice: Introduction to Resilient Lighting Systems*
- *ANSI/IES LP-16-22, Lighting Practice: Documenting Control Intent Narratives and Sequences of Operations*
- *ANSI/IES TM-24-20, Technical Memorandum: An Optional Method for Adjusting the Recommended Illuminance for Visually Demanding Tasks Within IES Illuminance Categories P through Y Based on Light Source Spectrum*
- *ANSI/IES TM-30-24, Technical Memorandum: IES Method for Evaluating Light Source Color Rendition*

1.0 Introduction And Scope

1.1 Introduction

There are multiple dimming methods by which aesthetic, energy saving, and/or code-required control of luminaires may be achieved as an alternative to on/off switching. Lighting control devices and systems provide a wide variety of options for users with an equally wide variety of interfaces. These can range from simple and familiar switches, sliders, and dials to sensors, touch screens and, more recently, mobile devices and Internet of Things (IoT) devices, many of which are still being developed. Regardless of how communication between the user and the lighting system begins, the final stage of controlling light is the actual control of or communication with the luminaire (or its driver, ballast, or transformer).

This variety of possible dimming and control methods (and protocols), even within a given luminaire family, poses challenges for anyone who writes or needs to respond to specifications: the designer, manufacturer, distributor, and contractor implementing the system. Many luminaire schedules within design and construction documents do not clearly identify the dimming or control methods, and while ANSI/IES LP-6-25,

Lighting Practice: Lighting Control Systems – Properties, Selection, and Specification (see **Preface**) includes descriptions of dimming and control methods, it does not provide a standard way of describing the specific dimming and control methods employed. The inclusion of these dimming methods and control protocol designations in design and construction documents—especially luminaire and control schedules—provides for consistency in selection of compatible dimming and control equipment.

This Recommended Practice provides standard designations for easily and uniformly identifying various dimming and control methods for designers and other specifiers to include in luminaire schedules. Manufacturers of luminaires, drivers, controllers, and lamps are encouraged to use these same designations to supplement part number keys and order guides in data sheets to clearly identify dimming methods that are compatible with their products. Compliance with this Recommended Practice is strictly voluntary and the responsibility of the manufacturer.

1.2 Scope

This Recommended Practice provides concise designations for open, non-proprietary dimming and control methods and protocols for luminaires (including standalone lamps) and controllers. This document does not address the internal control methods within a luminaire.

Document structure:

- **Section 2** provides concepts and terms.
- **Section 3** provides a table of standard designations for control methods and open protocols that are interoperable, including a short form and a longer description.
- **Section 4** provides a table of standard designations for common protocols that are not fully interoperable.
- **Annex A** provides sample luminaire and control schedules.
- **Annex B** provides sample information for inclusion in product data sheets.

2.0 Concepts

Two of the key concepts in any discussion of lighting controls are *methods* and *protocols*.

In this context, *methods* are electronic techniques for controlling a light-emitting device, e.g., phase control, pulse-width modulation (PWM), or on/off switching.

Protocols, then, define the methods for data representation, signaling, authentication, and error detection to enable the connection, communication, and data transfer among control devices and light sources. *Protocols* are typically specified in consensus standards, e.g., DALI and USITT DMX512.

As referred to in this document, a dimming or control method may be a protocol.

2.1 Multiple Protocols and Control Methods in One System

In any project, whether a large, integrated building controls system or a small standalone solution, multiple dimming and control methods and protocols may be (and commonly are) used in order to provide the intended lighting response. The need for multiple methods and protocols may be due to a variety of load types, equipment, and desired operations.

To ensure proper system integration and operation, the specifier, manufacturers, and contractors need to be aware of the control methods and protocols used by each product.

2.2 Open Versus Proprietary Protocols

Open protocols are standards that are publicly available and are developed in an open consensus process under the auspices of a recognized and typically not-for-profit organization. Such standards may be used at no charge or at a reasonable cost to cover development and administration. Proprietary intellectual property may sometimes be associated with a standard, but it can usually be licensed for a reasonable royalty fee or other licensing agreement.

Proprietary protocols are often developed and maintained by manufacturers or individuals (versus an open

consensus method). *Proprietary protocols* may be freely available or may be used only under contract or a licensing agreement.

3.0 Control Methods and Open Protocols

Table 3-1 provides a list of methods that a lighting control device may use to communicate with, signal, or otherwise manipulate a luminaire's functional parameters. In the simple case of an incandescent lamp, the lighting control device (dimmer or relay) directly manipulates the voltage that is supplied to the filament to achieve the required dimming level (the dimmer or relay may receive its control via another protocol). In luminaires that utilize drivers or ballasts, such as those with LEDs or fluorescent lamps, the dimming methods listed in the table refer to the control method or signal protocol between the lighting control device and the luminaire driver or ballast.

Table 3-1 also provides the recommended designations of control methods and open protocols that are interoperable. It is important to note that some of these may include extensions, parameters, or options that,

whether or not applied, may result in some limits to functionality. Use of the definition or reference standard (listed in the second column) is also acceptable. It is important to note that "Dimmable" is not an acceptable designation, since the term is not specific.

For any luminaire, regardless of its dimming method, a dimming curve may be applied to the signal, or dimming curves may be a parameter of the driver or ballast. Dimming curves come in many types and allow for adjustments to be introduced between the dimming percentage displayed to the user and the percentage output of the light source. For instance, a user setting of 50% output may correspond to a luminaire output of 42%. The designations in **Table 3-1** do not address dimming curves.

Designations in **Table 3-1** are appropriate for use on a luminaire's manufacturer data sheet to indicate how that luminaire is designed to be controlled, except for and Not Controlled (NC), also known as "always on." Switched Control (SWC) is used in a project specification or Sequence of Operation (SOO) to indicate a lighting load is only to be switched on and off (not dimmed) in that application. SWC also applies to luminaires that are not dimmable.

Table 3-1 Dimming and Control Method Designations – Fully Interoperable

Designation	Definition and/or Reference Standard	Comments
LE, FPC	Leading edge (a.k.a. forward phase control)	"TRIAC" (triode for alternating current) and "MLV" (magnetic low voltage) are not recommended designations for this type of control, since "TRIAC" refers to the technology and not the method, and MLV may not be exclusively leading edge.
TE, RPC	Trailing edge (a.k.a. reverse phase control)	"ELV" (electronic low voltage) is not a recommended designation for this type of control, since not all ELV loads are trailing edge, nor are all trailing edge loads low voltage.
UPC	Universal phase control (phase adaptive); compatible with either LE or TE	Dimmer may change modes automatically or require configuration; dimmer manufacturers are expected to provide this information. This designation is only appropriate when specifying or providing dimmers. Luminaires that are controlled via UPC dimmers should normally be designated with the more accurate designation of either LE or TE.

(continued next page)

Table 3-1 Dimming and Control Method Designations – Fully Interoperable *(continued)*

Designation	Definition and/or Reference Standard	Comments
LE3W	3-wire phase control	Control is achieved by utilizing a switched hot current carrying conductor, a leading edge (LE) dimmed conductor to provide the control signal, and a shared neutral conductor. <i>A legacy dimming method. Not common in new products.</i>
SWC	On/off switched control	For luminaires, drivers, and lamps that are not dimmable: this designation should only be used on a luminaire, driver, or light source that is not dimmable and can only be controlled in an on/off method. This designation is used on lighting schedules when the luminaires or lamps are only to be on/off switch controlled and not dimmed, regardless of whether they offer dimming functionality. For control: <i>Non-dim</i> (ND) is not a recommended designation for this type of control, as it may be confused with a load intended to be constantly on (see “NC” below).
NC	Not controlled (a.k.a. always on)	Constantly on (24/7). The NC designation may be used in control and luminaire schedules for luminaires that are switchable or dimmable but are not to be controlled (i.e., will be constantly on) for the specific project. This designation specifies that the luminaires could be left on and therefore not controlled, regardless of whether they offer additional dimming functionality. Therefore, this designation should not be used on a luminaire cutsheet, as another designation in these tables will always be more accurate.
10V	1 to 10 V (Refer to ANSI C82.1 ¹ and/or ANSI C137.1. ²)	Often referred to as <i>0-10V</i> , which can be confusing since no dimming occurs between 0 V and 1 V (the minimum level); Off is obtained via use of a relay or switch. (Refer to Section 9 and Annex B (B.1) of ANSI/IES LP-6-2 The controller sinks the current provided from the luminaire driver. Not interoperable with T10V devices.
10VOFF	Dim-to-off; 0 to 10 V (Refer to ANSI C137.1. ²)	Often referred to as <i>0-10V</i> or <i>0-10V Standby</i> , this method does not require a relay or switch for Off, because a low control voltage (approximately 0 to 0.5 V) signals the driver to go into standby (a.k.a. electronic off) mode. Often identified as “dim-to-off.” (Refer to Section 9 and Annex B (B.2) of ANSI/IES LP-6-25 for more information.) The controller sinks the current provided from the luminaire driver. Not interoperable with T10V devices.

Table 3-1 Dimming and Control Method Designations – Fully Interoperable *(continued)*

Designation	Definition and/or Reference Standard	Comments
T10V	ANSI E1.3 0-10V ³	Primarily used in the entertainment industry. The controller provides (sources) the current and provides for full range control from 0 – 10 V. Not compatible with 10VOFF or 10V devices.
BT NLC	Bluetooth networked lighting control	Wireless digital communication protocol developed and maintained by the Bluetooth Special Interest Group (SIG) specifically for networked lighting control systems. Uses short-range radio frequency (RF) to communicate with other nearby Bluetooth-enabled devices.
DALI	Digital Addressable Lighting Interface (Refer to IEC 62386-101 ⁴ and IEC 62386-102. ⁵)	An open protocol for bidirectional communication between digital lighting control products and digital luminaires. DALI is developed and advocated for by the Digital Illumination Interface Alliance (DiiA) commonly known as the DALI Alliance.
DALI-2	Digital Addressable Lighting Interface (Refer to IEC 62386-101. ⁴)	DALI-2 is the current “base level” DALI implementation. It includes the features of the original DALI protocol, plus some additional features, while maintaining backward compatibility. DALI-2 products are certified for compliance by the DALI Alliance (Refer to Section 9.5 and Annex B of ANSI/IES LP 6-25 for more information.)
DALI+	(DALI-2 over IP)	DALI+ is the IP-based or wireless version of DALI-2. DALI+ products are certified for compliance by the DALI Alliance.
D4i	ANSI C137.4 ⁶	D4i is a superset of DALI-2 specification that has an intra-luminaire architecture suitable for integral or per-luminaire sensors. There are several compulsory parts required for all D4i drivers. D4i drivers require auxiliary power.
DMX512	USITT DMX512-A (Refer to ANSI E1.11-2024. ⁷)	DMX512 is the recommended designation, although DMX is often used.
RDM	Remote Device Management for DMX512 (Refer to ANSI E1.20-2025. ⁸)	RDM is an extension to the DMX512 protocol that permits a controlling device to discover and then configure, monitor, and manage devices connected through a DMX512 network.
sACN	Lightweight streaming protocol for transport of DMX512 using ACN (refer to Table 4-1, Section 4.0 in this document). (Refer to ANSI E1.31. ⁹)	sACN is typically run on an Ethernet network.
PWMx	Pulse-width modulation	x = Operating voltage. Common voltages are 5, 12, and 24 VDC

4.0 Protocols That Are Not Fully Interoperable

In addition to the protocols described in **Table 3-1**, there are protocols and control transport layers that do not meet the requirements of being fully open and are therefore not fully interoperable.

These additional protocols fall into one of three types:

- Proprietary protocols
- Open and available protocols that do not include lighting control signals

- Protocols and transport layers that do not always function together in a predictable way

These protocols are commonly used, and typically function without issue, but since they are not openly available and fully interoperable, it is important that they be specified with care. These three types are discussed in further detail in the **Sidebar** and summarized in **Table 4-1**.

Typically, the designation “MFR” should be used with these control types, as this is an accepted method to indicate that a manufacturer’s proprietary implementation is specified, and therefore further diligence is required to ensure compatibility.

Sidebar: Protocol Types That Are Not Fully Interoperable

- *Proprietary protocols*: These are developed and maintained by a single party or a group of parties, and access to or interoperability with them is only available for members of that group within the proprietary system. Because proprietary protocols can only be used with compatible products, a standard designation for these protocols would not provide the clarity necessary for a complete specification. A specifier should clarify in the specification documents that proprietary protocols are being used, and that some manufacturers, products, or options are thus not compatible with the project design.
- *Open protocols that do not include lighting control signals*: An example is Power over Ethernet (PoE). In the context of lighting controls, the designation of PoE as a control type could be misleading. PoE is a well-documented set of standards for power delivery over Ethernet at the physical layer of the OSI model. However, there is no PoE standard for lighting controls at higher layers of the model. Therefore, while lighting controls systems that utilize PoE lighting controls provide power via one of the openly available power delivery standards, the messages being delivered are not interoperable from one manufacturer to another. Therefore, simply specifying PoE on a lighting controls document does not provide sufficient clarity for a complete specification of a PoE lighting control system.
- *Inconsistent terminology*: This third type is made up of a large group of controls designations for which the same terms are used for the application layer, transport layer, and/or the protocol layers, and are not applied in a consistent manner. An example is Z-Wave, a low-power mesh network standard. Z-Wave is a combination of Transport and higher layer specifications that can be combined with an open-source library for an entire control stack that is free to use, and openly interoperable between various manufacturers of controls devices and luminaires. However, Z-Wave is also used in various proprietary products that use, for example, the Transport and higher layers of the Z-Wave standard but provide a proprietary application layer that precludes a product, which has now become proprietary, from being used with a different open and interoperable Z-wave device elsewhere in the system. Even though both systems are proper implementations of Z-Wave controls, they are not interoperable.

Other examples of well known, often used, and not fully interoperable designations include LoRa, Zigbee, Bluetooth, Power Line Carrier, Wi-Fi, Thread and 6LoWPAN, and various other manufacturer-specific protocols.

Table 4-1. Common Dimming and Control Method Designations With Limited Interoperability Due to Manufacturer Proprietary Elements

Designation	Definition and/or Reference Standard	Comments
BT LE	Bluetooth Low Energy	A wireless Bluetooth implementation optimized for low power consumption and short-range communications.
BT Mesh	Bluetooth Mesh	A wireless Bluetooth implementation that allows for dynamic mesh communications.
ZBx	Zigbee 3.0, ¹⁰ Zigbee 4.0 ¹⁰	x = Zigbee version. Identification of the minimum version is needed so that the specific functionality required is supplied. Zigbee is managed by the Connectivity Standards Alliance (formerly, the Zigbee Alliance). This application is considered “MFR” (see below).
Z-Wave	Wireless mesh (some implementations may use proprietary elements)	A method to communicate lighting control signals, including dimming, over a wireless mesh network (some implementations may use proprietary elements).
ACN	Architecture for Control Networks (refer to ANSI E1.17) ¹¹	Not typically used for luminaire control
PoE	Power over Ethernet	A protocol for a standard way of delivering power, but that protocol lacks a standard for control communications.
TALQ		Interface Standard for Smart City Device Networks
MFR	Proprietary	This designation includes many implementations that use standard protocols, such as Zigbee, Wi-Fi, power line carrier (PLC), and Power over Ethernet (PoE) as a basis, but use manufacturer-specific commands and are therefore not an open method.

Annex A

Sample Luminaire and Control Schedules

This annex is not part of ANSI/IES RP-42-25 but is included for informational purposes only.

The schedules in **Sections A.1** and **A.2** provide generic examples to illustrate the use of dimming and control method designations. As stated in **Section 3.0**, “Dimmable” is not an acceptable designation, since the term is not specific.

A.1 Sample Luminaire Schedule

The example luminaire schedule shown in **Table A-1** has a “Control Method” column, which includes the dimming method designation from **Table 3-1** (see **Section 3.0**).

Table A-1. Example of a Luminaire Schedule

TYPE	DESCRIPTION	MANUFACTURER/ MODEL	LAMP	WATTS	VOLTAGE	CONTROL METHOD	NOTES
A	Wall Sconce	XYZ #199-35-UNV ABC #458-35-10V	LED 3500 K	33	120	10V	
B	2' x 4' RECESSED	XYZ #243-35-UNV ABC #577-35-10V	LED 3500 K	42	277	10V	
D1	4" Dia. CIRCULAR DOWNLIGHT	XYZ #443-30 HKL #CY41000	LED 3000 K	19	277	DALI	
D2	PENDANT	XYZ #446P-30 HKL #CP41000	LED 3000 K	19	120	DALI	
F4	1' x 8' WALL GRAZER	SKC #TYM465	LED RGBA	23/ft	277	DMX512	
G	Decorative Pendant	MKSS #4323	A19 LED 2700 K	11	120	TE	

A.2 Sample Controls Schedule

The example controls schedule shown in **Table A-2** includes a Control Method column, which includes the dimming method designation from **Table 3-1** (see **Section 3.0**). Some dimmable luminaires may be intended for switching only. (Note: Some control schedules may not include circuit numbers, as that information may appear in other schedules.)

Table A-2. Example of a Controls Schedule

AREA	CHANNEL (ZONE)	LUMINAIRE TYPE	DESCRIPTION	CIRCUIT #	VOLTAGE	LOAD	QTY	TOTAL LOAD	CONTROL METHOD	NOTES
MEETING	1	A	CENTER 2x4	LCP-5	277	43	4	172	10V	
MEETING	2	D1	PERIMETER DL	LCP-6	277	19	24	456	DALI	One driver per luminaire
LOBBY	1	D2	PENDANT	LCP-8	120	23	15	345	DALI	One driver per luminaire
LOBBY BAR	2	G	DECORATIVE	LCP-10	120	18	8	144	TE	
FRONT DESK	3	F4	WALL WASH	LCP-12	277	30	4	120	DMX512	
MARKET	1	D2	PENDANT	LCP-14	120	11	4	44	LE	
MARKET	2	H	TRACK	LCP-5	120	48	2	96	SWC	

Annex B

Sample Data Sheets

B.1 Example Data Sheet With Undefined (Nonspecific) Dimming Method

This example is representative of data sheets found online that declare a lamp dimmable but do not state the actual dimming method. The proper designations are shown to the right of the table. (Some fields have been left blank.)

LED Bulb Dimmable			
Bulb Characteristics		Bulb Dimensions	
Base	Medium Screw E26	Height	5.46 "
Shape	Bulb	Width	2.80"
Lamp Shape Code	A19		
Dimming Method or Control Method	LE, TE or UPC		
Voltage	120 V		
Wattage	12W		
Wattage Equivalent	75W		

B.2 Example Data Sheet With Defined Non-dimming Method (Non-RP-42 Format)

This example is representative of data sheets found online that declare a lamp not dimmable. While technically correct, it is not the recommended designation. The proper designations are shown to the right of the table.

LED Bulb			
Room Types			
Bedroom, Family Room, Dining Room, Hallways		Finish	White
Outdoor Rated	No	Applicable Dimming or Control Method	SWC
Replacement Watts	75 W		
Base	E26	Base Name	Medium
Bulb Shape	A21	Warranty	3 years
Color	Soft White		

B.3 Example Configurable Luminaire Data Sheet With No Dimming Method Specified

This example is representative of data sheets found online that do not declare the luminaire dimming or control method. This information may or may not be found elsewhere in the data sheet. Without clear information as to what dimming methods are compatible with this luminaire, it becomes problematic for the designer and installer to properly specify and install compatible dimming products appropriate for the luminaire.

LED Luminaire

Order Guide

Series	Lumens	Color Temp	Beam	Voltage	Options
	-		-		
ABC	L40 = 4,000	K30 = 3000 K	N = Narrow	120	EM = Emergency
	L55 = 5,500	K35 = 3500 K	M = Medium	240	OS = Occ Sensor
	L70 = 7,000	K40 = 4000 K	W = Wide	277	OSH = High Bay
		K50 = 5000 K		UNV (120-277)	Occ Sensor

B.4 Example Configurable Luminaire Data Sheet With One Dimming or Control Method Identified

This example is representative of data sheets found online that declare the luminaire family all dimmable, with the 10V method provided in a note to the part number configurator. It is important to note here that clearly providing a dimming designation allows the designer and installer to specify and provide the compatible dimming method and avoid errors in the field.

LED Luminaire

Order Guide

Series	Lumens	Color Temp	Beam	Voltage	Options
	-		-		
ABC	L40 = 4,000	K30 = 3000 K	N = Narrow	120	EM = Emergency
	L55 = 5,500	K35 = 3500 K	M = Medium	240	OS = Occ Sensor
	L70 = 7,000	K40 = 4000 K	W = Wide	277	OSH = High Bay
		K50 = 5000 K		UNV (120-277)	Occ Sensor

Note: All Luminaires Dimmable (10V)

B.5 Example Configurable Luminaire Data Sheet With Dimming Methods Identified

This example is representative of data sheets found online that declare the luminaire specifiable with different control methods and provide the available dimming methods in the part number configurator.

LED Luminaire

Order Guide

Series

Lumens

Color Temp

Beam

Voltage

Options

- - - - -

ABC

L40 = 4,000
L55 = 5,500
L70 = 7,000

K30 = 3000 K
K35 = 3500 K
K40 = 4000 K
K50 = 5000 K

N = Narrow
M = Medium
W = Wide

120
240
277
UNV (120-277)

EM = Emergency
OS = Occ Sensor
OSH = High Bay Occ
Sensor
10V = 1-10v Dimming
DALI = DALI Dimming

REFERENCES

- 1 American National Standards Institute. ANSI C82.11-2023, High Frequency Fluorescent Lamp Ballasts. Washington, DC: ANSI; 2023.
- 2 ANSI Board of Standards Review. ANSI C137.1-2022, American National Standard for Lighting Systems – 0-10V Dimming Interface for LED Drivers, Fluorescent Ballasts, and Controls. Rosslyn, Virg.: National Electrical Manufacturers Association; 2022.
- 3 American National Standards Institute. ANSI E1.3-2001 (R2021), Entertainment Technology – Lighting Control Systems 0 to 10V Analog Control Specification. Washington, DC: ANSI; 2021.
- 4 International Electrotechnical Commission. IEC 62386-101:2022, Digital Addressable Lighting Interface, Part 101: General requirements – System. Boston: IEC; 2022.
- 5 International Electrotechnical Commission. IEC 62386-102:2022, Digital Addressable Lighting Interface, Part 102: General requirements – Control gear. Boston: IEC; 2022.
- 6 American National Standards Institute. ANSI C137.4-2021, American National Standard for Lighting Systems – Interoperability of LED Drivers and Other Connected Devices via the Digital Addressable Lighting Interface. Rosslyn, Virg.: National Electrical Manufacturers Association; 2021.
- 7 American National Standards Institute. ANSI E1.11-2024, Entertainment Technology – USITT DMX512-A, Asynchronous Serial Digital Data Transmission Standard for Controlling Lighting Equipment and Accessories. Washington, DC: ANSI; 2024.
- 8 American National Standards Institute. ANSI E1.20-2010, Entertainment Technology – RDM – Remote Device Management over USITT DMX512 Networks. Washington, DC: ANSI; 2010.
- 9 American National Standards Institute. ANSI E1.31-2018, Entertainment Technology – Lightweight Streaming Protocol for Transport of DMX512 Using ACN. Washington, DC: ANSI; 2018.
- 10 Connectivity Standards Alliance. Online: <https://csa-iot.org/>. (Accessed 2025 Nov 3).
- 11 American National Standards Institute. ANSI E1.17-2015 (R2020), Entertainment Technology – Architecture for Control Networks. Washington, DC: ANSI; 2020.

Process for Change to an ANSI/IES Standard Under Continuous Maintenance

This standard is maintained under continuous maintenance procedures, for which IES has an established and documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Committee consideration will be given to proposed changes by June 30 of any given year for proposed changes received by the IES Director of Standards no later than December 31 of the previous year.

Submittal Format

Proposed changes must be submitted to the IES Director of Standards in the announced published format. However, changes may be accepted in an earlier published format, if the differences are immaterial to the proposed change submittal. If the Director of Standards concludes that a current form must be utilized, the proposer may be given up to 20 additional days to resubmit the proposed changes in the current format.

Specific changes in the text or values are required and must be substantiated. Any change proposals that do not meet these requirements will be returned to the proposer. Supplemental background documents to support changes submitted may be included.

Submission to the Committee Chair

The Director of Standards shall forward proposed changes received on appropriate forms to the committee chair for assigning to committee members (responders) to develop responses to submitters of proposed changes.

Review and Clarification

Responders shall review proposals and should contact the proposer if necessary for clarification.

Response Recommendation

Designated responders shall draft a recommended committee response, including any recommended changes to the standard. The 'responders' recommended responses shall be submitted to the committee chair in electronic form usable by Society Staff, including any recommended change to the standard in response to proposals received.

Options for Committee response are limited to:

- a) Proposed change accepted for public review without modification
- b) Proposed change accepted for public review with modification
- c) Proposed change accepted for further study
- d) Proposed change rejected

The responders shall provide reasons for any recommendation other than option (a) above.

The designated responders shall not recommend option (c) unless the further study can be completed by October 1 of that year, and providing the Committee can then vote for option (a), (b), or (d) no later than November 15 of that year.

Editing

The Committee chair or his or her designee shall edit the draft responses and circulate the edited drafts to the committee for review.

Form for Proposing Change to an ANSI/IES Standard Under Continuous Maintenance

NOTE:

Use a separate form for each comment. Submit to the Director of Standards, IES, 85 Broad St, FL 17, New York NY 10004.
Email: standards@ies.org. Fax: 212-248-5017.

1. Submitter: _____
Affiliation: _____
Address: _____
City: _____ State: _____ Zip: _____ Country: _____
Telephone: _____
Fax: _____
E-mail: _____

I hereby grant the Illuminating Engineering Society (IES) the non-exclusive royalty rights, including non-exclusive rights in copyright, in my proposals. I understand that I acquire no rights in publication of the standard in which my proposals in this, or other analogous, form are used. I hereby attest that I have the authority and am empowered to grant this copyright release.

Submitter's signature: _____ Date: _____

2. Title of publications and year published _____

3. Clause (section), sub-clause or paragraph number; and page number: _____

4. My proposal (check one):

- ☐ Change to read as follows
- ☐ Delete and substitute as follows
- ☐ Add new text as follows
- ☐ Delete without substitution

Use underscore to show material to be added (added) and strikethrough for material to be deleted (~~deleted~~). Use additional pages if needed.

5. Proposed change:

6. Reason and substantiation:

Select as applicable:

- ☐ Additional pages are attached. Number of additional pages: _____
- ☐ Attachments or referenced materials cited in this proposal accompany this proposed change.

Please verify that all attachments and references are relevant, current, and clearly labeled to avoid processing and review delays. Please list your attachments here:



Lighting Science Standards

Fundamentals, Metrics and Calculations

Lighting Practice Standards

Design, Engineering, and Specifications

Lighting Applications Standards

Design Criteria and Illumination Recommendations

Lighting Measurements and Testing Procedure Standards

Industry Standardization

Roadway and Parking Facility Lighting Standards

Criteria and Illumination Recommendations

Order# ANSI/IES RP=42-26

ISBN 978-0-87995-509-0

www.ies.org