Los Angeles Lakers Headquarters

2275 East Mariposa Avenue El Segundo, California 90245 RA Rec'd 012816 Returned 020216 RFI Code A0



Request for Information

RFI 152 - Low Roof Steel Connection

Date Submitted 1/28/2016 To Fred Hofmann From Ethan Beaver

Date Required 2/4/2016 Rossetti Morley Construction Company

Discipline Structural Tel: (313) 463-5151 Tel: 310-399-1600

Author RFI Ref. OCE RFI-23 fhofmann@rossetti.com ebeaver@morleybuilders.com

Document Ref. Number Title Revision

S-115 LOWER ROOF FRAMING PLAN - NORTH Nov 20, 2015 - No: 4

Question

Attachments None

Please provide a connection for the W12x19's below gridline G on lines 2 and 5 (see attached MCC-SK-RFI 152-1). The W12x19 is at an elevation of 132'-10-1/2" and the W16x40 is at an elevation of 134'-2-1/2".

 Answer


 Date Answered
 ______ Answered By ______

See comments on attached sheets, and see SK-152.1 for offset beam connection.

KM / JLA 2/1/16

This clarification is interpreted to be within the scope of referenced contracts issued in accordance with the Contract Documents, and without change in Contract Sum or Contract Time, and, as such, is not an authorization for work beyond the scope of the contract.

Printed on: 1/28/2016 Page 1



DRAWING LOG SUBMIT FOR APPR. RECORD SET PURCHASING FABRICATION CONTRACTOR 517 E. LA PALMA AVENUE ANAHEIM, CALIFORNIA 92801 Orange County Erectors, Inc.

Orange County Erectors, Inc.

ON STATE ON STATE OF STA PHONE: (714) 502-8455 FAX: (714) 502-0034 E-MAIL: DETAILING@OCERECTORS.COM LOS ANGELES LAKERS HEADQUARTERS SITE ADDRESS: 2275 MARIPOSA, EI SEGUNDO, CA. DRAWN BY ANN CHECKED BY MF SCOPE ITEM: DETAILS ERECTED X JOB NO. 15-019 F.O.B.

_lobs\2015-085_Lakers\01 - AB - E Sheets\E020e.dwg, 1/21/2016 11:07:37 AM, jonf, CWSD, CWSD

