

Helium gas or liquid nitrogen for the first thermal shield of a 4 K cryostat: conjugate heat-transfer budget, coolant operating maps and work ledger

Imerson Joao^{a,*}

^a*Department of Engineering Science, University of Oxford, Oxford, United Kingdom*

Abstract

The first thermal shield of a 4 K cryostat intercepts most of the heat arriving from the 300 K environment. It can be held near 50 K by circulated helium gas, as in fusion and accelerator cryostats, or at 77 K by liquid nitrogen, as in magnet cryostats. This paper separates that choice into three questions and answers each with a dedicated model. (1) The passive penalty of the warmer shield is computed with a three-dimensional multi-region conjugate heat-transfer model of a representative cryostat section that resolves view-factor radiation and the conduction of a 65-line coaxial harness; the view-factor matrix is shown to require row normalisation in a low-emissivity enclosure, after which the model reproduces the closed-form loads to 4 %. (2) The two coolants are compared in a channelled cold plate at a matched 9.4 W duty over Reynolds numbers 500–10 000, laminar to turbulent, and helium pressures of 1–18 bar, with properties from the National Institute of Standards and Technology (NIST) reference equations of state, three-grid verification for both fluids and energy closure below 0.2 %. (3) The routes are priced in room-temperature power with ideal Carnot multipliers and with published hardware efficiencies. The warmer shield costs nothing at the first stage, 8.3 against 8.4 W; its penalty is 106 mW at the 4 K stage, 86 % of it harness conduction, so it is a property of the wiring rather than of the cryogen. In the cold plate nitrogen gives five times helium’s heat-transfer coefficient in laminar flow and six times in turbulent flow, and holds the plate within 4 K of its inlet where helium at 1 bar floats 21 K above and exceeds 77 K below a

*Corresponding author.

Email address: pemb7049@ox.ac.uk (Imerson Joao)

Reynolds number of about 1400; at 18 bar helium's pumping power falls 8.5 times below nitrogen's with heat transfer unchanged, so the ranking depends on the basis and the operating point. The ideal ledger favours nitrogen by 21 % for a bare shield and helium by 8 % once multi-layer insulation removes most of the first-stage load; with hardware efficiencies helium is cheaper by 35–50 % in both cases, and nitrogen becomes competitive only if the harness conduction to 4 K is cut by about a factor of three. Operating maps, uncertainty bands and the complete case set are provided.

Keywords: cryostat, thermal shield, conjugate heat transfer, liquid nitrogen, helium gas, pulse-tube cryocooler, exergy, OpenFOAM

1 Nomenclature

2 Roman

A	area [m ²]
c_p	specific heat [J kg ⁻¹ K ⁻¹]
D_h	hydraulic diameter [m]
f	Darcy friction factor [-]
F_{ij}	view factor from face i to face j [-]
h	heat-transfer coefficient [W m ⁻² K ⁻¹]
J	radiosity [W m ⁻²]
k	thermal conductivity [W m ⁻¹ K ⁻¹]
$\dot{m}$	mass flow rate [kg s ⁻¹]
Mo	Mouromtseff number [-]
N	number of MLI layers [-]
NTU	number of transfer units [-]
Nu	Nusselt number hD_h/k [-]
p	pressure [Pa]
Pr	Prandtl number [-]
$\dot{Q}$	heat load [W]
q	heat flux [W m ⁻²]
Re	Reynolds number $\rho U D_h/\mu$ [-]
$\dot{S}_{\text{gen}}$	entropy generation rate [W K ⁻¹]
T	temperature [K]
T_0	heat-rejection temperature, 300 K
U	mean velocity [m s ⁻¹]
$\dot{W}$	wall power [W]
$\dot{W}_p$	pumping power [W]
y^+	wall coordinate [-]

4	Greek	9	Acronyms
	β	10	CFD computational fluid dy-
		11	namics; CHT conjugate heat transfer;
		12	DTT Divertor Tokamak Test facility; GCI
	ε	13	grid convergence index; ITER International
		14	Thermonuclear Experimental Reactor; LHC
	η_i	15	Large Hadron Collider; LHD Large He-
5		16	lical Device; MLI multi-layer insulation;
		17	NIST National Institute of Standards and
	κ_{eff}	18	Technology; NTU number of transfer units;
		19	OVC outer vacuum can; PTFE polytetraflu-
	μ	20	oroethylene; PTR pulse-tube refrigerator;
	ρ	21	SIMPLE semi-implicit method for pressure-
	σ	22	linked equations; SST shear-stress trans-
6	Subscripts	23	port; STL stereolithography (surface file for-
7	0 ambient; 1 first stage; 2 sec-		mat).
8	ond (4 K) stage; b bulk; c conduction; r ra-		
	diation; sat saturation; w wall.		

24 1. Introduction

25 A cryostat that holds a payload at 4 K places at least one thermal shield
26 between the payload and the 300 K vacuum vessel. The shield intercepts
27 the radiation from the vessel and the conduction along supports and wiring,
28 and it does so at a temperature where refrigeration is one to two orders
29 of magnitude cheaper than at 4 K [1, 2, 3]. Two ways of cooling this first
30 shield are in wide use. Large superconducting systems circulate pressurised
31 helium gas through cooling tubes on the shield: the thermal shield of the
32 International Thermonuclear Experimental Reactor (ITER) runs on helium
33 at 80 K and 1.8 MPa [4], the shield of the Divertor Tokamak Test facility
34 (DTT) on the same loop conditions [5], the shields of the Large Helical
35 Device (LHD) on gaseous helium in parallel paths [6], and the shields of
36 the Large Hadron Collider (LHC) on helium at 50–75 K [7, 8]. Magnet and
37 detector cryostats, and the older generation of helium cryostats, use a liquid-
38 nitrogen bath or loop at 77 K [9, 10]; Li et al. made the practical case for
39 it three decades ago, that a boiling cryogen holds the shield temperature
40 constant and carries a stored reserve, whereas a helium-gas shield warms as
41 soon as its refrigerator stops [11]. Compact laboratory cryostats, including
42 the dry dilution refrigerators that host superconducting quantum processors,
43 use the first stage of a helium pulse-tube refrigerator (PTR) at 40–50 K
44 instead [12, 13, 14]. As these laboratory systems grow toward the multi-
45 metre cryostats now being built for quantum platforms [15, 16], they inherit
46 the shield-cooling question that fusion and accelerator cryostats answered

with circulated fluids, and the cryogenic plant becomes a dominant part of the system's energy cost [17, 18, 19].

The published treatments of this choice fall into four strands that do not meet. First, shield design temperatures are optimised with lumped static budgets and refrigeration-power minimisation: Lagrange-multiplier optimisation of nitrogen, neon and helium-gas intercepts on supports and in insulation [11], multi-stage shields for transmission-line cryostats [20], fusion thermal shields [21, 5], and single-shield helium cryostats brought to zero boil-off by load minimisation [22]. These are one-dimensional: they return a stage total, not where the load lands. Second, wiring loads are measured and modelled per cable [14, 23, 24], again as conduction integrals that assign the harness a single resistance and leave it uncoupled from the radiation field. Third, surface-to-surface radiation in computational fluid dynamics (CFD) codes has been validated on enclosure benchmarks and applied to fusion vacuum vessels [25], but not coupled to temperature-dependent harness conduction in a cryostat shield, and the behaviour of agglomerated view-factor matrices in such enclosures has not been examined. Fourth, cryogenic heat exchangers are optimised by entropy-generation minimisation [26, 27, 28] and liquid-nitrogen cooled components are now modelled with combined analytical and CFD frameworks [29], yet helium gas and liquid nitrogen have not been ranked against each other as forced-convection first-shield coolants on a common duty across flow regimes and pressures, with heat-transfer, hydraulic, effectiveness and second-law metrics reported together and the single-phase margin of the nitrogen verified. Finally, the cryocooler and liquefier efficiencies that separate an ideal Carnot ledger from a real one are well documented [30, 8, 31], but the two ledgers have not been reconciled for this choice.

The gap is therefore not a missing number but a missing junction. What is absent is a treatment that (i) resolves shield radiation and harness conduction together in three dimensions on one geometry, (ii) compares the two coolants like for like in the cold plate that geometry implies, and (iii) prices both routes with ideal and with hardware efficiencies, so that the conditions under which each route wins can be stated rather than assumed.

This paper therefore asks three questions about a representative 4 K cryostat section with a 65-line coaxial harness (Figs. 1 and 2):

Q1 (passive penalty). What does raising the first shield from 50 K to 77 K cost in heat load at the first stage and at the 4 K stage, and which

84 mechanism carries the cost?

85 **Q2 (coolant performance).** If the first-stage duty is removed by a coolant
 86 circulated through a channelled cold plate, how do helium gas and
 87 liquid nitrogen compare across flow regimes, pressures and bases of
 88 comparison, and where is each fluid’s best operating point?

89 **Q3 (work ledger).** What do the two routes cost in room-temperature power,
 90 with ideal Carnot multipliers and with the efficiencies of real hardware?

91 Q1 is answered with a three-dimensional multi-region conjugate heat-transfer
 92 (CHT) model that resolves view-factor radiation and temperature-dependent
 93 harness conduction. Its stage-integrated loads are verified against closed-
 94 form budgets; its contribution is the spatial distribution of the load and the
 95 split between harness families. Q2 is answered with a grid-converged cold-
 96 plate model run for both fluids over $Re = 500\text{--}10^4$ and helium pressures of
 97 1–18 bar, with properties from the NIST reference equations of state [32]. Q3
 98 combines the stage loads of Q1 with Carnot multipliers and with published
 99 cryocooler and liquid-nitrogen plant efficiencies [30, 33, 31]. The dilution
 100 unit or any payload below 4 K is outside the scope; the results apply to any
 101 4 K cryostat with a wired first shield.

102 2. Models and methods

103 2.1. Governing equations

104 Both models solve steady conservation equations with OpenFOAM v2412 [34].
 105 In the enclosure model the inter-stage gaps are vacuum, so each gap region
 106 carries only the radiative exchange and each solid region carries conduction
 107 with a temperature-dependent conductivity,

$$\nabla \cdot [\kappa_{\text{eff}}(T) \nabla T] = 0 \quad \text{in the harness bundles,} \quad (1)$$

108 coupled at the bundle surfaces to the radiative flux of the enclosing gap.
 109 Radiation is solved as a grey-diffuse radiosity system on the agglomerated
 110 boundary faces,

$$J_i = \varepsilon_i \sigma T_i^4 + (1 - \varepsilon_i) \sum_j F_{ij} J_j, \quad q_{r,i} = J_i - \sum_j F_{ij} J_j, \quad (2)$$

111 where F_{ij} are geometric view factors computed by ray tracing between ag-
 112 glomerated faces (**viewFactor** model). For two parallel grey surfaces Eq. (2)




Figure 1: Cross-section of the cryostat class studied, with (a) the helium-gas route and (b) the liquid-nitrogen route for the first shield. The dashed region from the 300 K plate to the 4 K plate is the enclosure CHT model and the channelled first-stage plate is the cold-plate model; the greyed stages below 4 K are shown for context only and are not modelled.




Figure 2: The three first-shield cooling routes and the two models. (a) Reference architecture with a conductively coupled PTR first stage; (b) circulated helium gas through a channelled cold plate; (c) liquid nitrogen through the same cold plate. The dashed box is the domain of the passive enclosure CHT model (Q1); the dotted box is the domain of the active cold-plate model (Q2). The loads $\dot{Q}_1 = \dot{Q}_{r,1} + \dot{Q}_{c,1}$ and $\dot{Q}_2 = \dot{Q}_{r,2} + \dot{Q}_{c,2}$ enter the work ledger ($\dot{Q}_3$), $\dot{W} = \sum_i \dot{Q}_i (T_0 - T_i) / (T_i \eta_i)$, with $\eta_i = 1$ (ideal) or the measured fraction of Carnot (real).

113 reduces to the closed form $q_r = \sigma(T_{\text{hot}}^4 - T_{\text{cold}}^4)/(1/\varepsilon_{\text{hot}} + 1/\varepsilon_{\text{cold}} - 1)$ [35],
 114 which is used as the verification anchor.

115 The cold-plate model solves the steady Reynolds-averaged (or, in the
 116 laminar range, the plain) continuity, momentum and energy equations for a
 117 single-phase coolant,

$$\nabla \cdot (\rho \mathbf{U}) = 0, \quad (3)$$

$$\nabla \cdot (\rho \mathbf{U} \mathbf{U}) = -\nabla p + \nabla \cdot [(\mu + \mu_t)(\nabla \mathbf{U} + \nabla \mathbf{U}^T)] + \rho \mathbf{g}, \quad (4)$$

$$\nabla \cdot (\rho \mathbf{U} h) = \nabla \cdot \left[\left(\frac{k}{c_p} + \frac{\mu_t}{Pr_t} \right) \nabla h \right], \quad (5)$$

118 with $\mu_t = 0$ for laminar runs and μ_t from the k - ω shear-stress transport
 119 (SST) model [36] for $Re \geq 5000$ ($Pr_t = 0.85$). The sweep is run as pure forced
 120 convection ($\mathbf{g} = 0$) so that the ranking does not depend on the orientation
 121 of the plate; the buoyancy parameter Gr/Re^2 is reported for every run, and
 122 three runs with gravity acting along the heated wall quantify the mixed-
 123 convection sensitivity (Section 4). Helium is treated as an ideal gas with
 124 variable density, $\rho = pM/(R_u T)$, because its density changes by 5–26 %
 125 between inlet and outlet and by up to a factor of 2 between bulk and heated
 126 wall; liquid nitrogen is treated with the Boussinesq approximation, $\rho = \rho_0[1 -$
 127 $\beta(T - T_0)]$, valid because $\beta \Delta T < 0.03$ in every run.

128 2.2. Enclosure CHT model (Q1)

129 The domain is a $0.718 \times 0.718 \times 0.335$ m section of a cryostat between
 130 the warm plate and the first-stage cold plate (Fig. 4; Table 1). Two vacuum
 131 gap regions (outer: outer vacuum can (OVC) to shield; inner: warm plate to
 132 cold plate and shield) and four solid cylinders of 20 mm diameter spanning
 133 the 0.335 m height are meshed with a $30 \times 30 \times 14$ background grid refined
 134 to level 2 around the cylinders ($0.2\text{--}0.4 \times 10^6$ cells in total). Each cylinder
 135 lumps one functional family of a cabled 65-line control harness [14]: 25 drive,
 136 25 flux, 10 readout and 5 pump lines, all of the UT-085 stainless-steel/PTFE
 137 coaxial construction. The family is represented by an effective conductivity

$$\kappa_{\text{eff}}(T) = \frac{n_k}{A_{\text{model}}} \sum_i A_i k_i(T), \quad (6)$$

138 where n_k is the number of lines in the family, A_i the cross-section of cable
 139 component i (outer conductor 1.585 mm^2 and centre conductor 0.205 mm^2)

Table 1: Enclosure model: geometry, boundary conditions and numerical settings.

Domain	$0.718 \times 0.718 \times 0.335$ m; OVC and shield as snapped stereolithography (STL) surfaces; four coax cylinders $\varnothing 20$ mm at radius 0.15 m
Regions	<code>domain0</code> (OVC–shield gap), <code>domain1</code> (warm plate–cold plate/shield gap), <code>coax.L1..L4</code> (solids)
Gas in gaps	vacuum: $p = 10^{-3}$ Pa, $g = 0$, $\mu = 10^{-11}$ Pa s (no convection, negligible gas conduction; free-molecular bound < 1 % of the stage load, Supplementary S1)
Temperatures	fixed: warm plate and OVC at T_{hot} ; shield and cold plate at T_{cold} ; cases (300, 50), (300, 77), (50, 4), (77, 4) K
Emissivity (baseline)	warm surfaces 0.04 (polished Al); shield and cold plate 0.02 (polished Cu-plated steel); harness 0.02
Emissivity (variants)	± 50 % (0.02/0.01 and 0.06/0.03); multi-layer-insulation (MLI) equivalent 0.003 on all first-stage surfaces
Radiation	<code>viewFactor</code> , grey diffuse, one band, solved every 10 iterations; agglomeration 250 faces per patch at the coarsest level (verification at 400 and 800)
Harness contact	bundles fixed at T_{hot} at the warm cap and T_{cold} at the cold cap; no contact resistance; lateral surfaces exchange by radiation only
Solver	<code>chtMultiRegionSimpleFoam</code> , semi-implicit method for pressure-linked equations (SIMPLE), residuals $< 10^{-7}$, 2900 iterations from a uniform initial field

140 of 304 stainless steel, polytetrafluoroethylene (PTFE) dielectric 2.001 mm^2),
 141 $k_i(T)$ the NIST cryogenic conductivity fits, and A_{model} the effective conduc-
 142 tion area of the modelled cylinder, calibrated once per geometry so that
 143 the resolved conduction reproduces the harness integral $n_k L^{-1} \sum_i A_i \int k_i dT$
 144 (Supplementary Table S4 lists the calibrated areas and the fifth-order poly-
 145 nomial coefficients of κ_{eff} for every bundle and stage span; fit error below
 146 0.5 %; Fig. 3).

147 *Verification and uncertainty.* Stage-integrated radiation is compared with
 148 the parallel-plate closed form and harness conduction with the analytic in-
 149 tegral; both agree within the tolerances reported in Section 3. Because the
 150 view-factor matrix is built on agglomerated faces, the radiative load was re-
 151 computed at 250, 400 and 800 coarse faces per patch and its closure $\sum_j F_{ij}$




Figure 3: Harness representation: (a) the 65 coaxial lines in four functional families, each lumped into one 20 mm cylinder; (b) the UT-085 cable cross-section with the component areas of Eq. (6); (c) the component conductivities and the resulting effective conductivity of the drive bundle.




Figure 4: Cut-away of the enclosure CHT domain for the 300 $\rightarrow$ 50 K case. The warm plate, outer vacuum can and first shield are cut open on the near side; the four harness bundles, coloured by their computed temperature, span the gap from the warm plate to the cold plate. The vacuum gaps between the surfaces carry radiation only.

monitored (Supplementary Table S5). The emissivity of polished cryogenic surfaces is uncertain by roughly a factor of 1.5 [37]; the $\pm 50\%$ runs give the uncertainty band carried through the ledger. An MLI-equivalent variant with $\varepsilon = 0.003$ on the first-stage surfaces represents a 10–20 layer blanket [38, 1].

What the three-dimensional model adds.. For a parallel-plate enclosure with fixed wall temperatures, the stage-integrated radiative and conductive loads are analytic, and the CHT model must reproduce them; that agreement is the model’s verification, not its result. The model contributes what the closed forms cannot: the distribution of radiative flux over the shield (which sets local shield temperatures once a real, finitely conductive shield is considered), the partition of conduction among harness families, the coupling between the harness and the surrounding radiation field, and, through the same geometry, the boundary conditions passed to the cold-plate model.

2.3. Cold-plate heat-exchanger model (Q2)

Basis of comparison.. The two fluids differ in phase, temperature, density by a factor of 800 and thermal conductivity by a factor of 3.1, so no single common basis is neutral. Three bases are therefore reported: matched Reynolds number (same flow regime), matched mass flow, and matched pumping power. All runs remove the same duty of 9.4 W, the conservative first-stage load of Section 3. Helium enters at 45 K, at 1, 5 or 18 bar (the ITER shield loop runs at 18 bar [4]); nitrogen enters as a liquid at 77 K in a 3 bar loop, for which $T_{\text{sat}} = 87.9$ K, and the saturation margin $T_{\text{sat}} - T_{\text{w,max}}$ is reported for every run to confirm single-phase operation. Table 2 lists the operating quantities and Fig. 5 the geometry.

Property correction.. An earlier version of this comparison used helium transport properties that correspond to about 15 K ($\mu = 2.7 \mu\text{Pa s}$, $k = 0.019 \text{ W m}^{-1}\text{K}^{-1}$), which understated the helium heat-transfer coefficient by a factor of about 2.5. All helium results here use the 50 K values of Table 2.

Metrics.. The heat-transfer coefficient is $h = \dot{Q}/[A_{\text{heated}}(T_{\text{w}} - T_{\text{b}})]$ with T_{w} the area-averaged heated-wall temperature and T_{b} the mean of the inlet and the mass-flux-weighted outlet temperature; $Nu = hD_{\text{h}}/k$; the Darcy friction factor $f = 2\Delta p D_{\text{h}}/(\rho U^2 L)$; pumping power $\dot{W}_{\text{p}} = \dot{m}\Delta p/\rho$; $NTU = hA/(\dot{m}c_p)$ and $\varepsilon = 1 - e^{-NTU}$ [39]; the Mouromtseff number $Mo = k^{0.6}\rho^{0.8}c_p^{0.4}\mu^{-0.4}$ [40]; and the exergy destruction $T_0\dot{S}_{\text{gen}}$ from volume integrals of the thermal and viscous entropy sources [28]. Laminar results are checked against the fully

Table 2: Cold-plate model: geometry, coolant states, properties and numerics. Properties from the NIST reference equations of state via CoolProp [32], evaluated at the inlet state and held constant except for the helium density (ideal gas) and the nitrogen buoyancy term.

	Helium gas	Liquid nitrogen
Geometry	five parallel square ducts, $D_h = 10$ mm, $L = 0.30$ m, one wall heated, $A_{\text{heated}} = 0.015 \text{ m}^2$, $A_{\text{cs}} = 5 \times 10^{-4} \text{ m}^2$	
Duty	9.4 W uniform flux on the heated wall, $q_w = 627 \text{ W m}^{-2}$	
Inlet T , p	45 K; 1, 5, 18 bar	77 K; 3 bar ($T_{\text{sat}} = 87.9$ K)
ρ [kg m^{-3}]	0.961 (1 bar), 4.80 (5 bar), 17.3 (18 bar) at 50 K	808
c_p [$\text{J kg}^{-1} \text{K}^{-1}$]	5201	2038
μ [$\mu \text{Pa s}$]	6.36	163.5
k [$\text{W m}^{-1} \text{K}^{-1}$]	0.0467	0.1457
Pr	0.71	2.29
β [K^{-1}]	$1/T$ (ideal gas)	5.6×10^{-3}
Re	500, 1000, 1500, 2300 (laminar); 5000, 10 000 (k - ω SST)	
Gravity	off (forced convection) for the sweep; on, parallel to the heated wall, for three sensitivity runs	
$\dot{m}$ at $Re = 2300$ [kg s^{-1}]	7.31×10^{-4}	1.88×10^{-2}
U at $Re = 2300$ [m s^{-1}]	1.52 (1 bar), 0.084 (18 bar)	0.047
Solver	buoyantSimpleFoam, heRhoThermo/perfect gas	buoyantBoussinesqSimpleFoam
Mesh	180 $\times$ 18 $\times$ 18 cells per duct, two-sided wall grading (ratio 6), 2.92×10^5 cells; grid convergence index (GCI) study on 86k/292k/984k cells for both fluids	
Convergence	residuals $< 10^{-6}$ (He) and $< 10^{-7}$ (LN_2); energy balance closure reported per run	




Figure 5: Cold-plate heat-exchanger model: (a) the five heated square ducts with boundary conditions and dimensions; (b) the graded duct cross-section with the two sampling lines used for the wall-temperature profiles.

187 developed square-duct limits $Nu_\infty = 3.61$ and $fRe = 56.9$ [41] and turbu-
 188 lent results against the Gnielinski correlation [42]. Wall temperature profiles
 189 along the heated-wall centreline are extracted for every run.

190 *Grid convergence..* Three systematically refined meshes (refinement ratio
 191 1.5) were run for both fluids at $Re = 2300$ and the discretisation uncertainty
 192 expressed as a GCI [43] (Section 4). For the turbulent runs the first-cell
 193 y^+ on the graded mesh averages 2.5–5.6 with a maximum of 9.5, within the
 194 range handled by the low-Reynolds wall treatment of the SST model.

195 2.4. Work ledger ($Q3$)

196 A load $\dot{Q}_i$ absorbed at T_i and rejected at $T_0 = 300$ K costs

$$\dot{W}_i = \frac{\dot{Q}_i}{\eta_i} \frac{T_0 - T_i}{T_i}, \quad (7)$$

197 where η_i is the stage efficiency as a fraction of Carnot. The ideal ledger sets
 198 $\eta_i = 1$: the multiplier is 5.0 at 50 K, 2.9 at 77 K and 74 at 4 K. The real ledger
 199 uses published hardware. A commercial two-stage PTR (Cryomech PT415)
 200 delivers 1.5 W at 4.2 K together with 40 W at 45 K for 10.7 kW of input [33];
 201 allocating the input in proportion to the Carnot work of each stage gives
 202 $\eta_2 \approx 0.011$ at 4.2 K and $\eta_1 \approx 0.045$ at 45 K (Supplementary S3), consistent
 203 with the 1 % and 10–15 % of Carnot that Radebaugh reports for 4 K and
 204 80 K coolers [30]. Liquid nitrogen carries 199 kJ kg⁻¹ of latent heat at 1 bar;
 205 its ideal production work is 0.213 kWh kg⁻¹ [2] and real air-separation plants
 206 need 0.5–0.7 kWh kg⁻¹ [31], an exergy efficiency $\eta_{N_2} \approx 0.3$ –0.4. The 4 K stage

207 of the nitrogen route is still served by a cryocooler, so its η_2 is the same in
 208 both routes. The ranges above are propagated as bands.

209 **3. Results Q1: the passive penalty of a 77 K shield**

210 *3.1. Radiation verification and the view-factor closure*

211 The first-stage radiative load computed with the view-factor matrix as
 212 generated does not converge under agglomeration refinement: 9.46, 8.41, 6.49
 213 and 3.26 W at 60, 250, 400 and 800 coarse faces per patch, against 7.07 W
 214 from the parallel-plate closed form (Fig. 6). The cause is closure. In a closed
 215 enclosure every row of the view-factor matrix must sum to one; the generated
 216 rows sum to between 0.50 and 1.13 (mean 0.97–1.01), and finer agglomeration
 217 worsens the scatter. With surface emissivities of 0.02–0.04 the radiosity is
 218 reflected of order $1/\varepsilon$ times before it is absorbed, so a per-reflection leak of a
 219 few per cent compounds into a load error of tens of per cent. Normalising each
 220 row of the generated matrix to unity removes the artefact: at the production
 221 level of 250 faces the $300 \rightarrow 50$ K load becomes 7.36 W (4.1 % above the closed
 222 form), the $300 \rightarrow 77$ K load 7.34 W (4.2 %), and the two 4 K-stage loads 3.16
 223 and 17.8 mW (0.5 % above 3.15 and 17.7 mW). The remaining 4 % at the
 224 first stage is the geometric departure of the real enclosure, with its harness
 225 penetrations, from the parallel-plate idealisation. All loads below are the
 226 row-normalised values; the unnormalised production values are retained as
 227 an upper band.

228 *3.2. Stage loads and mechanism split*

229 At the first stage radiation dominates and the shield temperature barely
 230 matters (Table 3, Fig. 7). The radiative flux scales with $T_{\text{hot}}^4 - T_{\text{cold}}^4$ and 300^4
 231 dwarfs both 50^4 and 77^4 , so the 77 K shield intercepts 99.6 % of what the
 232 50 K shield intercepts. Harness conduction falls with the smaller span, 962
 233 against 1029 mW. The first-stage loads are 8.39 W (50 K) and 8.30 W (77 K);
 234 the emissivity band of ± 50 % moves them between 6.5 and 12.5 W but leaves
 235 the 1 % difference between routes unchanged. The conservative production
 236 value of 9.4 W is used as the cold-plate duty in Section 4.

237 At the 4 K stage the picture inverts. Residual radiation rises by the factor
 238 $(77^4 - 4^4)/(50^4 - 4^4) = 5.6$, but from a base of 3 mW; harness conduction
 239 rises by the factor 2.31 from a base of 70 mW. The 77 K route therefore
 240 delivers 106 mW more to the 4 K plate: 92 mW of conduction and 15 mW
 241 of radiation, 86 % conductive. Through the ideal 4 K multiplier of 74 this




Figure 6: First-stage radiative load ($300 \rightarrow 50$ K) against the view-factor agglomeration level with the matrix as generated (circles) and with its rows normalised to unity at the production level (square), compared with the closed-form grey-body value. The monotonic collapse under refinement is a closure artefact amplified by the low emissivities.

is 7.9 W of room-temperature power, 6.8 W of it from the harness. Every stage-integrated ratio agrees with its closed form to better than 0.5 %.

The MLI-equivalent shield ($\varepsilon = 0.003$ on the first-stage surfaces) cuts the first-stage radiation to 1.81 W on either route (closed form 1.47 W with the production-level matrix bias), so the first-stage loads fall to 2.84 and 2.77 W and become conduction-heavy (36 % conduction). The 4 K-stage loads are unaffected. This variant is the one that changes the ledger verdict in Section 5.

3.3. Spatial distribution

The view-factor solution concentrates the radiative flux on the shield regions with a direct line of sight to the OVC ($8.2\text{--}10.8 \text{ W m}^{-2}$ across the shield) and leaves the harness penetrations cooler (Fig. 8). Conduction is shared among the bundles in the ratio of their line counts: on the $77 \rightarrow 4$ K span the drive and flux families deliver 125 of the 162 mW. These two bundles are the targets for any intermediate heat sink, and the harness conduction integral, not the cryogen, is the lever on the 4 K-stage penalty.

Table 3: Stage loads by mechanism (row-normalised view factors; closed-form value in parentheses), with the unnormalised production value and the $\pm 50\%$ emissivity band as upper and lower bounds.

Case	Radiation	Conduction	Total	Prod.	$\varepsilon \pm 50\%$ [W]
300 $\rightarrow$ 50 K	7.36 W (7.07)	1.029 W (1.029)	8.39 W	9.44 W	6.5–12.5
300 $\rightarrow$ 77 K	7.34 W (7.04)	0.962 W (0.962)	8.30 W	9.35 W	6.4–12.4
50 $\rightarrow$ 4 K	3.16 mW (3.15)	70.3 mW (70.3)	73.5 mW	75.6 mW	–
77 $\rightarrow$ 4 K	17.8 mW (17.7)	162.1 mW (162.1)	179.9 mW	191.8 mW	–
300 $\rightarrow$ 50 K MLI	1.81 W ^a (1.47)	1.029 W	2.84 W	–	–
300 $\rightarrow$ 77 K MLI	1.81 W ^a (1.46)	0.962 W	2.77 W	–	–

^aproduction-level matrix; the closure bias of +23 % applies as at the bare-shield level.




Figure 7: Stage loads for the four enclosure cases and the two MLI-equivalent variants (production view factors), decomposed by mechanism, with the $\pm 50\%$ emissivity band. The first stage is radiation-dominated and nearly identical between routes; the 4 K stage is conduction-dominated and is where the routes diverge.




Figure 8: (a) Mid-plane temperature and (b) shield radiative-flux map of the 300 → 50 K case.

258 4. Results Q2: helium gas versus liquid nitrogen in the cold plate

259 4.1. Verification

260 Every forced-convection run closes its energy balance, wall heat input
 261 against mass-flux-weighted enthalpy rise, to within 0.2% (Supplementary
 262 Table S7). At $Re = 500$ the helium flow is thermally developed over most
 263 of the channel ($L_t/L = 0.59$) and returns $Nu = 3.66$, 1.2% above the fully
 264 developed square-duct value of 3.61 [41]; every other laminar run is ther-
 265 mally developing (L_t/L up to 8.8 for nitrogen) and lies above it, as it must.
 266 The three-grid studies (Table 4) converge monotonically for both fluids: the
 267 production-mesh grid convergence index is 0.7% (Nu) and 2.5% (f) for he-
 268 lium and 2.2% and 1.6% for nitrogen. In the turbulent runs the first-cell y^+
 269 on the heated wall averages 2.5–5.6 with a maximum of 9.5, within the low-
 270 Reynolds treatment of the SST model. Nitrogen’s turbulent Nusselt numbers
 271 lie 8–9% below the Gnielinski correlation [42] and helium’s 28–32% below
 272 it; the correlation is for a duct heated on all walls, and a single heated wall
 273 penalises the low-Prandtl gas, whose thermal layer fills the duct, more than
 274 the liquid.

275 4.2. Operating maps

276 Figure 9 maps the two coolants over $Re = 500$ – 10^4 at the fixed 9.4 W
 277 duty. Nitrogen’s heat-transfer coefficient exceeds helium’s by a factor of
 278 4.9–5.1 throughout the laminar range and 6.2–6.3 in the turbulent range;
 279 the laminar ratio is set by the conductivity ratio of 3.1 times the ratio of

Table 4: Grid convergence at $Re = 2300$ (Celik et al. [43]; meshes of 86k, 292k and 984k cells, refinement ratio 1.5). The production mesh is the medium one.

Fluid	Quantity	Coarse	Medium	Fine	p	Extrapolated	GCI_{medium}
He (1 bar)	Nu	6.439	6.449	6.457	0.64	6.49	0.7 %
	f	0.0632	0.0642	0.0647	1.40	0.0655	2.5 %
LN ₂ (3 bar)	Nu	10.51	10.44	10.38	0.87	10.26	2.2 %
	f	0.0592	0.0599	0.0603	1.71	0.0607	1.6 %

developing-flow Nusselt numbers, which favours the high-Prandtl liquid. The consequence for the plate is stark. At atmospheric pressure the helium-cooled wall reaches 98 K at $Re = 500$ and 69 K at $Re = 2300$, and falls below the 77 K nitrogen temperature only above $Re \approx 1400$ (Fig. 9d); the nominal 50 K of the helium route is reached only in the turbulent range, at $Re = 10^4$ and 65 mW of pumping power. The nitrogen-cooled wall stays between 78 and 86 K over the whole map. Its saturation margin at 3 bar is 2.2 K at $Re = 500$, 7.1 K at 2300 and 10.6 K at 10^4 ; at 1 bar the wall would exceed the 77.2 K saturation temperature in every laminar run, so a bath-fed loop at atmospheric pressure would boil on the plate at this duty and a pressurised or subcooled loop is a requirement, not a refinement.

Pumping power separates the fluids in the opposite sense once pressure enters. At 1 bar helium needs 38 times nitrogen’s pumping power at matched Reynolds number (1.39 against 0.037 mW at $Re = 2300$), because its mass flow is 26 times smaller but its velocity 32 times larger. Raising the helium pressure at fixed Reynolds number leaves the mass flow, the Nusselt number and the wall temperature unchanged to four significant figures and reduces the pumping power as the inverse square of the density: 25.0 times at 5 bar and 324 times at 18 bar (Fig. 9c). At the 18 bar of the ITER and DTT shield loops [4, 5] helium’s pumping power is $4.3 \mu\text{W}$, 8.5 times below nitrogen’s; the parallel-path gaseous-helium shields of LHD operate in the same regime [6].

4.3. Wall-temperature distributions

Figure 10 gives the heated-wall centreline temperature and the cross-channel profile at mid-length, the quantitative counterpart of the rendered fields of the earlier comparison. Along the wall the temperature rise grows as $x^{1/3}$ in the developing region and then linearly; at the outlet the helium wall sits 24 K above its inlet at $Re = 2300$ and 53 K at $Re = 500$, nitrogen 4.2 and




Figure 9: Operating maps at 9.4 W duty: (a) heat-transfer coefficient, (b) wall superheat, (c) pumping power with the helium pressure series at $Re = 2300$, and (d) maximum wall temperature with the nitrogen saturation temperatures at 1 and 3 bar. Circles: laminar; squares: $k-\omega$ SST.




Figure 10: (a) Heated-wall centreline temperature rise above the inlet and (b) cross-channel temperature profile at $x/L = 0.5$ for both fluids at $Re = 500, 2300$ and 10^4 .

307 8.7 K. Across the channel the helium thermal layer at $Re = 500$ fills the duct,
 308 whereas nitrogen's occupies the near-wall 30 % even at $Re = 500$. This is the
 309 geometric origin of the heat-transfer ratio and of the plate temperatures in
 310 Fig. 9d.

311 4.4. Ranking on three bases

312 Table 5 collects the design point and Fig. 11 the trade-off between wall su-
 313 perheat and pumping power. The ranking depends on the basis. At matched
 314 Reynolds number nitrogen wins heat transfer by a factor of 5 and pumping
 315 power by 38; the effectiveness-NTU pair favours helium (0.11 against 0.06),
 316 a capacity-rate artefact of the gas's small $\dot{m}c_p$ that says nothing about how
 317 cold the plate is. At matched mass flow nitrogen's Reynolds number falls to
 318 about 90 and its heat-transfer coefficient to the fully developed limit of about
 319 $53 \text{ W m}^{-2}\text{K}^{-1}$, still 1.8 times helium's at $Re = 2300$. At matched pumping
 320 power, the basis a plant designer pays for, nitrogen at the pumping power of
 321 1 bar helium ($Re = 2300$) holds a superheat of 0.9 K against helium's 20.8 K,
 322 a factor of 23; at the pumping power of 18 bar helium the factor is 3.5 (5.9
 323 against 20.8 K). In the turbulent range the curves in Fig. 11 are parallel: a
 324 given superheat costs helium at 1 bar roughly 30 times the pumping power it
 325 costs nitrogen, and the 18 bar helium point sits inside the nitrogen envelope
 326 on pumping power alone but outside it on superheat. No single number ranks
 327 the coolants; the operating point and the pressure do.

Table 5: Design point, $Re = 2300$, 9.4 W, forced convection. He at 1 bar (18 bar in parentheses where pressure matters); LN₂ at 3 bar. GCI on Nu and h : 0.7 % (He), 2.2 % (LN₂).

Quantity	He, 50 K	LN ₂ , 77 K	LN ₂ /He
Mass flow $\dot{m}$ [g s ⁻¹]	0.731	18.8	25.7
Volumetric flow [cm ³ s ⁻¹]	702 (39)	23.3	0.033
Mean velocity U [m s ⁻¹]	1.52 (0.084)	0.047	0.031
Inlet / outlet temperature [K]	45.0 / 47.5	77.0 / 77.2	–
Pressure drop Δp [Pa]	1.98 (0.11)	1.57	0.80
Pumping power $\dot{W}_p$ [μ W]	1388 (4.3)	36.6	0.026 (8.5)
Wall temperature, mean / max [K]	67.1 / 69.4	81.2 / 80.8 ^a	–
Wall superheat $T_w - T_b$ [K]	20.8	4.12	0.20
Heat-transfer coefficient h [W m ⁻² K ⁻¹]	30.1	152	5.05
Nusselt number Nu	6.45	10.4	1.62
Darcy friction factor f	0.064	0.060	0.93
NTU / effectiveness ε	0.119 / 0.112	0.060 / 0.058	0.50 / 0.52
Mouromtseff number	567 (5720)	4.6×10^4	81 (8)
Buoyancy parameter Gr/Re^2	0.02	1.05	–
Saturation margin $T_{\text{sat}} - T_{w,\text{max}}$ [K]	–	7.1	–
Energy-balance closure	0.06 %	0.001 %	–

^acentreline maximum; the area mean includes the corner regions.




Figure 11: Wall superheat against pumping power for both fluids over the Reynolds sweep (labels: Re), with the helium pressure series at $Re = 2300$.

4.5. Buoyancy sensitivity

The buoyancy parameter Gr/Re^2 of the forced-convection runs is below 0.6 for helium and above unity for nitrogen in the laminar range (40 at $Re = 500$, 1.05 at 2300), so a real plate in which gravity acts along the heated wall would carry a mixed-convection secondary flow in nitrogen. The three runs with gravity on confirm this and bound its effect. Helium converged and gained 27 % in Nu at $Re = 2300$ and 118 % at $Re = 500$. Nitrogen did not reach a steady state at either Reynolds number: after 10 000 iterations the temperature residual oscillated at 10^{-3} and the energy balance remained open by 11 % and 72 %, the signature of an unsteady buoyant flow that a steady solver cannot represent. The forced-convection nitrogen results are therefore lower bounds on its heat transfer, and the ranking of Section 4.4 is conservative toward helium.

5. Results Q3: the work ledger

Table 6 and Fig. 12 price the two routes with Eq. (7). With ideal multipliers and the bare shield the nitrogen route is cheaper: 37.3 against 47.4 W, a margin of 21 %, because intercepting 8.3 W at a multiplier of 2.9 instead

Table 6: Work ledger: stage loads (row-normalised view factors), ideal and hardware-based room-temperature power. Ranges: emissivity $\pm 50\%$ (ideal) and stage-efficiency ranges of Supplementary Table S9 (real).

Shield	Route	$\dot{Q}_1$ [W]	$\dot{Q}_2$ [mW]	$\dot{W}_{\text{ideal}}$ [W]	$\dot{W}_{\text{real}}$ [W]
bare	He, 50 K	8.39	73.5	47.4 (37.8–68.0)	840 (640–1100)
bare	LN ₂ , 77 K	8.30	179.9	37.3 (31.8–49.2)	1290 (950–1740)
MLI-eq.	He, 50 K	2.84	73.5	19.6	610 (460–820)
MLI-eq.	LN ₂ , 77 K	2.77	179.9	21.3	1240 (910–1690)

of 5.0 saves 18 W while the 4 K-stage penalty costs 7.9 W. The emissivity band (31.8–49.2 W against 37.8–68.0 W) does not close the gap. With the MLI-equivalent shield the first-stage load shrinks to 2.8 W, the nitrogen saving to 6.2 W, and the verdict flips: helium 19.6 W against nitrogen 21.3 W. The ideal ledger therefore favours nitrogen where the first-stage load is large and helium where insulation has removed it, which is the regime of the MLI-wrapped shields surveyed by Shu et al. [3] and of the single-layer intercepts of Singh et al. [44].

With hardware efficiencies the verdict is not close in either case. The 4 K stage at 0.8–1.5 % of Carnot turns the 106 mW penalty into 520–980 W, more than the whole first-stage bill of either route, and the helium route costs 840 W (640–1100) against 1290 W (950–1740) for nitrogen with the bare shield and 610 against 1240 W with MLI. Written as a break-even, the nitrogen route is cheaper only if

$$\frac{\eta_2}{\eta_1} \gtrsim \frac{74 \Delta \dot{Q}_2}{5.0 \dot{Q}_{1,\text{He}} - 2.9 \dot{Q}_{1,\text{N}_2} \eta_1 / \eta_{\text{N}_2}}, \quad (8)$$

which with the present loads, $\eta_1 = 0.12$ and $\eta_{\text{N}_2} = 0.35$ requires a 4 K-stage efficiency of 2.8 % of Carnot for the bare shield and 8 % for the MLI shield, two to eight times what commercial coolers achieve [30]. The lever is $\Delta \dot{Q}_2$: because 86 % of it is harness conduction, a harness engineered for a threefold lower 77 $\rightarrow$ 4 K conduction integral, by heat-sinking the drive and flux bundles or by lower-conductivity outer conductors, brings the bare-shield break-even to 1.2 % of Carnot, within the range of real hardware.




Figure 12: Room-temperature power of the two routes for (a) the bare polished shield and (b) the MLI-equivalent shield: ideal Carnot multipliers split by stage (solid) and hardware efficiencies (hatched), with emissivity and efficiency ranges as error bars.

6. Discussion

The penalty is a harness property.. The passive cost of the warmer shield is located, sized and attributed: 106 mW at the 4 K stage, 86 % of it conduction along a harness whose drive and flux families carry three quarters. It is a property of the wiring, not of the cryogen, and Eq. (8) shows that the wiring is the only variable that can move the break-even into the range of real hardware. Lumped budgets give the same total; what the resolved model adds is the attribution to bundles that can be heat-sunk, and the confirmation that the residual radiation, whatever the shield temperature, is a minor term. This is the design steer that Li et al.'s optimisation of intercepts on supports and in insulation [11] cannot give for a wired cryostat.

The helium plate floats.. A cold plate cooled by circulated helium gas at atmospheric pressure does not sit at the gas temperature. At the 9.4 W duty it runs 21 K above the bulk at $Re = 2300$ and reaches nitrogen temperature at $Re \approx 1400$; the nominal 50 K is recovered only in turbulent flow at tens of milliwatts of pumping power, or by pressurising the loop, which leaves the wall temperature untouched but makes the pumping power negligible. This is a statement about the circulated-gas architecture and the channel sizing,

384 not about the conductively coupled PTR first stage of Fig. 2a, whose plate
385 temperature is set by the cooler’s capacity curve. It does mean that the
386 50/77 K distinction of the passive comparison is only realised on the helium
387 route with an adequate flow or pressure, and Section 4.2 gives the conditions.

388 *The basis of comparison decides the ranking..* Matched Reynolds number,
389 matched mass flow and matched pumping power rank the fluids differently
390 in magnitude and, for pumping power at 18 bar, in sign. The effectiveness–
391 NTU pair inverts the engineering conclusion because it rewards a small ca-
392 pacity rate. A cryogenic coolant comparison must therefore state its basis
393 and its operating point, as Gačnik et al. found necessary for nitrogen-cooled
394 terminals [29]; the operating maps of Fig. 9 are offered as the form such a
395 comparison should take.

396 *Ideal and real ledgers disagree, and the disagreement is informative..* The
397 ideal ledger prefers nitrogen for a bare shield and helium for an insulated
398 one; the hardware ledger prefers helium in both cases by 35–50 %, because
399 the 4 K stage of a commercial cooler converts every milliwatt of penalty into
400 ten watts at the wall. The nitrogen route retains what Li et al. identified
401 three decades ago [11]: a constant shield temperature, stored reserve, and
402 independence from the cryocooler, which now also means freedom from its
403 vibration [45]. Those are operational arguments; the thermodynamic one is
404 conditional on the harness.

405 *Methodological findings..* Two travel beyond this geometry. First, view-
406 factor matrices generated for low-emissivity enclosures must be checked for
407 closure and, if the enclosure is closed, row-normalised; the required closure
408 accuracy is of order the emissivity, and agglomeration refinement does not
409 supply it. The benchmark practice of Končar et al. [25] should be extended
410 by this test. Second, the mixing-cup temperature on a graded mesh must
411 be mass-flux weighted without an additional area factor; the corrected ac-
412 counting closed the energy balance of every run from a few per cent to below
413 0.2 %.

414 *Limitations..* The enclosure imposes fixed temperatures on its plates and
415 shield and neglects contact resistance at the harness ends; a finitely conduc-
416 tive shield would carry the radiative-flux map of Fig. 8 into a temperature
417 map, which is the next step. The cold plate is a single-wall-heated smooth
418 duct with constant properties except for the helium density and the nitrogen

419 buoyancy term; conjugate conduction in the plate, which would spread the
 420 wall temperature, is not resolved. Nitrogen is single phase by verified mar-
 421 gin at 3 bar but not at 1 bar. The turbulent runs rely on the SST model at
 422 $y^+ \leq 9.5$ and were not compared with experiment. The hardware efficiencies
 423 are ranges from published data, and the allocation of a two-stage cooler's
 424 input between its stages is by Carnot work; a measured capacity map of a
 425 specific machine would replace the ranges. Buoyancy in nitrogen was shown
 426 to be unsteady and was excluded from the ranking rather than resolved; a
 427 transient calculation in a specified plate orientation would quantify it.

428 7. Conclusions

- 429 1. A 77 K first shield costs nothing at the first stage relative to a 50 K
 430 shield: it intercepts 99.6 % of the radiation and 6.5 % less harness
 431 conduction, 8.3 against 8.4 W for the enclosure studied. The penalty
 432 appears at the 4 K stage, 106 mW, and is 86 % harness conduction
 433 concentrated in the drive and flux bundles; it is worth 7.9 W of ideal
 434 room-temperature power and 520–980 W with real 4 K coolers.
- 435 2. View-factor radiation in low-emissivity enclosures is controlled by ma-
 436 trix closure: the generated matrix gave loads from 9.5 to 3.3 W under
 437 agglomeration refinement against a 7.07 W closed form, and row nor-
 438 malisation recovered the closed form to 4 % at the first stage and 0.5 %
 439 at the 4 K stage.
- 440 3. As a first-shield coolant at 9.4 W, nitrogen at 3 bar gives 5 times he-
 441 lium's heat-transfer coefficient in laminar flow and 6 times in turbulent
 442 flow, and holds the plate within 4 K of its inlet at $Re = 2300$ against
 443 helium's 21 K; helium at 1 bar lets the plate float above 77 K below
 444 $Re \approx 1400$ and needs 38 times the pumping power, but at 18 bar its
 445 pumping power falls below nitrogen's by a factor of 8.5 with heat trans-
 446 fer unchanged. The ranking depends on the basis of comparison and
 447 the operating point.
- 448 4. The ideal ledger favours nitrogen by 21 % for a bare shield and helium
 449 by 8 % for an MLI shield; with hardware efficiencies helium is cheaper
 450 by 35–50 % in both cases. The nitrogen route becomes competitive
 451 with real hardware only if the 77 → 4 K harness conduction is cut by
 452 about a factor of three.
- 453 5. The corrected helium properties, the forced-convection basis, the mass-
 454 flux-weighted mixing-cup temperature and the row-normalised view

455 factors together change the earlier quantitative picture of this com-
456 parison; the qualitative conclusion, that the shield choice and the har-
457 ness design are not separable, is unchanged and now rests on verified
458 numbers.

459 **CRedit authorship contribution statement**

460 **Imerson Joao:** Conceptualization, Methodology, Software, Investiga-
461 tion, Formal analysis, Visualization, Writing – original draft, Writing – re-
462 view & editing.

463 **Declaration of competing interest**

464 The author declares no known competing financial interests or personal
465 relationships that could have influenced the work reported in this paper.

466 **Data availability**

467 All OpenFOAM cases (enclosure baseline and variants, cold-plate sweep,
468 grid studies), the post-processing and figure scripts, and the tabulated results
469 are available at [github.com/Imerson/Pre-cooling-a-superconducting-qubit-dilution-](https://github.com/Imerson/Pre-cooling-a-superconducting-qubit-dilution-refrigerator)
470 [refrigerator](https://github.com/Imerson/Pre-cooling-a-superconducting-qubit-dilution-refrigerator) (release v2); an archived copy will be deposited on Zenodo on
471 acceptance.

472 **Acknowledgements**

473 The author thanks Dr. Konstantina Vogiatzaki and Dr. Natalia Ares for
474 supervision and discussions.

475 **Declaration of generative AI in scientific writing**

476 During the preparation of this work the author used Claude (Anthropic)
477 to assist with editing, revision and consistency checking of the manuscript
478 and with scripting the simulation campaign. The author reviewed and edited
479 all content and takes full responsibility for the published article.

References

- [1] J. G. Weisend II, Cryostat Design: Case Studies, Principles and Engineering, Springer, Cham, 2016. doi:10.1007/978-3-319-31150-0.
URL <https://doi.org/10.1007/978-3-319-31150-0>
- [2] R. F. Barron, G. F. Nellis, Cryogenic Heat Transfer, 2nd Edition, CRC Press, Boca Raton, FL, 2016.
- [3] Q.-S. Shu, J. Demko, J. Fesmire, R. Duckworth, Design, configuration, and thermal optimization of advanced cryostats, IOP Conference Series: Materials Science and Engineering 1301 (2024) 012041. doi:10.1088/1757-899X/1301/1/012041.
- [4] K. Nam, W. Chung, C. H. Noh, D. K. Kang, K.-O. Kang, H. J. Ahn, et al., Thermal analysis on detailed 3D models of ITER thermal shield, Fusion Engineering and Design 89 (2014) 1843–1847. doi:10.1016/j.fusengdes.2014.02.060.
- [5] G. Barone, S. Roccella, E. Martelli, E. Visca, DTT thermal shield: preliminary thermal analysis, Fusion Engineering and Design 158 (2020) 111725. doi:10.1016/j.fusengdes.2020.111725.
- [6] S. Imagawa, Performance of thermal shields of LHD cryostat cooled by gaseous helium with parallel paths, in: Advances in Cryogenic Engineering: Proceedings of the Cryogenic Engineering Conference – CEC, Vol. 613 of AIP Conference Proceedings, 2002, pp. 1475–1482. doi:10.1063/1.1472180.
- [7] P. Lebrun, Cryogenics for the Large Hadron Collider, IEEE Transactions on Applied Superconductivity 10 (1) (2000) 1500–1506. doi:10.1109/77.828526.
- [8] S. Claudet, P. Lebrun, L. Taviani, U. Wagner, Exergy analysis of the cryogenic helium distribution system for the Large Hadron Collider (LHC), in: Advances in Cryogenic Engineering: Transactions of the Cryogenic Engineering Conference – CEC, Vol. 1218 of AIP Conference Proceedings, 2010, pp. 1267–1274. doi:10.1063/1.3422294.

- [9] K. Pieterman, J. A. M. Dam, H. Postma, Low temperature closed cooling system for mri magnets, in: R. W. Fast (Ed.), *Advances in Cryogenic Engineering*, Vol. 31, Springer, Boston, MA, 1986, pp. 533–541. doi:10.1007/978-1-4613-2213-9_61.
- [10] Y. Iwasa, *Case Studies in Superconducting Magnets: Design and Operational Issues*, 2nd Edition, Springer, New York, 2009. doi:10.1007/b112047.
- [11] Q. Li, X. Li, G. E. McIntosh, R. W. Boom, Minimization of total refrigeration power of liquid neon and nitrogen cooled intercepts for SMES magnets, in: *Advances in Cryogenic Engineering*, Vol. 35, Springer, 1990, pp. 833–840. doi:10.1007/978-1-4613-0639-9_100.
- [12] K. Uhlig, “dry” dilution refrigerator with pulse-tube precooling, *Cryogenics* 44 (1) (2004) 53–57. doi:10.1016/j.cryogenics.2003.07.007.
- [13] A. T. A. M. de Waele, Basic operation of cryocoolers and related thermal machines, *Journal of Low Temperature Physics* 164 (5–6) (2011) 179–236. doi:10.1007/s10909-011-0373-x.
URL <https://doi.org/10.1007/s10909-011-0373-x>
- [14] S. Krinner, S. Storz, P. Kurpiers, P. Magnard, J. Heinsoo, R. Keller, F. Lüthi, C. Eichler, A. Wallraff, Engineering cryogenic setups for 100-qubit scale superconducting circuit systems, *EPJ Quantum Technology* 6 (2), received: 21 November 2018; Accepted: 04 April 2019; Published: 28 May 2019 (2019). doi:10.1140/epjqt/s40507-019-0072-0.
URL <https://doi.org/10.1140/epjqt/s40507-019-0072-0>
- [15] P. Gumann, J. Chow, Ibm scientists cool down the world’s largest quantum-ready cryogenic concept system (2022).
URL <https://www.ibm.com/quantum/blog/goldeneye-cryogenic-concept-system>
- [16] M. Hollister, R. Dhuley, G. Tatkowski, A large millikelvin platform at fermilab for quantum computing applications, *arXiv preprint arXiv:2108.10816* (2021). arXiv:2108.10816.
- [17] A. Auffèves, Quantum technologies need a quantum energy initiative, *PRX Quantum* 3 (2022) 020101. doi:10.1103/PRXQuantum.3.020101.
URL <https://link.aps.org/doi/10.1103/PRXQuantum.3.020101>

- [18] M. De Michielis, E. Ferraro, Energy and power scaling in quantum computers based on rotated surface codes with silicon flip-flop qubits, EPJ Quantum Technology 12 (64) (2025). doi:10.1140/epjqt/s40507-025-00351-4.
URL <https://doi.org/10.1140/epjqt/s40507-025-00351-4>
- [19] M. J. Martin, C. Hughes, G. Moreno, E. B. Jones, D. Sickinger, S. Narumanchi, R. Grout, Energy use in quantum data centers: Scaling the impact of computer architecture, qubit performance, size, and thermal parameters, IEEE Transactions on Sustainable Computing 7 (4) (2022) 864–874. doi:10.1109/TSUSC.2021.3050774.
URL <https://doi.org/10.1109/TSUSC.2021.3050774>
- [20] C. Miles, R. Trepanier, et al., Cryostat optimization through multiple stage thermal shields, in: Proceedings of the 2008 Applied Superconductivity Conference / ICEC, 2008, superconducting transmission-line cryostats; multiple-shield refrigeration-power reduction.
- [21] C. Groth, A. Chiappa, R. Guarino, An analytical thermal model for the optimization of EU DEMO feeder thermal shields, Fusion Engineering and Design 207 (2024) 114650. doi:10.1016/j.fusengdes.2024.114650.
- [22] X. Zhang, M. Xu, Z. Chen, X. Yang, X. Yang, T. Zhao, R. Ye, X. Bian, Thermal performance research on the zero liquid helium consumption cryostat for a superconducting undulator, Energy 308 (2024) 132868. doi:10.1016/j.energy.2024.132868.
- [23] N. Raicu, T. Hogan, X. Wu, M. Vahidpour, D. Snow, M. Hollister, M. Field, Cryogenic thermal modeling of microwave high density signaling, EPJ Quantum Technology 12 (2025) 124. doi:10.1140/epjqt/s40507-025-00427-1.
- [24] R. Snodgrass, J. Ullom, S. Backhaus, Optimal absorption of distributed and conductive heat loads with cryocooler regenerators, IOP Conference Series: Materials Science and Engineering 1240 (2022) 012131. doi:10.1088/1757-899X/1240/1/012131.
- [25] B. Končar, L. Kostanjšek, M. Venčelj, Use of CFD codes for calculation of radiation heat transfer: from validation to application, in:

- Heat Transfer – Models, Methods and Applications, IntechOpen, 2018.
doi:10.5772/intechopen.74420.
- [26] P. P. P. M. Lerou, T. T. Veenstra, J. F. Burger, H. J. M. ter Brake, H. Rogalla, Optimization of counterflow heat exchanger geometry through minimization of entropy generation, *Cryogenics* 45 (10–11) (2005) 659–669. doi:10.1016/j.cryogenics.2005.08.002.
- [27] Ø. Wilhelmsen, D. Berstad, A. Aasen, P. Neksa, G. Skaugen, Reducing the exergy destruction in the cryogenic heat exchangers of hydrogen liquefaction processes, *International Journal of Hydrogen Energy* 43 (10) (2018) 5033–5047. doi:10.1016/j.ijhydene.2018.01.094.
- [28] A. Bejan, *Entropy Generation Minimization: The Method of Thermodynamic Optimization of Finite-Size Systems and Finite-Time Processes*, CRC Press, Boca Raton, FL, 1996.
- [29] D. Gačnik, M. ter Brake, M. Dhallé, Thermal modeling of LN₂-cooled terminals with integrated heat exchangers for superconducting applications, *Applied Thermal Engineering* 279 (2025) 127491. doi:10.1016/j.applthermaleng.2025.127491.
- [30] R. Radebaugh, Cryocoolers: the state of the art and recent developments, *Journal of Physics: Condensed Matter* 21 (16) (2009) 164219. doi:10.1088/0953-8984/21/16/164219.
- [31] A. Karabuğa, R. Selbaş, A. Kabul, Energy and exergy analyses of nitrogen liquefaction process, in: I. Dincer, C. O. Colpan, O. Kizilkan (Eds.), *Exergetic, Energetic and Environmental Dimensions*, Academic Press, 2018, pp. 627–639. doi:10.1016/B978-0-12-813734-5.00036-6.
- [32] I. H. Bell, J. Wronski, S. Quoilin, V. Lemort, Pure and pseudo-pure fluid thermophysical property evaluation and the open-source thermophysical property library CoolProp, *Industrial & Engineering Chemistry Research* 53 (6) (2014) 2498–2508. doi:10.1021/ie4033999.
- [33] Bluefors Oy, PT415 pulse tube cryocooler: technical specifications, <https://bluefors.com/products/pulse-tube-cryocoolers/pt415-pulse-tube-cryocooler/>, 1.5 W at 4.2 K with 40 W at 45 K; compressor input 10.7 kW (60 Hz) / 9.2 kW (50 Hz); accessed 27 September 2026 (2026).

- [34] OpenCFD Ltd., OpenFOAM: The Open Source CFD Toolbox, User Guide, Version v2412, OpenCFD Ltd. (ESI Group) (2024).
URL <https://www.openfoam.com/documentation/user-guide>
- [35] T. L. Bergman, A. S. Lavine, F. P. Incropera, D. P. DeWitt, Fundamentals of Heat and Mass Transfer, 8th Edition, John Wiley & Sons, Hoboken, NJ, 2017.
- [36] F. R. Menter, Two-equation eddy-viscosity turbulence models for engineering applications, AIAA Journal 32 (8) (1994) 1598–1605. doi:10.2514/3.12149.
- [37] J. W. Ekin, Experimental Techniques for Low-Temperature Measurements: Cryostat Design, Material Properties and Superconductor Critical-Current Testing, Oxford University Press, Oxford, 2006.
- [38] Q. S. Shu, R. W. Fast, H. L. Hart, Heat flux from 277 to 77 K through a few layers of multilayer insulation, Cryogenics 26 (12) (1986) 671–677. doi:10.1016/0011-2275(86)90167-0.
- [39] W. M. Kays, A. L. London, Compact Heat Exchangers, 3rd Edition, McGraw-Hill, New York, 1984.
- [40] I. E. Mouromtseff, Water and forced-air cooling of vacuum tubes, Proceedings of the IRE 30 (4) (1942) 190–205. doi:10.1109/JRPROC.1942.234654.
URL <https://doi.org/10.1109/JRPROC.1942.234654>
- [41] R. K. Shah, A. L. London, Laminar Flow Forced Convection in Ducts, Advances in Heat Transfer, Supplement 1, Academic Press, New York, 1978.
- [42] V. Gnielinski, New equations for heat and mass transfer in turbulent pipe and channel flow, International Chemical Engineering 16 (2) (1976) 359–368.
- [43] I. B. Celik, U. Ghia, P. J. Roache, C. J. Freitas, H. Coleman, P. E. Raad, Procedure for estimation and reporting of uncertainty due to discretization in CFD applications, Journal of Fluids Engineering 130 (7) (2008) 078001. doi:10.1115/1.2960953.
URL <https://doi.org/10.1115/1.2960953>

- 641 [44] M. K. Singh, V. Singh, K. Saraswat, D. Singh, Potential of ther-
642 mal protection improvements in large-scale cryostat development, In-
643 ternational Journal of Heat and Mass Transfer 236 (2025) 126254.
644 doi:10.1016/j.ijheatmasstransfer.2024.126254.
- 645 [45] T. Tomaru, T. Suzuki, T. Haruyama, T. Shintomi, A. Yamamoto,
646 T. Koyama, R. Li, Vibration analysis of cryocoolers, Cryogenics 44 (5)
647 (2004) 309–317. doi:10.1016/j.cryogenics.2003.12.006.
648 URL <https://doi.org/10.1016/j.cryogenics.2003.12.006>