Benchmarking Classical Machine Learning Models for Shading-Fault Detection in Rooftop Photovoltaic Systems Using Real Sensor Data

Zablon Ombiro*[1] and Bernard Shibwabo[1]

[1]School of Computing and Engineering Sciences, Strathmore University, Nairobi, Kenya

Abstract

Most published comparisons of machine-learning classifiers for photovoltaic (PV) fault detection are validated on simulated faults. We compare seven classical and ensemble-tree classifiers on the Réunion dataset, a 4 kW domestic rooftop plant on which shading faults were physically staged and logged. Readings within a staged episode are near-duplicates, so every train/test split is grouped by episode. A 20,800-row subsample that retains all 17 fault episodes was evaluated with three repeats of five-fold group-aware nested cross-validation, with synthetic minority oversampling (SMOTE) applied inside the training folds. Random Forest and XGBoost gave the highest mean accuracy (0.838 and 0.831) and Matthews correlation coefficient (MCC; 0.526 and 0.522). After Holm correction across the 21 pairwise Wilcoxon tests, only Random Forest's accuracy advantage over k-nearest neighbours and the multi-layer perceptron remained significant. Logistic Regression and the Decision Tree (accuracy 0.820) could be separated neither from the ensembles nor from the weakest models. SMOTE lowered binary MCC for six of the seven classifiers. Errors were concentrated in whole episodes: the Random Forest almost entirely missed four of the 17 fault episodes, including one of two uniform-shading and two of five intermittent-shading episodes. A post-hoc diagnostic shows that the no-fault rows were sampled over a wider range of times of day and output levels than the fault rows. Clock time alone reaches an MCC of 0.44, and PV-side voltage alone 0.72. The reported scores therefore reflect operating-condition differences as well as shading signatures. We release the pipeline and the diagnostics, and identify matched no-fault sampling as the step needed before the classifier ranking can be generalised.

Keywords: photovoltaic fault detection; shading faults; classifier comparison; group-aware cross-validation; class imbalance; SHAP

1 Introduction

Partial or uniform shading forces shaded cells into reverse bias. They then dissipate rather than generate power, and the resulting hot spots are a recognised fire-risk pathway. On small rooftop systems the loss is often invisible on a production dashboard, so detection has to come from the inverter's electrical measurements.

Classical and ensemble-tree classifiers are the usual baselines for this kind of tabular monitoring data, and several multi-model comparisons exist (Eldeghady et al., 2024; Khandeparkar et al., 2025; Mouleloued et al., 2025). Most of them use simulated faults, because fault-labelled field data are scarce. Field data bring a problem that simulation hides. A staged fault persists for minutes to hours, so adjacent readings are almost identical, and a random row-level split puts near-copies of the same reading on both sides of the train/test boundary. Rankings obtained

*Corresponding author.

under such splits, or on simulated data, cannot be assumed to hold under field conditions. The closest real-data comparison we know of (Toche Tchio et al., 2024) does not group its splits and does not test differences between classifiers.

We use the Réunion dataset (Graillet et al., 2022), one of the few public records in which shading faults were staged and logged on an operating plant. Seven classifiers are compared under a protocol that keeps every episode wholly inside one fold, and the pairwise differences are tested with multiplicity correction. Four questions guide the analysis:

- **RQ1.** Under episode-grouped evaluation, which classifiers perform best, and which differences survive statistical testing?
- **RQ2.** Does SMOTE, applied inside the training folds, change the ranking or only the absolute scores, and does its effect depend on the model family?
- **RQ3.** Which electrical signals drive the decisions, and is that consistent across model families?
- **RQ4.** Do the less interpretable models give a measurable gain over Logistic Regression and a single Decision Tree?

The contributions are: (i) a seven-classifier benchmark on real staged shading faults; (ii) an episode-grouped nested evaluation, made tractable by documented subsampling; (iii) multi-metric results with Holm-corrected paired tests and effect sizes, and a per-model normalised SHAP comparison; and (iv) episode-level error analysis and confound diagnostics that bound how far the results generalise. The pipeline, results and diagnostics are public.

2 Related work

Eldeghady et al. (2024), Khandeparkar et al. (2025) and Mouleloued et al. (2025) compare supervised classifiers, including Random Forest and, in one case, XGBoost, on simulated PV fault data. They report point estimates without cross-model significance tests. Ensembles have also been validated on real DC-side and multi-plant data (Chen et al., 2018; Dhibi et al., 2021; Harrou et al., 2022; Hussain et al., 2022), including about 70,000 readings from a 500 kWp system (Gaaloul et al., 2025). Related comparisons pit the support vector machine (SVM) against XGBoost (Suliman et al., 2024) and combine logistic regression, decision-tree and SVM learners in a voting ensemble (Yang and Ismail, 2022). Mellit and Kalogirou (2022) find that the advantage of ensembles over classical learners is real but not universal, which is the case for testing differences rather than reading them off point estimates. Toche Tchio et al. (2024) compare several classifiers, including Random Forest, SVM and Logistic Regression, on real low-cost-sensor data that include partial shading, without grouped splits or significance testing. Class imbalance and label noise have been handled with RUSBoost (Adhya et al., 2023) and distributionally robust logistic regression (Wang et al., 2023). Ensembles have also been applied to thermal images (Krishna Veni et al., 2025) and to an emulator testbed (Quiles-Cucarella et al., 2025).

Real field data have mostly been used for other tasks. Kappler et al. (2024) combine a long short-term memory network with a one-diode model for shading-aware power forecasting. PVF-10 provides real drone thermal imagery (Wang et al., 2024a). Graillet et al. (2022) describe the dataset used here but report no classifier.

The classifiers span distinct inductive biases: k-nearest neighbours (kNN; Cover and Hart, 1967), the maximum-margin SVM (Cortes and Vapnik, 1995), the decision tree (Quinlan, 1986), the multi-layer perceptron (MLP; Rumelhart et al., 1986), logistic regression as the linear reference, and the bagged and boosted ensembles Random Forest (Breiman, 2001) and XGBoost

Table 1: Closest prior studies and how this work differs.

Study	Data and task	Difference in this work
Eldeghady et al. (2024)	Simulated PV array faults; several supervised classifiers; accuracy-focused	Real staged faults; six metrics; corrected paired tests
Khandeparkar et al. (2025)	Simulated fault signatures, four types; five models incl. RF and XGBoost	Same ensemble baselines on real data with grouped splits
Mouleloued et al. (2025)	Seven-class fault dataset; five models incl. RF	MCC and AUC-ROC alongside accuracy; significance testing
Toche Tchio et al. (2024)	Real low-cost-sensor data incl. partial shading; several classifiers	Episode-grouped CV, repeated paired tests, SHAP
Utama et al. (2023)	Comparison of explanation methods for PV faults	SHAP across seven classifiers on a normalised scale
Kappler et al. (2024)	Real installation; LSTM + physical model; forecasting	Discrete fault classification; multi-model comparison
Graillet et al. (2022)	Data descriptor of the Réunion plant	First classifier benchmark on this record

(Chen and Guestrin, 2016). A deep sequence model trained on simulated data (Amiri et al., 2024) motivates the sequence-aware extension left to future work.

Native importance measures, such as a logistic coefficient or a tree's impurity reduction, cannot be compared across model families. SHAP (Lundberg and Lee, 2017) is the usual remedy in PV fault detection (Utama et al., 2023) and in related energy and machinery studies (Cakiroglu et al., 2024; Santos et al., 2024; Bindingsbø et al., 2023). It is comparable across models only when the explained outputs share a scale, a point we return to in Section 4.4.

Accuracy is misleading under class imbalance. The Matthews correlation coefficient (MCC) is symmetric in classes and error types (Chicco and Jurman, 2020). SMOTE (Chawla et al., 2002) is the reference oversampler, but its benefit depends on the classifier (Swana et al., 2022; Maldonado-Correa et al., 2024), and in transformer diagnosis it has mainly helped tree ensembles (Prasojo et al., 2023; Wang et al., 2024b). For comparing classifiers we follow Demšar (2006). All-pairwise testing requires a multiplicity correction (García and Herrera, 2008). Effect sizes (Kerby, 2014) complement p-values, although they do not settle the wider critique of null-hypothesis testing (Benavoli et al., 2017). Wainer and Cawley (2021) show that non-nested tuning is usually adequate in practice, so the nested design used here is the conservative choice.

Table 1 positions this study against the closest prior work.

3 Methodology

3.1 Dataset and target construction

We use the electrical-production log of inverter 1 of the Réunion plant (Graillet et al., 2022): a 4 kW, 24-module installation at 26° tilt in a tropical climate. The log has one sample every 5–8 s and seven channels: PV-side current I_a, grid current I_g, daily cumulative grid energy E_g, grid frequency F_g, grid power P_g, PV-side voltage V_a and grid voltage V_g. Faults were staged and logged with an explicit code, so the labels record an experimental condition rather than an inference.

After rows with missing values are dropped, the file has 2,988,798 rows from 1 October 2021 to 13 April 2023 (559 days). Table 2 gives the fault-code distribution. No-fault rows make up 97.17% of the record. Splitting the series at every change of fault state gives 35 contiguous runs: 17 fault episodes and 18 no-fault runs. All fault episodes fall between 8 February and 19 May 2022, a window of about 100 days.

Table 2: Fault-code distribution of the full record (2,988,798 rows), before subsampling.

Code	Description	Rows	Share (%)	Episodes
0.0	No fault	2,904,284	97.17	18
1.0	Uniform shading (entire string obscured)	6,318	0.21	2
2.1	Constant partial shading, 1 module	2,148	0.07	1
2.2	Constant partial shading, 2 modules	2,460	0.08	1
2.3	Constant partial shading, 3 modules	3,287	0.11	1
3.1	Constant partial shading, 1/3 module	2,717	0.09	3
3.2	Constant partial shading, 2/3 module	6,292	0.21	4
4.0	Intermittent partial shading (moving shadow)	61,292	2.05	5

Nested tuning of seven classifiers on about three million rows is not feasible on a single CPU workstation. The pipeline therefore keeps a random contiguous slice of at most 400 rows per fault episode and 2,000 rows per no-fault run, and drops whole no-fault runs at random until no more than 15,000 no-fault rows remain. All 17 fault episodes are retained. The benchmark has 20,800 rows in 24 episodes: 14,000 no-fault, 4,000 constant-partial-shading and 2,800 severe-tier rows, a fault prevalence of 32.7%. A constant no-fault predictor scores 0.673 accuracy (MCC 0) on it. All metrics below describe this capped benchmark, not the 2.83%-prevalence record.

The binary label is read directly from the fault code ($y = 0$ for code 0.0, otherwise $y = 1$). A three-tier label groups codes by extent, following Graillet et al. (2022, Table 3): tier 0, no fault; tier 1, constant partial shading (2.1–3.2); and tier 2, severe shading (1.0 uniform and 4.0 intermittent). The grouping is a modelling choice, which is why both schemes are reported.

3.2 Features and class-imbalance handling

All 29 features are computed within an episode, so no window crosses an episode boundary. There are four groups:

- the seven raw channels;
- four instantaneous features: I_g/I_a, $P_g/(V_a I_a)$, $|F_g - 50|$ and $V_g - V_a$;
- sixteen rolling features: the mean μ_w and standard deviation σ_w of P_g, I_a, V_g and F_g over $w = 5$ and 10 samples (about 30 and 60 s);
- two first differences, ΔP_g and ΔI_a.

Because V_g is nearly constant (s.d. about 4 V), $V_g - V_a$ carries essentially the same information as V_a.

Logistic Regression, kNN, the SVM and the MLP receive features standardised on the training fold; the tree models use raw scales. SMOTE (imbalanced-learn, three neighbours) is fitted inside each training fold, including the inner tuning folds. Every run is repeated without SMOTE.

3.3 Classifiers and tuning

Table 3 lists the search spaces. Hyperparameters are chosen by randomised search (15 draws, or every configuration where the space is smaller, as for Logistic Regression's six) inside each outer training fold. The search uses an inner three-fold group-aware split scored on macro-F1, so the outer test fold never informs selection. Table 4 gives the configuration selected most often under the primary condition. The modal choices are strongly regularised: the smallest C for Logistic Regression, depth 3 for the Decision Tree and XGBoost, and a minimum leaf size of 10

Table 3: Randomised-search space per model (d = number of features; q = Minkowski exponent).

Model	Search space
Logistic Regression	$C \in \{10^{-3}, 10^{-2}, 10^{-1}, 1, 10, 100\}$; L2 penalty (all 6 evaluated)
kNN	$k \in \{3, 5, 11, 21, 31, 51\}$; weights $\in$ {uniform, distance}; $q \in \{1, 2\}$
Decision Tree	max depth $\in \{3, 4, 6, 8, 12, 16, \infty\}$; min samples per leaf $\in \{1, 5, 10, 20\}$; criterion $\in$ {Gini, entropy}
SVM (RBF)	$C \in \{0.1, 1, 10, 100\}$; $\gamma \in$ {scale, auto, 10^{-3}, 10^{-2}, 10^{-1}}
MLP	hidden layers $\in$ {(16), (32), (64), (16,8), (32,16)}; $\alpha \in \{10^{-4}, \ldots, 10^{-1}\}$; initial learning rate $\in \{5 \times 10^{-4}, 10^{-3}, 10^{-2}\}$; early stopping
Random Forest	trees $\in \{100, 200, 300\}$; max depth $\in \{\infty, 8, 16\}$; min samples per leaf $\in \{1, 5, 10\}$; features per split $\in \{\sqrt{d}, \log_2 d\}$
XGBoost	trees $\in \{100, 300, 500\}$; max depth $\in \{3, 6, 9\}$; learning rate $\in \{0.01, 0.05, 0.1, 0.3\}$; row and column subsampling $\in \{0.7, 0.85, 1.0\}$

Table 4: Modal configuration across the 15 outer-fold searches (binary scheme, with SMOTE).

Model	Modal configuration
Logistic Regression	$C = 0.001$; L2
kNN	$k = 3$; $q = 1$; uniform weights
Decision Tree	max depth 3; min samples per leaf 1; Gini
SVM (RBF)	$C = 0.1$; $\gamma = 0.01$
MLP	one hidden layer of 64 units; $\alpha = 10^{-4}$; initial learning rate 5×10^{-4}
Random Forest	300 trees; max depth 8; min samples per leaf 10; $\log_2 d$ features per split
XGBoost	100 trees; max depth 3; learning rate 0.01; row subsampling 0.7; column subsampling 0.85

for Random Forest. This is consistent with only 17 distinct fault episodes being available for learning.

3.4 Evaluation and statistical testing

The outer loop is five-fold cross-validation, stratified by class and grouped by episode, and repeated three times with different shuffles. This gives 15 outer folds. Five folds is the largest number that leaves several fault episodes on each side of every split. Within a repeat, all 28 runs (7 classifiers $\times$ 2 label schemes $\times$ 2 resampling conditions) share the same outer partitions.

The binary scheme with SMOTE is the primary condition. We report accuracy, fault-class precision, recall and F1 (macro-averaged for the tier scheme), MCC and AUC-ROC. MCC is the headline metric, because accuracy is inflated by the 67.3% majority class:

$$\mathrm{MCC} = \frac{TP \cdot TN - FP \cdot FN}{\sqrt{(TP + FP)(TP + FN)(TN + FP)(TN + FN)}}. \tag{1}$$

Pairwise differences in accuracy and MCC are tested with the Wilcoxon signed-rank test on the 15 paired folds. Holm's step-down correction is applied across the 21 pairs of each metric. The matched-pairs rank-biserial correlation r (Kerby, 2014) is reported as the effect size. The three repeats reuse the same 17 fault episodes, so the 15 folds are not independent and the uncorrected tests are anti-conservative. The Holm-adjusted results should therefore be read as the more reliable ones.

Table 5: Software environment (minimum versions, as pinned in the repository's `requirements.txt`).

Component	Version
Python	3.x
pandas / NumPy	$\geq$2.0 / $\geq$1.24
scikit-learn / imbalanced-learn	$\geq$1.3 / $\geq$0.11
SciPy / matplotlib	$\geq$1.10 / $\geq$3.7
XGBoost / SHAP	$\geq$2.0 / $\geq$0.44
Hardware	single CPU-only workstation; no GPU

Table 6: Binary scheme with SMOTE; mean ± s.d. over 15 outer folds.

Model	Accuracy	Precision	Recall	F1	MCC	AUC-ROC
Logistic Regression	.820±.124	.776±.269	.766±.275	.741±.231	.483±.378	.893±.170
kNN	.772±.137	.707±.293	.689±.273	.663±.238	.388±.342	.822±.172
Decision Tree	.820±.175	.806±.282	.773±.276	.764±.252	.500±.420	.861±.198
SVM (RBF)	.800±.130	.784±.272	.667±.266	.690±.237	.435±.354	.846±.179
MLP	.757±.196	.712±.314	.702±.299	.670±.261	.387±.416	.820±.230
Random Forest	.838±.156	.844±.267	.744±.297	.759±.256	.526±.416	.859±.260
XGBoost	.831±.153	.822±.257	.755±.272	.767±.232	.522±.404	.870±.250

3.5 Implementation

All experiments ran on a single CPU-only workstation, with a fixed seed (42) for SMOTE, the classifiers and the search. The outer split of repeat i uses seed $42 + i$. The 28 runs took 26,666 s (7.4 h). Table 5 lists the software. The post-hoc diagnostics in Sections 4.7 and 5.6 use the same outer splits and the fixed modal Random Forest configuration.

4 Results

4.1 Primary comparison

Table 6 and Fig. 1 report the primary condition. Random Forest has the highest accuracy (0.838) and MCC (0.526), followed by XGBoost (0.831, 0.522). Logistic Regression and the Decision Tree both reach 0.820 accuracy (MCC 0.483 and 0.500). kNN, the SVM and the MLP trail (0.772, 0.800 and 0.757). Logistic Regression has the highest AUC-ROC (0.893), so its ranking of samples is good even though its default-threshold accuracy is lower. Fold-to-fold standard deviations are large for every model (Random Forest MCC 0.526 ± 0.416), because folds differ in which episodes they hold out (Section 4.7).

Without SMOTE (Table 7), Random Forest again leads (0.839, MCC 0.531), and Logistic Regression (0.830) moves ahead of XGBoost (0.814). Removing SMOTE raises accuracy for every model except XGBoost.

4.2 Confusion matrices

Table 8 and Fig. 2 pool the out-of-fold predictions: 62,400 per model (20,800 rows × 3 repeats). Random Forest and XGBoost produce the fewest false alarms (2,801 and 3,021). The SVM misses the most faults (6,420 false negatives; recall 0.667). Missing a fault is the costlier error when the hazard is undetected shading.




Figure 1: Six metrics per classifier (binary scheme, with SMOTE); error bars show the fold-wise standard deviation.

Table 7: Binary scheme without SMOTE; mean ± s.d. over 15 outer folds.

Model	Accuracy	Precision	Recall	F1	MCC	AUC-ROC
Logistic Regression	.830±.149	.824±.265	.742±.289	.751±.248	.511±.406	.901±.170
kNN	.792±.146	.763±.278	.693±.288	.687±.239	.439±.362	.849±.177
Decision Tree	.823±.189	.818±.290	.778±.278	.773±.261	.516±.442	.878±.206
SVM (RBF)	.805±.141	.819±.268	.657±.261	.700±.234	.456±.363	.841±.175
MLP	.788±.180	.763±.294	.722±.291	.709±.252	.451±.404	.854±.220
Random Forest	.839±.157	.852±.263	.739±.296	.761±.255	.531±.416	.861±.253
XGBoost	.814±.171	.824±.287	.727±.269	.747±.249	.508±.415	.846±.258

4.3 Statistical significance

Table 9 gives the uncorrected Wilcoxon p-values on accuracy. Before correction, Random Forest exceeds kNN ($p < .001$, $r = .93$) and the MLP ($p < .001$, $r = 1.0$), and XGBoost exceeds both ($p = .009$, $r = .79$; $p = .010$, $r = .73$). On MCC, both ensembles exceed kNN ($p = .003$, $r = 1.0$), the MLP ($p = .006$ and .026) and the SVM ($p = .021$ and .016), and the Decision Tree exceeds kNN ($p = .041$). No comparison involving Logistic Regression is significant on either metric. Neither is any comparison among Logistic Regression, the Decision Tree and the two ensembles (all $p \geq .37$ on MCC and $p \geq .42$ on accuracy).

After Holm correction over the 21 pairs, two comparisons survive on accuracy: Random Forest over the MLP ($p_{\text{Holm}} = .001$) and over kNN ($p_{\text{Holm}} = .009$). None survives on MCC; the smallest is $p_{\text{Holm}} = .070$, for both ensembles versus kNN. The large effect sizes show that the ensembles beat kNN and the MLP in most folds. But with 17 fault episodes and correlated repeats, the design can confirm only the largest gaps. The lack of significant differences among Logistic Regression, the Decision Tree and the ensembles is a failure to detect a difference. It does not show that they perform equally.

Table 8: Pooled confusion-matrix counts (binary, with SMOTE; positive class = fault).

Model	TN	FP	FN	TP
Logistic Regression	36,778	5,222	4,471	15,929
kNN	35,138	6,862	6,019	14,381
Decision Tree	37,415	4,585	4,454	15,946
SVM (RBF)	37,546	4,454	6,420	13,980
MLP	34,871	7,129	5,914	14,486
Random Forest	39,199	2,801	5,026	15,374
XGBoost	38,979	3,021	4,883	15,517




Figure 2: Pooled confusion matrices (binary, with SMOTE): (a) Logistic Regression, kNN and Decision Tree; (b) SVM and MLP; (c) Random Forest and XGBoost.

4.4 Feature attribution

SHAP values were computed for every classifier fitted on the full benchmark (binary, with SMOTE). Two caveats apply. First, the explained models use library-default hyperparameters, not the tuned configurations of Table 4, and the attributions are in-sample. Second, the explainers return different output scales: log-odds for Logistic Regression and XGBoost, probability for the others. Raw mean |SHAP| values therefore cannot be compared or summed across models. Fig. 3 normalises each model's attributions to shares of its own total.

V_a ranks first for the Decision Tree, Random Forest, XGBoost and the SVM, third for kNN and fourth for the MLP. kNN's top feature, $V_g - V_a$, is itself a near-linear transform of V_a. Logistic Regression relies mostly on rolling means of P_g and I_a and ranks V_a fifth. Averaged over the seven models, V_a accounts for 23% of the attribution, followed by E_g (9%) and $V_g - V_a$ (8%). E_g is a daily cumulative counter, so its prominence is a warning sign rather than a physical finding (Section 5.6).

Table 9: Pairwise Wilcoxon signed-rank p-values on accuracy (15 paired folds; upper triangle). Bold: significant after Holm correction over 21 pairs. r: matched-pairs rank-biserial correlation, reported where $p < .05$ uncorrected; positive values favour the column model.

	kNN	DT	SVM	MLP	RF	XGB
LR	.055	.599	.055	.277	.720	.847
kNN		.151	.188	1.000	**<.001** (r=.93)	.009 (r=.79)
DT			.303	.095	.679	.975
SVM				.421	.121	.121
MLP					**<.001** (r=1.0)	.010 (r=.73)
RF						.421




Figure 3: Share of each model's total mean |SHAP| for the twelve features with the largest average share (binary, with SMOTE). μ_w: w-sample rolling mean.


4.5 Label scheme and resampling

Table 10 compares the binary and three-tier schemes under both resampling conditions. With SMOTE, every classifier loses accuracy and MCC on the tier task, and the ensembles keep the highest tier scores (XGBoost 0.746 / 0.477; Random Forest 0.741 / 0.465). Without SMOTE, the order changes: the Decision Tree (0.763 / 0.527) and Logistic Regression (0.758 / 0.483) lead, and the Decision Tree loses only 6 accuracy points from binary to tier, against 20 with SMOTE. The SVM's apparent robustness to the finer task (Fig. 4b) is therefore specific to the SMOTE condition.

Fig. 4a shows the effect of SMOTE on binary MCC. It is negative for six of the seven models: largest for the MLP (−0.064) and kNN (−0.051), and negligible for Random Forest (−0.004). Only XGBoost gains (+0.014). On the tier scheme SMOTE costs Logistic Regression and the Decision Tree 14.4 and 18.9 MCC points.

Table 10: Binary versus three-tier scheme, with and without SMOTE (mean over 15 folds).

	With SMOTE				Without SMOTE			
	Accuracy		MCC		Accuracy		MCC	
Model	bin.	tier	bin.	tier	bin.	tier	bin.	tier
Logistic Regression	.820	.650	.483	.339	.830	.758	.511	.483
kNN	.772	.664	.388	.328	.792	.699	.439	.354
Decision Tree	.820	.619	.500	.338	.823	.763	.516	.527
SVM (RBF)	.800	.728	.435	.428	.805	.744	.456	.442
MLP	.757	.624	.387	.295	.788	.654	.451	.304
Random Forest	.838	.741	.526	.465	.839	.749	.531	.467
XGBoost	.831	.746	.522	.477	.814	.747	.508	.460



(a) (b)

Figure 4: (a) Effect of SMOTE on binary MCC. (b) Accuracy under the binary and three-tier schemes, with SMOTE.

4.6 Feature ablation

Table 11 varies the feature set of a Random Forest held at the modal configuration of Table 4 (binary, with SMOTE). The configuration was chosen from the outer-fold searches, so these figures are mildly optimistic. Raw channels alone (A) score close to the full set (C). The temporal block alone (B) is clearly worse (MCC 0.366). However, B contains no V_a term, because the rolling features are built from P_g, I_a, V_g and F_g. Its deficit therefore reflects the absence of V_a as much as the use of temporal features. AUC-ROC varies little (0.858–0.870), so the feature set mainly moves default-threshold decisions.

4.7 Per-fault-type and per-episode performance

Table 12 gives the binary Random Forest's recall per fault code (modal configuration, pooled out-of-fold predictions), together with the number of episodes detected. Because every code has between one and five episodes, the row-level recall is in effect an episode count, and each episode is classified almost all-or-nothing. Four of the 17 fault episodes are almost entirely missed (share of rows correct ≤ 0.007): the single code-2.3 episode, one of the two uniform-shading episodes and two of the five intermittent episodes. One code-3.1 episode is partly missed (0.84). All other fault episodes are detected in at least 98% of their rows.

The missed episodes share an operating signature. The code-2.3 episode and one missed intermittent episode were recorded at low output (median P_g of 217 W and 179 W), with V_a of 181 and 169 V. The no-fault median V_a is 184 V, against 151 V for fault rows, so these episodes

Table 11: Random Forest feature ablation (binary, with SMOTE, fixed modal hyperparameters, 15 folds).

Configuration	Features	Accuracy	MCC	AUC-ROC
A: raw channels	7	.821±.171	.504±.423	.870±.201
B: rolling and difference features (no V_a)	18	.743±.092	.366±.295	.860±.223
C: all features	29	.839±.156	.528±.417	.858±.260

Table 12: Binary Random Forest per fault code (specificity for code 0.0), pooled over 15 folds. Episodes detected: share of rows correct ≥ 0.5.

Code	Description	Pooled rows	Recall	Episodes detected
0.0	No fault (specificity)	42,000	0.935	–
1.0	Uniform shading	2,400	0.501	1 / 2
2.1	Constant partial, 1 module	1,200	0.999	1 / 1
2.2	Constant partial, 2 modules	1,200	1.000	1 / 1
2.3	Constant partial, 3 modules	1,200	0.007	0 / 1
3.1	Constant partial, 1/3 module	3,600	0.947	3 / 3
3.2	Constant partial, 2/3 module	4,800	1.000	4 / 4
4.0	Intermittent (moving shadow)	6,000	0.595	3 / 5

sit inside the no-fault voltage range. The other missed intermittent episode has near-normal V_a (176 V) at full output. A moving shadow may simply have been off the array for much of the retained 400-row slice, which is 2–15% of each intermittent episode. The missed uniform-shading episode injected no power at all during its slice. Code 2.1, with fewer raw rows than code 2.3, is detected perfectly, which rules out sparsity as the explanation for code 2.3.

At tier level (three-class Random Forest with SMOTE, pooled; accuracy 0.768, macro-F1 0.564), the per-tier F1 is 0.909 for no fault, 0.587 for constant partial shading and 0.197 for severe shading (precision 0.272, recall 0.154). The faults most closely tied to the fire-risk motivation are the ones detected least reliably.

5 Discussion

5.1 Comparative performance (RQ1)

The ensembles have the best point estimates. The only differences that survive multiplicity correction are Random Forest's accuracy advantages over kNN and the MLP. Logistic Regression and the Decision Tree fall between the two groups and cannot be separated from either. A defensible reading is that the ensembles are at least as good as any alternative tested, and clearly better than kNN and the MLP. A clean split into two tiers is not supported.

5.2 Effect of SMOTE (RQ2)

SMOTE lowered binary MCC for six classifiers and helped only XGBoost, and then marginally. On the tier scheme it reversed the ranking of the Decision Tree and Logistic Regression relative to the ensembles. A likely reason is that fault episodes are long runs of near-identical readings, so interpolating between them adds little information about the class boundary while distorting distance-based, margin-based and single-tree learners. SMOTE should not be applied by default at the benchmark's 32.7% prevalence, in line with reports from machine-fault and wind-turbine SCADA data (Swana et al., 2022; Maldonado-Correa et al., 2024).

Table 13: Post-hoc diagnostic: Random Forest (modal configuration, no SMOTE) on restricted inputs; same 3×5 grouped outer folds.

Inputs	Accuracy	MCC	AUC-ROC
Clock hour only	.732±.114	.443±.260	.792
E_g only	.616±.130	.196±.269	.735
V_a only	.880±.075	.724±.158	.913
P_g, I_a	.822±.091	.592±.189	.821
Seven raw channels	.851±.115	.685±.217	.876
Six raw channels (no E_g)	.888±.084	.744±.185	.922

5.3 Feature influence (RQ3)

Once attributions are put on a common scale, V_a is the dominant input for most models. A physical mechanism exists: a shaded cell limits the string current and triggers a bypass-diode voltage step, and the resulting multi-peak power–voltage curve can lead maximum power point tracking to a lower-voltage operating point (Kappler et al., 2024). The same direction of change, however, is produced by module heating at high irradiance, and in this benchmark the fault rows are concentrated at midday while the no-fault rows are not (Section 5.6). The present data cannot separate the two mechanisms.

5.4 Interpretability and operation (RQ4)

The ensembles show no detectable gain over Logistic Regression or the Decision Tree. Both are cheaper to retrain and easier to audit: a depth-3 tree can be read as three threshold rules. For an operations team with limited data-science support, the evidence here does not justify the added opacity of an ensemble. That conclusion rests on non-significance in a small-sample design, not on demonstrated equivalence, and it should be revisited on matched data.

5.5 Variability across folds

Each outer fold holds out three or four fault episodes, and episodes are detected almost all-or-nothing. A fold's score therefore depends mainly on whether it contains one of the four hard episodes. This is why the standard deviations are large, and why paired comparison on identical folds is necessary.

5.6 Operating-condition confound

The subsampling keeps a contiguous 400-row slice (about 33 min) per fault episode and a 2,000-row slice per no-fault run. All fault slices fall between 10:00 and 17:00. Most no-fault slices extend into early morning or late afternoon, between 05:51 and 18:11. The median clock hour is similar (12.6 versus 13.4), but the spread is not (s.d. 1.7 versus 3.7 h), and the median grid power differs widely (982 W for fault rows versus 274 W for no-fault rows). To measure the effect, we re-ran the outer protocol with the modal Random Forest and no SMOTE on restricted inputs (Table 13). Clock time alone, which carries no electrical information, gives MCC 0.44, more than kNN or the MLP achieve with 29 features. V_a alone gives 0.72, and the six raw channels without E_g give 0.74; both exceed every tuned model in Table 6.

Two conclusions follow. First, part of what the classifiers learn is when and at what output level each class was recorded, not only the shading signature. The absolute scores in this paper should not be read as field detection rates. Second, the engineered features and SMOTE lowered the performance of the Random Forest instead of raising it. The ranking of the 29-feature models partly reflects how each model copes with redundant or confounded inputs. The remedy is to

draw no-fault rows from the same clock window and irradiance band as the fault episodes, which the plant's companion meteorological file allows, and to replace E_g by its rate of change.

5.7 Validity and scope

Three controls guard against train/test leakage: scaling and SMOTE are fitted on training folds only, tuning is nested, and no episode is split across folds. Every one of the 28 runs is reported. Pairwise tests are Holm-corrected, although they still treat correlated repeats as independent.

Three further limitations remain. The tier grouping is checked only against the binary scheme. The SHAP analysis explains default-parameter models in-sample. Tables 11 and 12 use a configuration chosen with knowledge of the outer folds.

Externally, the data come from one plant, one climate and one staging campaign, with all faults inside a 100-day window. The results are evidence about relative behaviour on this record under the stated sampling. They are not performance figures to expect at other installations.

5.8 Deployment

A deployed detector would inform maintenance dispatch and, for severe shading, a safety-relevant decision. The per-episode results show that a system built on these models would miss a materially larger share of uniform and intermittent shading than of constant partial shading. Before any operational use, the models would need validation on other plants and module technologies, a human-in-the-loop dispatch process, and monitoring for drift from soiling, degradation and season. None of these steps is undertaken here.

6 Conclusions

We compared seven classical and ensemble-tree classifiers on real, physically staged shading faults, under episode-grouped nested cross-validation with corrected paired tests. Random Forest and XGBoost gave the best point estimates. After multiplicity correction, only Random Forest's accuracy advantage over kNN and the MLP was significant, and Logistic Regression and the Decision Tree could not be distinguished from the ensembles. SMOTE reduced MCC for six of seven models and should not be a default. Errors concentrate in a few whole episodes, including half of the uniform-shading and two-fifths of the intermittent-shading episodes. A post-hoc diagnostic shows that the no-fault class differs from the fault class in time of day and output level, enough for clock time alone to reach an MCC of 0.44. The scores therefore mix shading signatures with acquisition context.

Future work will (i) re-run the benchmark with no-fault rows matched to the fault episodes in clock time and irradiance, using the companion meteorological data; (ii) replace the Wilcoxon tests with a corrected resampled t-test and report per-episode results; (iii) recompute SHAP on the tuned, out-of-fold models on a common output scale; (iv) extend the ablation to all feature blocks with and without SMOTE; and (v) evaluate sequence models and other real fault-labelled PV datasets as they become available.

Declaration of generative AI and AI-assisted technologies

During the preparation of this work the authors used ChatGPT (OpenAI) and Claude (Anthropic) to assist with drafting, copy-editing and consistency checks of the manuscript against the stored results. The authors reviewed and edited all output against the experimental data and take full responsibility for the content.

CRediT authorship contribution statement

Zablon Ombiro: Conceptualization, Methodology, Software, Validation, Formal analysis, Investigation, Data curation, Writing – original draft, Writing – review & editing, Visualization. **Bernard Shibwabo:** Supervision, Validation, Writing – review & editing.

Declaration of competing interest

The authors declare no known competing financial interests or personal relationships that could have influenced the work reported in this paper.

Data and code availability

The dataset is publicly available on Zenodo (Graillet et al., 2022). The data-preparation, modelling and analysis code, the stored results and the post-hoc diagnostics (`review/reanalysis.py`) are available at `https://github.com/IncognitoGK9/pv-fault-benchmark` (Ombiro, 2026).

Acknowledgements

The authors thank the Department of Computing, Strathmore University, for academic guidance and computing resources.

Funding

This research received no external funding.

References

Adhya, D., Chatterjee, S., Chakraborty, A.K., 2023. Diagnosis of PV array faults using RUSBoost. Journal of Control, Automation and Electrical Systems 34 (1), 157–165. https://doi.org/10.1007/s40313-022-00947-6

Amiri, A.F., Kichou, S., Oudira, H., Chouder, A., Silvestre, S., 2024. Fault detection and diagnosis of a photovoltaic system based on deep learning using the combination of a convolutional neural network (CNN) and bidirectional gated recurrent unit (Bi-GRU). Sustainability 16 (3), 1012. https://doi.org/10.3390/su16031012

Benavoli, A., Corani, G., Demšar, J., Zaffalon, M., 2017. Time for a change: a tutorial for comparing multiple classifiers through Bayesian analysis. Journal of Machine Learning Research 18 (77), 1–36.

Bindingsbø, O.T., Singh, M., Øvsthus, K., Keprate, A., 2023. Fault detection of a wind turbine generator bearing using interpretable machine learning. Frontiers in Energy Research 11, 1284676. https://doi.org/10.3389/fenrg.2023.1284676

Breiman, L., 2001. Random forests. Machine Learning 45 (1), 5–32. https://doi.org/10.1023/A:1010933404324

Cakiroglu, C., Demir, S., Ozdemir, M.H., Aylak, B.L., Sariisik, G., Abualigah, L., 2024. Data-driven interpretable ensemble learning methods for the prediction of wind turbine power incorporating SHAP analysis. Expert Systems with Applications 237, 121464. https://doi.org/10.1016/j.eswa.2023.121464

Chawla, N.V., Bowyer, K.W., Hall, L.O., Kegelmeyer, W.P., 2002. SMOTE: synthetic minority oversampling technique. Journal of Artificial Intelligence Research 16, 321–357. https://doi.org/10.1613/jair.953

Chen, T., Guestrin, C., 2016. XGBoost: a scalable tree boosting system. In: Proceedings of the 22nd ACM SIGKDD International Conference on Knowledge Discovery and Data Mining, pp. 785–794. https://doi.org/10.1145/2939672.2939785

Chen, Z., Han, F., Wu, L., Yu, J., Cheng, S., Lin, P., Chen, H., 2018. Random forest based intelligent fault diagnosis for PV arrays using array voltage and string currents. Energy Conversion and Management 178, 250–264. https://doi.org/10.1016/j.enconman.2018.10.040

Chicco, D., Jurman, G., 2020. The advantages of the Matthews correlation coefficient (MCC) over F1 score and accuracy in binary classification evaluation. BMC Genomics 21, 6. https://doi.org/10.1186/s12864-019-6413-7

Cortes, C., Vapnik, V., 1995. Support-vector networks. Machine Learning 20 (3), 273–297. https://doi.org/10.1007/BF00994018

Cover, T., Hart, P., 1967. Nearest neighbor pattern classification. IEEE Transactions on Information Theory 13 (1), 21–27. https://doi.org/10.1109/TIT.1967.1053964

Demšar, J., 2006. Statistical comparisons of classifiers over multiple data sets. Journal of Machine Learning Research 7, 1–30.

Dhibi, K., Mansouri, M., Bouzrara, K., Nounou, H., Nounou, M., 2021. An enhanced ensemble learning-based fault detection and diagnosis for grid-connected PV systems. IEEE Access 9, 155622–155633. https://doi.org/10.1109/ACCESS.2021.3128749

Eldeghady, G.S., Kamal, H.A., Hassan, M.A.M., 2024. Comparative analysis of the performance of supervised learning algorithms for photovoltaic system fault diagnosis. Science and Technology for Energy Transition 79, 27. https://doi.org/10.2516/stet/2024024

Gaaloul, Y., Kechiche, O.B.H.B., Oudira, H., Chouder, A., Hamouda, M., Silvestre, S., Kichou, S., 2025. Faults detection and diagnosis of a large-scale PV system by analyzing power losses and electric indicators computed using random forest and KNN-based prediction models. Energies 18 (10), 2482. https://doi.org/10.3390/en18102482

García, S., Herrera, F., 2008. An extension on "statistical comparisons of classifiers over multiple data sets" for all pairwise comparisons. Journal of Machine Learning Research 9, 2677–2694.

Graillet, A., Lebreton, C., Tang, C., Kbidi, F., Jegado, T., Damour, C., Benne, M., 2022. Electrical production data of a domestic grid-connected rooftop PV plant in normal and shading faults conditions associated with solar and meteorological data in a tropical climate. Data in Brief 46, 108723. https://doi.org/10.1016/j.dib.2022.108723. Dataset: https://doi.org/10.5281/zenodo.7828879

Harrou, F., Taghezouit, B., Khadraoui, S., Dairi, A., Sun, Y., Hadj Arab, A., 2022. Ensemble learning techniques-based monitoring charts for fault detection in photovoltaic systems. Energies 15 (18), 6716. https://doi.org/10.3390/en15186716

Hussain, M., Al-Aqrabi, H., Hill, R., 2022. Statistical analysis and development of an ensemble-based machine learning model for photovoltaic fault detection. Energies 15 (15), 5492. https://doi.org/10.3390/en15155492

Kappler, T., Starosta, A.S., Munzke, N., Schwarz, B., Hiller, M., 2024. Detection of shading for short-term power forecasting of photovoltaic systems using machine learning techniques. EPJ Photovoltaics 15, 17. https://doi.org/10.1051/epjpv/2024013

Kerby, D.S., 2014. The simple difference formula: an approach to teaching nonparametric correlation. Comprehensive Psychology 3, 1. https://doi.org/10.2466/11.IT.3.1

Khandeparkar, V., Shreshtha, Ramu, S.K., 2025. Effectiveness of supervised machine learning models for electrical fault detection in solar PV systems. Scientific Reports 15, 34919. https://doi.org/10.1038/s41598-025-18802-4

Krishna Veni, K.S., Senthil Kumar, N., Gnanavadivel, J., 2025. Non-invasive health status diagnosis of solar PV panel using ensemble classifier. Electrical Engineering 107 (5), 5447–5459. https://doi.org/10.1007/s00202-024-02760-7

Lundberg, S.M., Lee, S.-I., 2017. A unified approach to interpreting model predictions. In: Advances in Neural Information Processing Systems 30, pp. 4765–4774.

Maldonado-Correa, J., Valdiviezo-Condolo, M., Artigao, E., Martín-Martínez, S., Gómez-Lázaro, E., 2024. Classification of highly imbalanced supervisory control and data acquisition data for fault detection of wind turbine generators. Energies 17 (7), 1590. https://doi.org/10.3390/en17071590

Mellit, A., Kalogirou, S., 2022. Assessment of machine learning and ensemble methods for fault diagnosis of photovoltaic systems. Renewable Energy 184, 1074–1090. https://doi.org/10.1016/j.renene.2021.11.125

Mouleloued, Y., Kara, K., Chouder, A., Aouaichia, A., Silvestre, S., 2025. Euclidean distance-based tree algorithm for fault detection and diagnosis in photovoltaic systems. Energies 18 (7), 1773. https://doi.org/10.3390/en18071773

Ombiro, Z., 2026. pv-fault-benchmark: source code for benchmarking classical machine learning models for shading-fault detection in rooftop PV systems. GitHub repository. https://github.com/IncognitoGK9/pv-fault-benchmark

Prasojo, R.A., Putra, M.A.A., Ekojono, Apriyani, M.E., Rahmanto, A.N., Ghoneim, S.S.M., Mahmoud, K., Lehtonen, M., Darwish, M.M.F., 2023. Precise transformer fault diagnosis via random forest model enhanced by synthetic minority over-sampling technique. Electric Power Systems Research 220, 109361. https://doi.org/10.1016/j.epsr.2023.109361

Quiles-Cucarella, E., Sánchez-Roca, P., Agustí-Mercader, I., 2025. Performance optimization of machine-learning algorithms for fault detection and diagnosis in PV systems. Electronics 14 (9), 1709. https://doi.org/10.3390/electronics14091709

Quinlan, J.R., 1986. Induction of decision trees. Machine Learning 1 (1), 81–106. https://doi.org/10.1007/BF00116251

Rumelhart, D.E., Hinton, G.E., Williams, R.J., 1986. Learning representations by back-propagating errors. Nature 323 (6088), 533–536. https://doi.org/10.1038/323533a0

Santos, M.R., Guedes, A., Sanchez-Gendriz, I., 2024. SHapley Additive exPlanations (SHAP) for efficient feature selection in rolling bearing fault diagnosis. Machine Learning and Knowledge Extraction 6 (1), 316–341. https://doi.org/10.3390/make6010016

Suliman, F., Anayi, F., Packianather, M., 2024. Electrical faults analysis and detection in photovoltaic arrays based on machine learning classifiers. Sustainability 16 (3), 1102. https://doi.org/10.3390/su16031102

Swana, E.F., Doorsamy, W., Bokoro, P., 2022. Tomek link and SMOTE approaches for machine fault classification with an imbalanced dataset. Sensors 22 (9), 3246. https://doi.org/10.3390/s22093246

Toche Tchio, G.M., Kenfack, J., Voufo, J., Abessolo Mindzie, Y., Fouedjou Njoya, B., Ouro-Djobo, S.S., 2024. Diagnosing faults in a photovoltaic system using the Extra Trees ensemble algorithm. AIMS Energy 12 (4), 727–750. https://doi.org/10.3934/energy.2024034

Utama, C., Meske, C., Schneider, J., Schlatmann, R., Ulbrich, C., 2023. Explainable artificial intelligence for photovoltaic fault detection: a comparison of instruments. Solar Energy 249, 139–151. https://doi.org/10.1016/j.solener.2022.11.018

Wainer, J., Cawley, G., 2021. Nested cross-validation when selecting classifiers is overzealous for most practical applications. Expert Systems with Applications 182, 115222. https://doi.org/10.1016/j.eswa.2021.115222

Wang, B., Chen, Q., Wang, M., Chen, Y., Zhang, Z., Liu, X., Gao, W., Zhang, Y., Zhang, H., 2024a. PVF-10: a high-resolution unmanned aerial vehicle thermal infrared image dataset for fine-grained photovoltaic fault classification. Applied Energy 376, 124187. https://doi.org/10.1016/j.apenergy.2024.124187

Wang, L., Chi, J., Ding, Y., Yao, H., Guo, Q., Yang, H., 2024b. Transformer fault diagnosis method based on SMOTE and NGO-GBDT. Scientific Reports 14, 7179. https://doi.org/10.1038/s41598-024-57509-w

Wang, M., Xu, X., Yan, Z., 2023. Online fault diagnosis of PV array considering label errors based on distributionally robust logistic regression. Renewable Energy 203, 68–80. https://doi.org/10.1016/j.renene.2022.11.126

Yang, N.-C., Ismail, H., 2022. Voting-based ensemble learning algorithm for fault detection in photovoltaic systems under different weather conditions. Mathematics 10 (2), 285. https://doi.org/10.3390/math10020285