City Government of Baguio Health Services Office	Document Code: BGO.HSO.F.PHL.037	
BACTERIOLOGICAL ANALYSIS OF WATER TEST REPORT	Rev.: 1	Effectivity Date: March 9, 2026

SEQUENCE # 2123

Establishment:* (Requesting Party/ Client) **JOSHUA WATER REFILLING STATION**

Sample Code: W26-2123

Control Number: 06O1026-R18

Owner:*	Irene Batne
Submitted by:*	Larry Batne
Sample Collected by:*	Larry Batne
Classification:	Water Refilling Station
Source of Water Supply:*	Water District
Address/ Location of (Sampling Point):*	#247 Maridit, Loakan Liwanag, Baguio City (Water Purifier Faucet)
Date/Time Received:	October 06, 2026 @ 9:39AM
Date/Time Analysis Started:	October 06, 2026 @ 9:40AM
Date Analysis Completed:	October 08, 2026PM
Date Reported:	October 09, 2026AM
Contact Number:	09212246071
Sample Type:	PROCESSED - PURIFIER

Page: 1 of 1

Sample Description	Results of Analyses			
	Bacteriological Tests	**Total Coliforms** (MPN/100mL)**	**Escherichia coli ** (MPN/100mL)**	**Heterotrophic Plate Count *** (est. CFU/mL)**
Date & Time Collected: October 06, 2026 @ 8:30AM Received a PURIFIED water sample, clear without particles placed in a 1 Liter WHITE cap PET bottle, unsealed, labelled JOSHUA REF. STATION.	**Standard Values (PNSDW 2017)**	**ABSENT or <1 MPN/100mL**	**ABSENT or <1 MPN/100mL**	**<500 CFU/mL**
	Sample Code: W26-2123	**ABSENT or <1 MPN/100mL**	**ABSENT or <1 MPN/100mL**	**<1 CFU/mL**

Philippine National Standards for Drinking Water **(PNSDW)** 2017; Standard Methods for the Examination of Water and Wastewater **(SMEWW)**, 24th edition; Most Probable Number **(MPN)**; estimated Colony Forming Unit **(est. CFU)**; Polyethylene Terephthalate **(PET)**; * Marked information provided by (the)requesting party.

METHODOLOGY:

Enzyme Substrate Test Readycult Coliforms 100** Presence /Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters, Environmental Protection Agency (EPA) version 1.1, January 2007; SMEWW 24th edition; 9221 Multiple Tube Fermentation Technique (MTFT) ; 9221B.3 Presumptive Phase (modified); 9215 Heterotrophic Plate Count (HPC); 9215B Pour Plate Method (modified)*** (48 hours @ 35C; Nutrient Agar); Merck Microbiology Manual 12th edition.

REMARKS:

Water sample tested Absence of Coliforms. The heterotrophic plate count is within the standard limit. Bacteriologically COMPLIANT (PASSED) with the Philippine National Standards for Drinking Water 2017.

Results given in this report are those obtained at the time of test and refer only to the particular water sample submitted. The laboratory cannot ascertain and guarantee if the tested water is representative of the water from the given address and point of sampling. This report shall not be reproduced in part, except in full without the written approval of the HSO Laboratory.

WILSON B. DAYAO, RMT, MLS(ASCP)^{CM}
PRC License No. 0039677 (WMLA-17-0540)
Medical Technologist I

VIRGINIA V. DE JOYA, MD, MPH, FPSP
PRC License No. 26131
Pathologist

HSO
H2O

Date signed:
OCT 09 2026