



Air Infiltration (Blower Door) Testing

Account:	Indrasena Varakantham	Site Contact:	Susan Horak
Address:	817 Brett Drive Allen, TX 75013	Community/Development:	Montgomery Farm
		Model/Plan:	817 Brett Drive
Program(s):	City Forms, Home Energy Rating, Residential IECC 2021	Cond. Area (SF)/Volume (CF):	5356.0 / 65040.5
		Certification #:	HERS: 7427364 , IECC: 10333490
Inspector/Rater:	Sporkey Ewbanks	Email:	sewbanks@foxenergyspecialists.com
Phone:	346-901-0066	Date:	09/06/2024

Blower Door Test Results

Blower Door Testing Only

☐ ROUGH ☒ FINAL ☐ RE-TEST ☐ AT SPECIAL REQUEST

☒ YES ☐ NO

Manometer used during test: DG-700; serial #

Blower Door Test Results

Blower Door Reading (CFM50): 3087.6	Blower Door Reading (ACH50): 2.8
Blower Door Test Location: Garage Door	Ring? A
Weather Conditions? Warm sunny breezy	

Inspector Comments

Notes:

Blower Door Test Results: PASSED

Fox Energy Specialists

Toll-Free: 866.448.0961 | Email: inspections@foxenergyspecialists.com

©2015 The Nelrod Company, Fort Worth, TX 76109. Fox Energy Specialists is a registered service mark of The Nelrod Company.