DESIGN CRITERIA:

1. GOVERNING CODES AND STANDARDS
   - INTERNATIONAL BUILDING CODE (IBC) 2021 EDITION
   - INTERNATIONAL RESIDENTIAL CODE (IRC) 2018 EDITION
   - AMERICAN CONCRETE INSTITUTE (ACI), BUILDING CODE REQUIREMENT FOR STRUCTURAL CONCRETE, ACI 318-19
   - AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC), SPECIFICATION FOR STRUCTURAL STEEL BUILDING ANSI/AISC 360-16
   - NATIONAL CONCRETE MASONRY ASSOCIATION (NCMA), SPECIFICATIONS FOR THE DESIGN AND CONSTRUCTION OF LOAD BEARING CONCRETE MASONRY
2. DESIGN LOADS

A. DEAD LOADS INCLUDE THE WEIGHT OF STRUCTURAL COMPONENTS, AS WELL AS THE WEIGHT OF MECHANICAL, ELECTRICAL EQUIPMENT. ANY CHANGES IN TYPE ,SIZE OR LOCATION OF MECHANICAL, ELECTRICAL EQUIPMENT FROM THAT INDICATED ON THE DRAWING SHALL BE REPORTED TO THE ENGINEER PRIOR TO INSTALLATION FOR VERIFICATION OF THE ADEQUACY OF SUPPORTING MEMBERS.

B. UNIFORM OCCUPANCY LIVE LOADS:
   - FLOOR 40 PSF
   - OPEN DECK FLOOR 60 PSF
   - ROOF 16 PSF
   - ATTIC (W/O STORAGE) 10 PSF
   - ATTIC (W/ STORAGE) 20 PSF

C. CONCENTRATED LIVE LOADS AS SPECIFIED BY THE IBC AND EQUIPMENT WEIGHTS PRODUCING STRESSES GREATER THAN THE TABULATED UNIFORM LIVE LOADS SHALL GOVERN THE DESIGN OF INDIVIDUAL STRUCTURAL ELEMENTS.

D. WIND LOADS IN ACCORDANCE WITH THE IBC AND ASCE 7-16
   - RISK CATEGORY II
   - BASIC WIND SPEED 105 MPH (ULT)
   - EXPOSURE B
   - IMPORTANCE FACTOR 1.0

E. SEISMIC LOAD IN ACCORDANCE WITH THE IBC AND ASCE 7-16
   - SITE CLASS - C
   - SEISMIC DESIGN CATEGORY - B
   - SEISMIC IMPORTANCE FACTOR - 1.0
   - MAPPED SPECTRAL RESPONSE ACCELERATION, Ss - 0.113 g
   - MAPPED SPECTRAL RESPONSE ACCELERATION, S1 - 0.058 g
   - RESPONSE MODIFICATION COEFFICIENT, R - 3.5
   - LATERAL FORCE RESISTING SYSTEM - MOMENT FRAME & ORDINARY BRACED FRAME

F. SNOW LOAD - 5 PSF

BUILDING PAD PREPARATION AND FOUNDATION DESIGN

1. FOUNDATION DESIGN AND BUILDING PAD PREPARATION SHALL BE IN ACCORDANCE WITH SUBSURFACE EXPLORATION REPORT NO. ST22-0033, BY WHITWORTH ENGINEERING, FORT WORTH, TEXAS, DATED FEBRUARY 07, 2022, REFER FOUNDATION DRAWINGS FOR MORE INFORMATION.

GENERAL NOTES:

1. REFER TO ARCHITECTURAL, MECHANICAL AND ELECTRICAL DRAWINGS FOR ANCHORS, INSERTS, REGLETS AND EMBEDDED ITEMS NOT SHOWN ON STRUCTURAL DRAWINGS. CONTRACTOR IS TO VERIFY DIMENSIONS AT THE SITE.CONTRACTOR IS TO VERIFY MECHANICAL LOADINGS AND LOCATIONS. THE CONTRACTOR IS TO ALSO VERIFY SIZES AND LOCATIONS OF MECHANICAL OPENINGS.
2. CONSTRUCTION EQUIPMENT WITH A TOTAL LOADED WEIGHT OF MORE THAN 3000 POUNDS IS NOT PERMITTED ON THE COMPOSITE FLOOR SLAB WITHOUT PRIOR WRITTEN AGREEMENT OF THE ARCHITECT/ENGINEER.
3. CONSTRUCTION MATERIALS ARE TO BE SPREAD OUT IF PLACED ON FRAME FLOORS OR ROOF. LOAD IS NOT TO EXCEED THE DESIGN LIVE LOAD PER SQUARE FOOT.

ENGINEERED LUMBER FOR ALL LEVELS:

1. PRE-ENGINEERED I-JOISTS TO BE LOUISIANA PACIFIC, TRUSS JOIST OR APPROVED EQUAL.
2. MULTIPLE PLY I-JOISTS TO BE CONNECTED PER MANUFACTURER'S SPECIFICATIONS.
3. PRE-ENGINEERED LVL BEAMS TO BE A 2900FB-2.0E BY LOUISIANA PACIFIC OR APPROVED EQUAL.
4. ALTERNATE OPEN-WEB FLOOR OR ROOF JOIST TO BE SUPPLIED BY A TRUSS MANUFACTURER WITH AN APPROVED TEXAS ENGINEER'S SEAL AND SIGNATURE ON TRUSS LAYOUT AND PROFILES.

FRAMING:

1. ALL EXTERIOR WALL STUD FRAMING SHALL BE 2X6, SYP #2 AT 16" O.C AND INTERIOR WALL STUD FRAMING SHALL BE 2X4, SYP#2 AT 16" O.C AND CONFORM WITH LATEST BUILDING CODE AS ADOPTED BY CITY.
2. INSTALL MULTIPLE 2X STUDS UNDER THE WIDTH OF THE SUPPORTED BEAM UNLESS NOTED OTHERWISE ON FRAMING PLANS.
3. METAL TIES ARE NOT REQUIRED TO CONNECT CEILING JOISTS TO RAFTERS UNLESS NOTED ON FRAMING PLANS. PROVISIONS TO RESIST THE OUTWARD THRUST OF THE ROOF HAVE BEEN MADE BY OTHER METHODS.
4. FLOOR SHEATHING TO BE APA SPAN RATED 3/4" MIN. GLUED AND NAILED TO FLOOR FRAMING.
5. ROOF SHEATHING TO BE MIN. 7/16" OSB.
6. ALL EXTERIOR WALL SHEATHINGS TO BE MIN. 7/16" O.S.B., OR APPROVED EQUAL, NAILED PER CODE.
7. ALL WOOD MEMBERS TO BE #2 SOUTHERN PINE, U.O.N.
8. PROVIDE DOUBLE JOISTS WHERE WALL RUNS PARALLEL TO JOIST.
9. ALL METAL CONNECTORS SHALL BE SIMPSON OR APPROVED EQUAL.
10. ALL NAILING FOR FRAMING SHALL BE PER IRC 2018.

NON-MASONRY CHIMNEY FRAMING NOTES: (IF APPLICABLE)

1. VERTICAL FRAMING IN CHIMNEYS SHALL BE CONTINUOUS #2-2X4 LUMBER FROM WALL TOP PLATE TO TOP OF CHIMNEY. IF SPLICING IS REQUIRED, THE STUD SHALL BE SCABBED WITH A 48" LONG 2X4, CENTERED ABOUT THE SPLICE, USING 2 ROWS OF 12D NAILS SPACED 6" O.C.
2. CORNERS SHALL BE FRAMED WITH A MIN. OF 3 STUDS.
3. THE ENTIRE CHIMNEY STRUCTURE SHALL BE SHEATHED WITH 7/16" OSB WITH VERTICAL GRAINS. HORIZONTAL SPLICES SHALL BE BLOCKED WITH SHEATHING NAILED TO BLOCKS.
4. STUDS SHALL BEAR ON TOP OF WALL PLATES OR BEAMS AS SHOWN ON FRAMING PLANS.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkaainc.com
Firm Registration: F-10656
STRUCTURAL : CONST. ADMINISTRATION : PROJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING
2 09-26-22 DIMENSIONS
3 12-21-22 CITY COMMENTS

JOB No: 220035
Issue: 06-14-2022

Sheet Name: GENERAL NOTES

Sheet No.: S0.01



FOUNDATION PLAN

SCALE: 3/16" = 1'-0"

FOOTING SCHEDULE			
MARK	SIZE	REINFORCING (LONG DIRECTION)	REINFORCING (SHORT DIRECTION)
F4	4'-0" x 4'-0" x 2'-6"	(5) #5 T&B	(5) #5 T&B
F5	5'-0" x 5'-0" x 2'-6"	(6) #5 T&B	(6) #5 T&B
F6	6'-0" x 6'-0" x 2'-6"	(7) #5 T&B	(7) #5 T&B
CF4X6	6'-0" x 4'-0" x 2'-6"	(6) #5 T&B	(8) #5 T&B

PLAN LEGEND

1. DENOTES ONE STRAND TO BE STRESSED
2. "BS,S" DENOTES TWO STRANDS TO BE STRESSED
3. DENOTES FACTORY SEATING END
4. DENOTES CHAIR
5. DENOTES CHANGE IN ELEVATION

PLAN NOTES

1. SLAB THICKNESS T= 4 1/2"
2. EXTERIOR BEAM , D = 36"
   INTERIOR BEAM , D = 30"
3. BEAM WIDTH , W = 12"
4. S DENOTES SLAB STRAND
5. BS DENOTES BEAM STRAND
6. ALL ELEVATION ARE REFERENCED TO FIRST FLOOR FINISH ELEVATION = 100'-0". REFER TO CIVIL / ARCH'L. DRAWINGS FOR ABSOLUTE ELEVATIONS.
7. BEAM STRANDS SHALL BE STRESSED FROM THE SAME SIDE AS SLAB STRANDS.
8. PORCH/PATIO SLAB STEPS 2" AT THRESHOLD AND SLOPES 1/4" PER FOOT AWAY FROM BUILDING. REFER ARCHITECTURAL

NOTES:

1. REFER SOIL REPORT FOR TREATMENT OF SLAB SUBGRADE. GRADE BEAM SHALL BE EMBEDED MINIMUM 12" INTO UNDISTURBED SUBGRADE.
2. PROVIDE 1/2"Ø X 12" LONG ANCHOR BOLTS @ 32" O.C. (MAX) AT BOTTOM PLATE OF ALL EXTERIOR AND INTERIOR BEARING WALLS.
3. G.C. SHALL VERIFY ALL DIMENSIONS AND BRICKLEDGE LOCATIONS W/ ARCH'L. BUILDING PAD SHALL BE PREPARED ACCORDING TO GEOTECHNICAL REPORT.
4. BEAM AND SLAB STRAND (BSXX, SXX) LENGTH GIVEN ESTIMATION PURPOSE ONLY. STRAND LENGTHS SHALL BE THE RESPONSIBILITY OF THE SUPPLIER.
5. ALL BEAM SHALL HAVE 2 STRANDS.

GENERAL NOTES

1. WATER CONTENT SHALL BE CONTROLLED AND MINIMIZED IN ACCORDANCE WITH ACTS BUILDING CODE REQUIREMENTS AS REFERENCED ABOVE.
2. ALL CONVENTIONAL REINFORCING BARS SHALL BE GRADE 60 IN ACCORDANCE WITH ASTM A615.

SITE PREPARATION NOTES

1. SITE GRADING AND DRAINAGE AROUND THE FOUNDATION SHALL BE MAINTAINED AT ALL TIMES IN SUCH A MANNER THAT SURFACE OR GROUND WATER WILL NOT COLLECT AROUND THE SLAB. ADEQUATE POSITIVE DRAINAGE SHALL BE PROVIDED SLOPING AWAY FROM THE FOUNDATION WITH A SLOPE OF 2-5% (1/4"-5/8" PER FOOT) FOR A MINIMUM DISTANCE OF 5'-0" FROM EDGE OF FOUNDATION.
2. FOR FINAL GRADES, THERE SHALL BE POSITIVE DRAINAGE SLOPING AWAY FROM THE SLAB. A MINIMUM OF 6" CLEARANCE BETWEEN TOP OF SLAB AND OR BRICK-LEDGE AND SOIL SURFACE SHALL BE MAINTAINED.
3. BEAM TRENCHES SHALL BE CLEAN PER PLAN. BEAM BOTTOMS MUST BE FOUNDED IN AT LEAST 12" OF UNDISTURBED SOIL OR PROPERLY COMPACTED FILL, UNLESS PIERS ARE SPECIFIED.
4. AT CONTRACTOR'S OPTION, A SAND CUSHION OR THIN LAYER OF SELECT FILL MAY BE USED AS THE TOP LAYER FOR THE PAD. EXISTING SOILS MAY BE USED AS LONG AS THEY PRESENT NO HAZARD TO THE POLYETHYLENE VAPOR BARRIER.
5. A LAYER OF 10 MIL POLYETHYLENE WITH LAPPED JOINTS BETWEEN THE SAND/EXISTING MATERIAL AND SLAB SHALL BE REQUIRED.
6. CONSTRUCTION JOINTS ARE PROHIBITED.
7. TENDONS AND BARS SHALL BE SUPPORTED BY CHAIRS SPACED AT A 4' MAXIMUM INTERVAL AND TIED AT ALL INTERSECTIONS TO PREVENT MOVEMENT DURING CONCRETE PLACEMENT. S-HOOKS MAY NOT BE USED FOR TENDON TIES.
8. CONCRETE SHALL BE VIBRATED TO INSURE CONSOLIDATION AROUND TENDON ANCHORAGES.
9. SLAB STRAND LOCATIONS MAY BE PLACED WITHIN 8" OF PLAN LOCATION TO MAINTAIN PROPER CLEARANCES. CENTER TO CENTER DISTANCE OF SLAB STRAND SHOULD NOT BE MORE THAN 5'-0" O.C
10. WHERE DISCREPANCIES BETWEEN SLAB DIMENSIONS AND ARCHITECTUAL PLANS ARE NOTICED, THE ARCHITECTURAL PLANS SHALL CONTROL.
11. COORDINATE STRUCTURAL DRAWINGS WITH ARCHITECTURAL DRAWINGS FOR ALL OPENINGS, DROPS, INSERTS, SLOPES, BRICK-LEDGES, AND OTHER RELATED ITEMS.
12. IF SOLID ROCK IS INCOUNTERED DURING TRENCHING OF BEAMS, BEAM DEPTH MAY BE REDUCED, BUT MUST MAINTAIN A MINIMUM OF 12" SOIL COVER UPON FINAL GRADE.
13. PLUMBING LINES SHALL NOT BE LOCATED PARALLEL TO THE INSIDE OF THE BEAMS.
14. SIDEWALKS AND DRIVES SHALL BE GRADED TO SLOPE AWAY FROM THE FOUNDATION TO ELIMINATE AND PREVENT PONDING OF WATER.
15. TREES AND SHRUBS SHOULD NOT BE LOCATED CLOSER TO THE FOUNDATION THAN A HORIZONTAL DISTANCE EQUAL TO ROUGHLY ½ OF THE TREE'S OR SHRUB'S MATURE HEIGHT.
16. THE DESIGN BASED UPON GEOTECH REPORT NO ST22-0033 BY WHITWORTH ENGINEERING, FORT WORTH , TX DATED FEBRUARY 07 , 2022.

POST-TENSIONED CONCRETE

1. ALL CONCRETE CONSTRUCTION TO COMPLY WITH "ACI SPECIFICATION FOR STRUCTURAL CONCRETE" (ACI-301), "BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE" (ACI 318), PTI GUIDE "SPECIFICATION FOR UNBONDED SINGLE STRAND TENDONS".
2. CAST IN PLACE CONCRETE SHALL STRICTLY ADHERE TO THE PROPORTIONS ESTABLISHED IN DESIGN MIXES, CONSISTING OF THE ACTUAL MATERIALS TO BE USED DURING CONSTRUCTION, FOR THE SEVERAL STRENGTHS AND USES INTENDED. THESE DESIGN MIXES ARE TO BE PREPARED BY A QUALIFIED LABORATORY.
3. CAST IN PLACE CONCRETE IS TO BE NORMAL WEIGHT AND IS TO DEVELOP A MINIMUM COMPRESSIVE STRENGTH f'c OF 3,000 PSI AT 28 DAYS UNLESS NOTED OTHERWISE.
4. STRANDS SHALL NOT BE STRESSED UNTIL CONCRETE ATTAINS A MINIMUM STRENGTH OF 2,500 PSI. STRESSING SHALL BE PERFORMED BETWEEN 3 AND 10 DAYS FOLLOWING CONCRETE PLACEMENT.
5. REINFORCEMENT SHALL BE FABRICATED AND PLACED IN CONFORMANCE WITH THE LATEST "ACI STANDARD BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE" (ACI 318).
6. PRESTRESSING STEEL SHALL BE SEVEN-WRE, STRESS-RELIEVED, LOW RELAXATION STRAND FOR PRESTRESSED CONCRETE MANUFACTURED IN ACCORDANCE WITH ASTM-416 AND FREE FROM CORROSION HAVING A GUARANTEED MINIMUM ULTIMATE TENSILE STRENGTH OF 270 KSI. ALL PRESTRESSING STRANDS SHALL KEEP ACCURATE RECORD OF THE MODULUS OF ELASTICITY OF EACH STRAND OR GROUP OF STRANDS FROM SAME MILL RUN. THIS MODULUS OF ELASTICITY SHALL BE USED TO DETERMINED ACTUAL ELONGATION.
   - NOMINAL DIAMETER = 0.5 INCHES
   - AREA = 0.153 SQ. INCHES
   - ULTIMATE STRENGTH = 270 KSI
   - YIELD STRENGTH = 220 KSI
7. POST-TENSION STRAND SHALL BE COATED WITH CORROSION PREVENTIVE MASTIC AND ENCLOSED IN AN EXTRUDED PLASTIC SUPPAGE SHEATHING. TORN OR DAMAGED SHEATHING SHALL BE PATCHED BEFORE CONCRETE POURING.
8. ALL ANCHORING HARDWARE SHALL MEET THE MINIMUM REQUIREMENTS SET FORTH IN ACI STANDARD BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE, ACI 318, CHAPTER 18, OR PRESTRESSED CONCRETE.
9. ANCHOR CASTING WITH REUSABLE PLASTIC OR DISPOSABLE STROFOA GROMMET SHALL BE USED AT ALL STRESSING ENDS WHERE ANCHORAGE MUST BE RECESSED IN CONCRETE IN ORDER TO RECEIVE REQUIRED CONCRETE COVER.
10. ANCHOR CASTINGS WITH POWER-SEATED WEDGES SHALL BE USED FOR ALL FIXED-END ANCHORAGE.
11. TENDONS SHALL BE FABRICATED WITH SUFFICIENT LENGTH BEYOND EDGE FORM TO ALLOW STRESSING. A MINIMUM LENGTH OF ONE FOOT AT EACH STRESSING END IS REQUIRED.
12. ALL PRESTRESSING STEEL SHALL BE PROTECTED AT THE JOB SITE FROM EXCESSIVE RUST OR OTHER CORROSION PRIOR TO FABRICATION. EXPOSED SUFFICIENT PROTECTION SHALL ALSO BE PROVIDED FOR PRESTRESSING STEEL AT THE ENDS OF MEMBERS TO PREVENT DETERIORATION BY RUST OR CORROSION.
13. SUFFICIENT CHAIRS SHALL BE PROVIDED TO MAINTAIN VERTICAL ALIGNMENT OF STRANDS. TENDONS SUPPORTS SHOULD NOT BE SPACED MORE THAN 4'-0" O.C. IN BOTH DIRECTIONS.
14. CONCRETE SHALL BE PLACED IN SUCH A MANNER THAT ALIGNMENT OF POST-TENSIONING TENDONS REMAINS UNCHANGED. SPECIAL PROVISION SHALL BE MADE TO ENSURE PROPER VIBRATION OF CONCRETE AROUND ANCHORAGES. USES OF "TRAPEZES" SHALL BE REQUIRED TO SUSPEN CONCRETE PUMP HOSE ABOVE THE PREPARED TENDONS, REINFORCING AND FORMWORK.
15. INSTALL WEDGES HORIZONTALLY SIDE BY SIDE, NOT VERTICALLY.
16. ALL STRESSING SHALL BE UNDER THE DIRECT CONTROL OF A PERSON EXPERIENCED AND QUALIFIED IN THAT WORK AND CERTIFIED BY PTI.
17. ALL PRESTRESSED STEEL SHALL BE STRESSED BY MEANS OF HYDRAULIC JACKS, EQUIPPED WITH ACCURATE READING, CALIBRATED HYDRAULIC PRESSURE. A CALIBRATION CHART WILL ACCOMPANY EACH JACK. MEASURED ELONGATION AND JACK GAUGE READING AGREEMENT WITHIN 10% SHALL BE SATISFACTORY.
18. IT IS RECOMMEND THAT THE PRESTRESSING PROCESS BE MONITORED AND RECORDED BY A THIRD-PARTY INSPECTOR.
19. PRESTRESSING CONTRACTOR AND INSPECTOR SHALL MONITOR AND KEEP A LOF OF JACK PRESSURE, TENDON STRESS, AND ELONGATION FOR EACH STRAND AND INDEX THE STRAND LOCATION ON A PLAN. RECORD INFORMATION SHALL BE FORWARDED TO THE OWNER AND MK ENGINEERS AND ASSOCIATES INC (MKEA) FOR RECORD.
20. THE MAXIMUM JACKING FORCE TO OVERCOME FRICTION SHALL NOT EXCEED 94% OF THE YIELD STRENGTH OR 80% OF THE SPECIFIED TENSILE STRENGTH OF THE TENDON. MAXIMUM ANCHORAGE STRESS SHALL NOT EXCEED 82% OF YIELD STRENGTH OR 70% OF THE SPECIFIED TENSILE STRENGTH.
21. TOTAL ELONGATION SHALL BE BASED UPON PL/AE
    - P = REQUIRED ANCHORAGE FORCE OF STRAND = 70% ULTIMATE
    - L = STRAND LENGTH
    - A = CROSS SECTIONAL AREA
    - E = MODULUS OF ELASTICITY
22. AFTER STRESSING IS COMPLETED, TENDONS SHALL BE CUT OR BURNED OFF TO WITHIN ONE INCH FROM THE FACE OF ANCHOR.
23. STRESSING POCKETS SHALL BE FILLED FLUSHED WITH NON-SHRINK GROUT WITHIN 7 DAYS AFTER STRESSING. POCKETS MUST BE CLEANED AND PREPARED PER GROUT MANUFACTURER'S REQUIREMENTS.
24. VERTICAL PLACEMENT TOLERANCES IN SLAB TENDONS SHALL BE LIMITED TO PLUS OR MINUS 1/4".
25. HORIZONTAL PLACEMENT TOLERANCES IN SLAB TENDONS SHALL BE LIMITED TO 1". IF IT IS NECESSARY, DEFLECT TENDONS HORIZONTALLY FOR AS MUCH AS 6" MAXIMUM TO AVOID PLUMBING STACKS OR OTHER OBSTRUCTIONS - THIS VARIANCE SHALL BE ACCOMPLISHED BY 20 FT RADIUS TAPER WITH SMOOTH CURVATURES FROM END OF THE TENDON RATHER THAN WITH SHORT RADIUS CURVATURES WITHIN THE IMMEDIATE AREA OF THE OBSTRUCTION.
26. PENETRATIONS THROUGH BEAMS SHALL BE AT RIGHT ANGLES AND PLACED WITHIN THE MIDDLE THIRD (HEIGHT) OF THE BEAM. IF THIS CANNOT BE ACHIEVED, SUBMIT A PLAN OF APPROVAL OF PENETRATIONS TO THE ENGINEER FOR REVIEW.
27. PENETRATIONS MUST BE WRAPPED SUCH THAT THERE IS A MINIMUM OF 1/2" CLEAR SPACE AROUND THE PENETRATION AND MUST BE AT LEAST 6" FROMANY TENDON. MOVE TENDON WITH THE RADIUS REQUIREMENTS IN THESE NOTES TO ACHIEVE CLEARANCES.
28. JACKING FORCE IS 33 KIPS AND TO BE SEATED AT 28.9 KIPS.
29. MINIMUM EFFECTIVE PRE STRESS IS 175 PSI.
30. STRESS SHORT STRANDS BEFORE LONG STRANDS.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkaainc.com
Firm Registration: F-10636
STRUCTURAL : CONST. ADMINISTRATION : PROJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING
2 09-26-22 DIMENSIONS

JOB No: 220035
Issue: 06-14-2022

Sheet Name: FOUNDATION PLAN

Sheet No.: 2

S1.01



1ST FLOOR CEILING AND 2ND FLOOR FRAMING PLAN

SCALE: 3/16"=1'-0"

KEY NOTE:

1. CEILING FRAMING TO BE 2X6 @ 24" O.C. (MAX), U.O.N.
2. CEILING FRAMING TO BE 2X8 @ 24" O.C. (MAX), U.O.N.
3. CEILING FRAMING TO BE 2X10 @ 24" O.C. (MAX), U.O.N.
4. CEILING FRAMING TO BE 2X12 @ 24" O.C. (MAX), U.O.N.
5. CEILING FRAMING TO BE 2X12 @ 16" O.C. (MAX), U.O.N.
6. CEILING FRAMING TO BE 2X8 @ 16" O.C. (MAX), U.O.N.
7. FLOOR FRAMING TO BE 16" DEEP PJI-60 JOISTS @ 16" O.C. (MAX), U.O.N.

PLAN NOTE:

1. PROVIDE ONE ADDITIONAL JOIST UNDER WALL WHERE JOISTS RUNNING PARALLEL TO WALL (TYP), U.O.N.
2. "H" DENOTES HEADERS - REFER SPAN CHART ON S4.00.
3. PROVIDE 1/2"ØX12" LONG ANCHOR BOLTS @ 32'-0" O.C. FOR ALL EXTERIOR AND INTERIOR BEARING WALLS.
4. ADJUST JOIST SPACING TO AVOID CONFLICT WITH FLOOR OPENINGS.
5. PROVIDE DOUBLE JOIST AROUND OPENINGS.
6. PROVIDE DOUBLE JOIST UNDER TUB.
7. PROVIDE 3-2X6 STUDS AT EACH END OF ALL LVL AND 3-2X12 BEAMS, U.O.N. USE 1/2" PLYWOOD SPACERS AS REQ'D. IN BETWEEN MEMBERS TO FLUSH W/ WALL.
8. ALL FLOOR BEAMS SHALL BE FLUSH WITH FLOOR JOISTS, U.O.N.
9. ALL EXTERIOR WALL SHEATHING SHALL BE 7/16 OSB.
10. ALL C1 SHALL BE 10X10 POST GRADE S.Y.P. SELECT STRUCTURAL, PRESSURE-TREATED - ATTACHED TO CONC. W/ SIMPSON ABU1010Z
11. ALL C2 SHALL BE HSS4X4X5/16 OR STD PIPE STEEL COLUMN.
12. PRE-ENGINEERED OPEN-WEB TRUSSES CAN BE USED AT CONTRACTOR'S OPTION - DESIGNED BY OTHERS.
13. ALL BEARING WALLS SHALL BE 2X AT 16" O.C., U.O.N.
14. PROVIDE DOUBLE 2X6 STUDS @ 12" O.C. AT BALLOON FRAMING WALL.
15. ALL FLOOR BEAMS SHALL BE FLUSH WITH FLOOR JOISTS U.O.N.
16. WHEN MULTIPLE PLIES OF LVL OR 2X12'S BEAMS ARE USED, FASTEN ALL PLIES USING 3 ROWS OF 12d BOX NAILS (0.128X3.25) AT 12" O.C. MAXIMUM END DISTANCE NOT TO EXCEED 6". CLINCH NAILS WHERE POSSIBLE.
18. STAIR FRAMING SHALL BE BY OTHERS.
19. "UWA" DENOTES UNDER WALL.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkaainc.com
Firm Registration: F-10636
STRUCTURAL : CONST. ADMINISTRATION : PROJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING
2 09-26-22 DIMENSIONS
3 12-21-22 CITY COMMENTS

JOB No: 220035
Issue: 06-14-2022

Sheet Name:
1ST FLOOR CEILING & 2ND FLOOR FRAMING PLAN

Sheet No.:
S1.02



2ND CEILING FRAMING PLAN

SCALE: 3/16" = 1'-0"

PLAN NOTES:

1. REFER TO S1.02 FOR INFORMATION NOT REPEATED.
2. PROVIDE TRIPLE CEILING JSTS (MIN) IF THERE ARE ANY HVAC UNITS SITTING ON CEILING JSTS.
3. SINGLE LVL BEAM OF SAME WIDTH CAN BE USED IN LIEU OF MULT-PLY LVL BEAMS.

KEY NOTES:

- ① 2X6 @ 24" O.C. (MAX), U.O.N.
- ② 2X10 @ 24" O.C. (MAX), U.O.N.
- ③ 2X12 @ 24" O.C. (MAX), U.O.N.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
O (214) 253 2506 : Email: info@mkainc.com
Firm Registration: F-10656
STRUCTURAL : CONST. ADMINISTRATION : PRJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035

Issue: 06-14-2022

Sheet Name:
2ND FLOOR CEILING FRAMING PLAN

Sheet No.:
S1.03



ROOF FRAMING PLAN

SCALE: 3/16" = 1'-0"

NOTES:

1. ALL ROOF RAFTERS TO BE #2 SYP 2X8 @ 24" O.C (MAX), U.O.N. ON PLAN.
   RAFTERS SHALL BE TIED TO CEILING JOISTS BY NAILING.
   HIPS, VALLEYS, AND RIDGES TO BE MINIMUM ONE NOMINAL SIZE LARGER.
   PURLIN BRACES TO BE SAME SIZE AS RAFTER.
2. PROVIDE COLLAR TIES AT 48" O.C. (MAX), TYP., U.O.N.
3. RAFTER BRACES DOWN TO WALLS OR CEILING JOISTS BELOW (TYP).
4. PROVIDE DOUBLE RAFTERS (MIN.) AT HVAC SUPPORT, IF ANY.
5. REFER S1.03 & S1.02 FOR INFORMATION NOT REPEATED HERE.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkaainc.com
Firm Registration: F10656
STRUCTURAL : CONST. ADMINISTRATION : PRJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035

Issue: 06-14-2022

Sheet Name:
ROOF FRAMING PLAN

Sheet No.:
S1.04



1ST FLOOR WALL BRACE PLAN

SCALE: 3/16" = 1'-0"

WALL BRACE LEGEND



MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 - Email: info@mkaainc.com
Firm Registration: F-10636
STRUCTURAL : CONST. ADMINISTRATION : PRJCT. MANAGEMENT

Seal:



Indrasena - New Residence
817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035
Issue: 06-14-2022

Sheet Name:
WALL BRACE PLAN 1ST FLOOR

Sheet No.:
S2.01



2ND FLOOR WALL BRACE PLAN

SCALE: 3/16" = 1'-0"

WALL BRACE LEGEND



MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkassinc.com
Firm Registration: F-10636
STRUCTURAL : CONST. ADMINISTRATION : PRJCT. MANAGEMENT

Seal:

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035

Issue: 06-14-2022

Sheet Name:
WALL BRACE PLAN 2ND FLOOR

Sheet No.:
S2.02


10'-6 1/2"
SECOND FLOOR
13'-6"
8 RISERS @ 6.75"
4'-5"
13'-6"
16 RISERS @ 6.75"
10 1/2"
LANDING @ 9"
FIRST FLOOR
0'-0"



01 TYP. EXTERIOR BEAM DETAIL
N.T.S.



02 BEAM DETAIL AT DOOR
N.T.S.



03 TYP. INTERIOR BEAM DTL
N.T.S.



04 SECTION
N.T.S.



05 THICKEN SLAB
N.T.S.



06 TYPICAL EXTERIOR BEAM AT GARAGE
N.T.S.



07 TYPICAL EXTERIOR BEAM AT GARAGE
N.T.S.



08 SECTION
N.T.S.



09 SECTION AT DROPPED SLAB
N.T.S.

10 NOT USED
N.T.S.

11 NOT USED
N.T.S.



12 SECTION
N.T.S.



13 SECTION AT WIDE BEAM
N.T.S.



16 TYPICAL CORNER ANCHORAGE
N.T.S.



14 TYP. GRADE BEAM REINF. DETAIL

15 N.T.S.



NOT USED

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkaainc.com
Firm Registration: F-10656
STRUCTURAL : CONST. ADMINISTRATION : PROJCT. MANAGEMENT

Seal:

Indrasena - New Residence
817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035
Issue: 06-14-2022

Sheet Name:
FOUNDATION DETAILS

Sheet No.:
S3.01



01 SILL PLATE PLAN
N.T.S.



NOTE:
1. SIMPSON TITEN HD 1/2"Ø X 4" MAY BE USED AS AN ALTERNATE @ CONTRACTORS OPTION.

02 DETAIL
N.T.S.



03 NON-LOAD BEARING SUPPORT AT FLOOR
N.T.S.



04 TYPICAL FRAMING AT FLOOR / ROOF OPENING
N.T.S.

HANGER SCHEDULE				
SIZE/TYPE	1-PLY	2-PLY	3-PLY	4-PLY
2X6	LUS26	LUS26-2	LUS26-3	-
2X8	LUS26	LUS26-2	LUS26-3	-
2X10	LUS210	LUS210-2	LUS210-3	-
2X12	LUS210	LUS210-2	LUS210-3	-
9 1/2" LVL	HUS1.81/10	HUS410	HU610	HHUS7.25/10
11 7/8" LVL	HUS1.81/10	HHUS410	HHUS5.50/10	HHUS7.25/10
14" LVL	HUS1.81/10	HHUS410	HHUS5.50/10	HHUS7.25/14
16" LVL	-	HHUS410	HHUS5.50/14	HHUS7.25/14

NOTE:
1) ALL CONNECTORS SHALL BE BY SIMPSON OR EQ.
2) ALL CONNECTORS SHALL BE INSTALLED PER MNFR'S SPECIFICATIONS.

05 N.T.S.



06 SILL PLATE PLAN
N.T.S.



07 SILL PLATE PLAN
N.T.S.



08 SILL PLATE PLAN
N.T.S.

NOTE: THESE OPENING DETAILS APPLY ONLY TO FLOOR / ROOF PENETRATIONS. IF MECHANICAL EQIPMENT IS TO BE SUPPORTED BY FLOOR / ROOF, TRUSSES SHALL BE DESIGNED FOR RTU LOADS WHERE APPLICABLE.



09 TYPICAL FRAMING AT FLOOR / ROOF OPENING
N.T.S.

BRICK LINTEL SCHEDULE		
CLEAR SPAN	SUPPORT ON EACH END	STEEL ANGLE
5'-0" OR LESS	3"	L3-1/2x3-1/2x1/4"
7'-0"	6"	L4x3-1/2x5/16"
8'-0"	6"	L5x3-1/2x5/16"
9'-0"	8"	L5x3-1/2x3/8"
10'-0"	8"	L6x3-1/2x3/8"
16'-0"	12"	*L8x4x1/2"
* INDICATES REQUIREMENT FOR HOLES IN VERTICAL LEG @ 16" O.C. FOR 3-1/2" LAG BOLTS (LOOSELY SECURED TO HEADER/BEAM TO PREVENT ROTATION.		

10 N.T.S.

ROOF BRACING SCHEDULE			
	HT.	REQUIREMENTS	SECTION
TYPICAL ROOF BRACING	1 - 8FT.	2X4 "T" BRACING	2X4
	9 - 16 FT.	2X6/2X6 "T" BRACING	2X6
	17 - 25 FT.	2X8/2X8 "T" BRACING	2X8



	ROUGH OPENING WIDTH	HEADER SIZE		
		LOAD BEARING	NON BEARING	
H	UP TO 4'-0"	(2) 2x6	(2) 2x6	
H	3'-7" TO 6'-0"	(2) 2x8	(2) 2x8	
H	6'-1" TO 8'-0"	(2) 2x10	(2) 2x8	
H	8'-1" TO 9'-0"	(2) 2x12	(2) 2x10	

NOTES:
- PROVIDE PLYWOOD SPACER NAILED TO HEADERS TO FLUSH WITH THE WALL AS REQ'D.
- FOR THE LOAD BEARING HEADERS OVER 9'-0" SPAN, SEE FRAMING PLAN.

16 HEADER SCHEDULE
N.T.S.



12 BEAM NAILING CONNECTION DETAILS
N.T.S.



TYPICAL ALTERNATE

17 STUD WALL BLOCKING DETAIL
N.T.S.



LENGTH OF WALL (BETWEEN CORNERS)	SPLICE LENGTH (MINIMUM)	NAILS ALONG SPLICE LENGTH
LESS THAN 10'-0"	1'-4"	4-16d
OVER 10'-0"	1'-4"	6-16d
OVER 20'-0"	2'-8"	10-16d
OVER 30'-0"	6'-0"	18-10d

NOTE:
1. DO NOT SPLICE PLATE WITHING 6'-0" OF ENDS OF WOOD STRUCTURAL PANEL SHEAR WALLS.
2. THIS DETAIL APPLIES AT ALL EXTERIOR WALLS AND INTERIOR SHEAR WALLS.

18 TYPICAL TOP PLATE SPLICE
N.T.S.



14 WOOD BEAM TO MIDDLE COLUMN CONNECTION (TYP)
N.T.S.

NAILING REQUIREMENTS FOR MULTIPLE PLY BEAMS		
6" DEPTH	2 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
8" DEPTH	2 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
10" DEPTH	3 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
12" DEPTH	3 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
14" DEPTH	4 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
16" DEPTH	4 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
18" DEPTH	5 ROWS OF 12D NAILS @ 12" O.C.	(EACH LAM. LAYER)
NOTE: IF OSB IS BETWEEN LAMINATIONS, THEN 16D NAILS MUST BE USED		

15 N.T.S.

3(2x6) TYP. NAILING PATTERN W/ 2 ROWS OF 10d NAILS



2(2x6) TYP. NAILING PATTERN W/ 2 ROWS OF 8d NAILS



NOTE: ALL NAILING PATTERNS FOR BUILT UP COLUMNS SHALL FOLLOW NDS SPECIFICATION.

19 BUILT UP COLUMN NAILING PATTERN
N.T.S.



20 WOOD BEAM TO CORNER COLUMN CONNECTION (TYP)
N.T.S.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 - Email: info@mkaainc.com
Firm Registration: F-10656
STRUCTURAL : CONST. ADMINISTRATION : PROJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035
Issue: 06-14-2022

Sheet Name:
TYP. WOOD DETAILS

Sheet No.:
S4.00

A1 EXTERIOR RIM BOARD



A2 JSTS. BLOCKING AT INTERIOR SUPPORT



A3 HANGER DETAIL



A4 DOUBLE I-JOIST NAILING SCHEDULE



* CONNECT DOUBLE I-JOISTS USING 4' LONG FILLER BLOCKS AT EACH SUPPORT AND AT 8' O.C., MAXIMUM.
* PROVIDE 4' FILLER BLOCKS AT ALL CONCENTRATED LOADS. CENTER FILLER BLOCKS ON LOAD.
* FASTEN FILLERS THOUGH I-JOIST WEBS USING TWO ROWS OF 8D NAILS AT 6" O.C. USE 10D NAILS FOR LPI 56A SERIES. STAGGER ROWS AND CLINCH WHEN POSSIBLE.
* FLOOR SHEATHING TO BE GLUED AND NAILED TO FLANGES OF BOTH PLIES TO PROVIDE CONTINUOUS LATERAL RESTRAINT FOR EACH PLY.

A5 CANTILEVER DETAIL

3/4" OSB (OR EQUAL) REINFORCEMENT BOTH SIDES



ATTACH REINFORCEMENT TO TOP AND BOTTOM FLANGES WITH 8D NAILS AT 6" O.C. BOTH SIDES WITH NAILS STAGGERED TO AVOID SPLITTING.

A6 RAFTER CUT DETAIL

GLUE AND NAIL 3/4" X ? X 24" PLYWOOD WEB FILLERS TO BOTH SIDES OF WEB WITH 3 ROWS OF 10d NAILS SPACED AT 6" O.C. STAGGERED FROM EITHER SIDE AND CLINCH



A7 JULIET BALCONY DETAIL



A8 BEAM TO BEAM CONNECTION





01 GAMBREL CEILING KNEE BRACE
N.T.S.



02 SECTION
N.T.S.



11 DETAIL
N.T.S.



12 DETAIL
N.T.S.



03 ROOF OVERFRAME INSTALLATION
N.T.S.



04 LATERAL BRACING OF FLOAT BEAM
N.T.S.



05 DETAIL
N.T.S.



06 SECTION AT STEEL BEAM (TYP)
N.T.S.



07 JSTS TO STEEL BM CONNX. AT CEILING
N.T.S.



08 TYP SEC @ EXTERIOR WALL
N.T.S.



09 TYP SEC @ EXTERIOR WALL
N.T.S.



NOTE:
1. PROVIDE STRAPS @ INTERIOR SIDE OF WALL.
2. STRAP IS REQUIRED AT ALL LOCATIONS WHERE WALL STUDS SITTING ON PLATE (DISCONTINUOUS).
3. ALL OPENINGS UP TO 3'-6" AT BALLOON FRAME TO BE SUPPORTED BY ONE KING STUDS (MIN).
ALL OPENINGS > 3'-6" AT BALLOON FRAME TO BE SUPPORTED BY DOUBLE KIND STUDS (MIN), SEE PLAN FOR MIN. STUDS REQ'D. AT EACH END OF LVL BEAMS/HEADERS.

10 TYP. BALLOON FRAME & STRAP DETAILS (WHERE APPLICABLE)
N.T.S.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 - Email: info@mkaainc.com
Firm Registration: F-10656
STRUCTURAL : CONST. ADMINISTRATION : PRJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence

817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035

Issue: 06-14-2022

Sheet Name:
TYP. WOOD DETAILS

Sheet No.:
S4.01



A TYPICAL BRACE PANEL
SCALE: N.T.S.

NOTE:
1. INSTALL SHEATHING ON INSIDE AND OUTSIDE OF WALL IF 2 STORY ABOVE PANEL.
2. THIS PANEL TO BE USED AT 1ST FLOOR WALL BRACES LESS THAN 48" IN WIDTH.



BRACED WALL DETAIL
VIEW FROM INSIDE HOUSE



BRACED WALL DETAIL
VIEW FROM OUTSIDE HOUSE

B TYPICAL BRACE PANEL
SCALE: N.T.S.



04 DETAILS
SCALE: N.T.S.



05 STHD INSTALLATION DETAIL
N.T.S.



06 HOLD DOWN ANCHOR
SCALE: N.T.S.



07 PLAN VIEW AT HOLD DOWNS
SCALE: N.T.S.



SECTION

08 DETAILS
SCALE: N.T.S.



09 STRAP AROUND WINDOW OPENING DETAIL
N.T.S.



DIAPHRAGM SCHEDULE	
ROOF DIAPHRAGM	1-SIDED 23/32" STRUCTURAL -1 SHEATHING BLOCKED W/ 10d NAILS 4" O.C. @ DIAPHRAGM BOUNDARIES AND 6" O.C. @ ALL OTHER EDGES. ALL EDGES BLOCKED.
FLOOR DIAPHRAGM (ALL LEVELS)	1-SIDED 3/4" STRUCTURAL -1 SHEATHING BLOCKED W/ 10d NAILS 4" O.C. @ DIAPHRAGM BOUNDARIES AND 6" O.C. @ ALL OTHER EDGES. ALL EDGES BLOCKED.

11 DIAPHRAGM LAYOUT
SCALE: N.T.S.

13 NOT USED
SCALE: N.T.S.

14 NOT USED
SCALE: N.T.S.

15 NOT USED
SCALE: N.T.S.

WALL BRACING NOTES
1. ALL WALL BRACING TO COMPLY WITH 2018 IRC OR NEWER BUILDING CODE CURRENTLY ADOPTED BY CITY OFFICIAL.
2. INSTALL BRACING PANELS AS NOTED ON ATTACHED DWG S2.01 ACCORDING TO DETAILS SHOWN ON THIS PAGE.
3. OSB WALL SHEATHING TO BE INSTALLED WITH GRAIN VERTICAL.
4. AT HORIZONTAL JOINTS, INSTALL 2X4 BLOCKING AT JOINTS AND NAIL.

TIE DOWN ANCHORS
(USE THESE ANCHORS AFTER THE SLAB IS CURED)
1. LOCATE HTT5 SIMPSON TIES AT CORNERS OF THE "C" AND "D" WALL BRACING PANELS AS NOTED ON WALL BRACING PLANS.
2. DRILL INTO SLAB WITH 3/4" DIA. DRILL BIT. HOLES SHOULD BE DRILLED 8" DEEP MIN.
3. HOLES SHOULD BE CLEANED WITH COMPRESSED AIR AND BRUSH IN EACH HOLE. ALL CONCRETE DUST MUST BE REMOVED FROM HOLES
4. IN EACH HOLE, INJECT SIMPSON ACRYLIC-TIE ADHESIVE PER MANUFACTURER'S REQ'TS.
5. INSTALL 5/8" X 8" THREADED ROD INTO EACH HOLE (SIMPSON RFB#5X12). DO NOT DISTURB THREADED ROD FOR AT LEAST TWO HOURS TO ALLOW GLUE TO CURE.
6. AFTER WAITING FOR GLUE TO CURE, INSTALL SIMPSON HTT5 TIES AND NAIL TO STUDS WITH (26) - 16d NAILS.

16 WALL BRACING & HOLDDOWN NOTES

17 NOT USED

18 NOT USED
SCALE: N.T.S.

19 NOT USED
SCALE: N.T.S.

20 NOT USED
SCALE: N.T.S.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 : Email: info@mkaainc.com
Firm Registration: F-10656
STRUCTURAL : CONST. ADMINISTRATION : PRJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence
817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035
Issue: 06-14-2022

Sheet Name:
TYP. WALL BRACE DETAILS

Sheet No.:
S4.02



NOTE:
USE SHEAR TAB FOR SMALLER OF
TWO BEAMS INTERSECTING AT COLUMN.
FOR ALL OTHER CONDITIONS, USE
A STANDARD THRU PLATE CONNECTION

01 TYPICAL BM - COLUMN SHEAR TAB CONN
N.T.S.



02 TYP BM TO COLUMN CONNX.

A. COMBINATION BOLTED-WELDED CONNECTION



NOTE:
3 BOLTS SHOWN AS AN EXAMPLE ONLY
NUMBER OF BOLTS TO BE DETERMINED
PER PART IV, AISC MANUAL

NOTE:
WELD TO BEAM, BOLTS TO GIRDER SHOWN,
BOLTS TO BEAM, WELD TO GIRDER PERMITTED.
REFER TO PART IV, AISC MANUAL

B. BOLTED CONNECTION



03 TYP BEAM TO BEAM CONNX.
N.T.S.

NOTE:	NOTE:	NOTE:
COMBINATION BOLTED-WELDED AND BOLTED CONNECTION SHOWN. FULLY WELDED CONNX PERMITTED. REFER TO PART IV, AISC MANUAL. ALL CONNECTIONS TO PROVIDE MINIMUM SHEAR CAPACITY INDICATED IN TABLE OR ON PLANS	WELD TO GIRDER, BOLTS TO BEAM SHOWN, BOLTS TO GIRDER, WELD TO BEAM PERMITTED REFER TO PART IV, AISC MANUAL	WELDED AND COMBINATION BOLTED WELDED CONNECTIONS SHOWN. FULLY BOLTED CONNECTIONS PERMITTED. REFER TO PART IV,AISC MANUAL. ALL CONNECTIONS TO PROVIDE MINIMUM SHEAR CAPACITY INDICATED IN TABLE OR ON PLANS



04 TYP BEAM TO COLUMN CONNX
PLAN VIEW
N.T.S.

BOLT SCHEDULE		
BEAM SIZE	ROWS OF X Ø BOLTS	
	WEB PL CONNX	DBL. < CONNX
W8,W10	2	2
W12	3	3
W14	3	3
W16	4	3
W18	5	4
W21	6	5

NOTES:
1.ALL BOLTS SHALL MEET ASTM A325
2. AT ALL MOMENT CONNECTIONS USE A325 BOLTS TORQUED TO PROOF.
3. AT ALL OTHER CONNECTIONS, BOLTS SHALL BE INSTALLED SNUG TIGHT.

05 BOLT SCHEDULE
N.T.S.

06 NOT USED
N.T.S.

07 NOT USED
N.T.S.

08 NOT USED
N.T.S.

09 NOT USED
N.T.S.

10 NOT USED
N.T.S.

11 NOT USED
N.T.S.

12 NOT USED
N.T.S.





13 OPTIONAL BM - COLUMN CONNECTION
N.T.S.

14 NOT USED
N.T.S.

15 NOT USED
N.T.S.



COLUMN SCHEDULE		BASE PLATE SCHEDULE		
TYPE	SIZE	TYPE	SIZE (IN)	BOLTS (IN)
C-1	HSS4X4X5/16 4" STD PIPE	BP1	6"X10"X3/4"	4-3/4"Ø

16 COLUMN SCHEDULE
N.T.S.

MK and Associates, Inc.
400 Chisholm Place, Suite 106
Plano, TX 75075
D (214) 253 2506 Email: info@mkaainc.com
Firm Registration: F10656
STRUCTURAL: CONST. ADMINISTRATION PROJCT. MANAGEMENT

Seal:

STATE OF TEXAS
MOHAMMAD H. KABIR
124645
LICENSED
PROFESSIONAL ENGINEER
06-14-2022

Indrasena - New Residence
817 Brett Drive, Allen TX 75013

Revision:
1 06-30-22 STAIR LANDING

JOB No: 220035
Issue: 06-14-2022

Sheet Name:
STEEL DETAILS

Sheet No.:
S5.00