

**Academic year**  
2024 - 2025

**Provide a title**

**Inte Vleminckx**

Supervisors

**prof. dr. H. Vangheluwe, UAntwerpen**  
**R. Mittal, Doctoral Fellow, UAntwerpen**



**University of Antwerp**  
**| Faculty of Science**

## Disclaimer

This document is an examination document that has not been corrected for any errors identified. Without prior written permission of both the supervisor(s) and the author(s), any copying, copying, using or realizing this publication or parts thereof is prohibited. For requests for information regarding the copying and/or use and/or realisation of parts of this publication, please contact to the university at which the author is registered.

Prior written permission from the supervisor(s) is also required for the use for industrial or commercial utility of the (original) methods, products, circuits and programs described in this thesis, and for the submission of this publication for participation in scientific prizes or competitions.

This document is in accordance with the faculty regulations related to this examination document and the Code of Conduct. The text has been reviewed by the supervisor and the attendant.

# Contents

<b>1</b>	<b>Introduction</b>	<b>1</b>
<b>2</b>	<b>Proposed Approach</b>	<b>2</b>
2.1	The First Steps . . . . .	2
2.1.1	A Simple Modelica Model . . . . .	3
2.1.2	Interaction With The Control Loop . . . . .	3
2.1.3	Complete Intergration . . . . .	3
<b>3</b>	<b>Modelica Library Overview</b>	<b>4</b>
<b>4</b>	<b>Results</b>	<b>5</b>
<b>5</b>	<b>Conclusion</b>	<b>6</b>

# 1 Introduction

The development of products in the heating, ventilation, and air conditioning (HVAC) industry presents significant challenges in testing and validation. Building physical prototypes for every design iteration is often costly and time-consuming. A promising alternative is to model the most expensive or complex components in a virtual environment, enabling early testing without full-scale prototypes. This approach allows the evaluation of critical subsystems, particularly the control software that regulates HVAC systems.

In this study, we investigate how to test the control loop of a heating and ventilation system by modeling all physical elements—such as the valve, the actuator controlling the valve, the flow sensor, the pipe network, and the pressure pump that generates the fluid flow. The control loop, which determines the actuator setpoint based on the flow sensor measurements, will interact with the virtual model using co-simulation techniques. To assess the feasibility and performance of this approach, we compare two testing strategies: Software-in-the-Loop (SiL), and Hardware-in-the-Loop (HiL). In SiL testing, the model interacts with a compiled version of the control loop running on a separate system, with all connections established virtually. In HiL testing, the model runs on one system while the control loop is executed on the actual embedded hardware used in the real setup, with physical connections between the two.

Our methodology proceeds in stages. First, we develop a simple flow circuit in Modelica to demonstrate basic co-simulation capabilities. Using this model, we investigate how to integrate it with SiL and HiL environments. Once this foundation is established, we expand the Modelica component library with more detailed and realistic system elements. Finally, we construct an advanced flow circuit model and benchmark SiL results against HiL results to evaluate performance differences and validate the modeling approach.

Inte: add what can be expected in each upcoming section in one sentence.

## 2 Proposed Approach

### 2.1 The First Steps

To address the problem at hand, we must first establish a clear understanding of the overall problem statement. As outlined in the introduction, our goal is to test the control loop of a heating and ventilation system by modeling all physical elements and allowing the control loop to interact with this model. To achieve this, we need to define, as simply as possible, what the model requires as input from the control loop and what the control loop requires as input from the model, without yet considering detailed configuration parameters of the individual physical components. With this understanding in place, we can represent the interaction between the control loop and the model using the following diagram:




Figure 2.1: Simple representation of interaction between control loop and model

Next, we provide a more detailed explanation of the process illustrated in Figure 2.1. In this setup, the control loop receives a target flow setpoint. Although the source of this setpoint is not relevant to our study, it defines the desired flow rate in the circuit. To achieve this flow rate, the control loop calculates an actuator setpoint, which adjusts the valve opening to provide the required flow. In order to perform this calculation, the control loop must receive feedback from the model in the form of the measured flow in the circuit. By comparing the measured flow to the target flow, the control loop can determine the necessary actuator setpoint and adjust the valve position accordingly.

With this simplified setup, we can construct a Modelica model that accepts one real-valued input and produces one real-valued output—the actuator setpoint and the measured flow, respectively. For testing purposes, we can initially provide fixed output values from the model to the control loop to observe how the actuator setpoint evolves over time. To enable full co-simulation, we must also determine how to establish interaction between the Modelica model and the control loop. The workflow for this process is as follows:

1. Develop a simple Modelica model.
2. Investigate how the compiled control loop can be accessed and controlled using Python.
3. Integrate the Modelica model into the Python code so that the control loop can exchange data with the model in real time.




Figure 2.2: A simplified model representatino

### 2.1.1 A Simple Modelica Model

A very simple Modelica model can be represented as shown in Figure 2.2.

This model accepts an actuator setpoint as input and produces a measured flow as output, which is currently fixed at a value of 3 for testing purposes.

### 2.1.2 Interaction With The Control Loop

### 2.1.3 Complete Intergration

## 3 Modelica Library Overview

## 4 Results



## 5 Conclusion

# Bibliography