Optimal Approximation of Non-linear Power Flow Problem*

Nina Vishnyakova

`ninavishn@yandex.ru`

Moscow Institute of Physics and Technology (State University)

This paper addresses Optimal Approximation of Non-linear Power Flow Problem. To solve it, the "trust region approach" method is used, which implies a consequent consideration of convex optimization problems. The obtained results are compared with results of well-known methods such as SDP Relaxation, SOC Relaxation etc. (1). The rate of convergence of studied method for large dimensions problems with tens of thousands of nodes is investigated.The results of direct computations confirm a higher rate of convergence for the proposed method and a reduction in the computational resources, necessary for performing each iteration.

Index terms: *optimal power flow, non-convex optimization problem, trust region approach, convex restriction* .

1 Introduction

In this article we explore the problem of optimization of the workload in the energy network in order to reduce the cost of electricity production. This is a very important topic in the power industry (2). Energy flows are huge, so any results, leading to small improvements in the scale of the power grid, lead to a tremendous economic effect [YM: blue]"Energy flows are huge..." – try to rewrite the sentence. Take a look on the paper you cite; what is there motivation?.

The problem is called AC-Optimal Power Flow problem AC-OPF problem) [YM: We have two problems: AC-OPF and DC-OPF, the second one is a linear programming]. In general case this optimization problem with constraints, imposed by nonlinear Kirchhoff's equations and the needs of consumers, has a convex functional and non-convex constraints. A large number of articles offer various solutions. Linear approximation method suggests linearizing the power flow constraints. Local optimization methods are about looking for a local optimum of the AC-OPF problem. And global optimization methods propose convexifying the constraints imposed by the Kirchhoff's laws.

In this paper, we solve the OFP problem using the "trust region approach" method, which implies a consequent consideration of convex optimisation problems. We study the convergence of the method and the rate of convergence in relation to large dimension problems with tens of thousands of nodes.

The obtained results are compared with another methods: DC Approximation, LPAC Approximation, SDP Relaxation, SOC Relaxation, QC Relaxation. The results of direct computations confirm a fast rate of convergence for the proposed method and a reduction in the computational resources, necessary for performing each iteration.

[YM: Nina, Very good! Sorry for the very brief comments, I have a short stopover on my way to Europe. Few comments are below:

– References are missing. I have added a few (2–5), take a look please. In (2) you will find a proper setup and a motivation behind the problem;

– try to support each statement by a citation, e.g., the problem hardness, the problem motivation etc.

]

2 Problem Statement

Consider a power network modeled by a directed graph $\mathbf{G}(\mathcal{N}, \mathcal{E})$ where buses are represented by nodes in $\mathcal{N}$ and transmission lines by edges in $\mathcal{E} \subset \mathcal{N} \times \mathcal{N}$. Let $\mathcal{R}$ denote the set of reference (slack) buses, $\mathcal{G}$ - all generators, $\mathcal{L}$ - all loads.

Consider the following operating constraints:

$$\angle V_r = 0 \ \ \forall r \in \mathcal{R} \tag{1}$$

$$S_k^{gl} \leqslant S_k^g \leqslant S_k^{gu} \ \ \forall k \in \mathcal{G} \tag{2}$$

$$v_i^l \leqslant |V_i| \leqslant v_i^u \ \ \forall i \in \mathcal{N} \tag{3}$$

$$\sum_{k \in G_i} S_k^g - \sum_{k \in L_i} S_k^d - \sum_{k \in S_i} Y_k^s |V_i|^2 = \sum_{(i,j) \in E_i \cup E_i^R} S_{ij} \ \ \forall i \in \mathcal{N} \tag{4}$$

for the variables:

$$S_k^g \ \ \forall k \in \mathcal{G} \text{ - generator complex power dispatch}$$
$$V_i \ \ \forall i \in \mathcal{N} \text{ - bus complex voltage}$$
$$S_{ij} \ \ \forall (i,j) \in \mathcal{E} \text{ - branch complex power flow}$$

and data:

$$S_k^{gl}, S_k^{gu} \ \ \forall k \in \mathcal{G} \text{ - generator complex power lower and upper bounds}$$
$$v_i^l, v_i^u \ \ \forall i \in \mathcal{N} \text{ - voltage lower and upper bounds}$$
$$S_k^d \ \ \forall k \in \mathcal{L} \text{ - load complex power consumption.}$$

AC-OPF Problem is to minimize:

$$\sum_{k \in \mathcal{G}} \left(c_{2k} (\mathrm{Re}(S_k^g))^2 + c_{1k} \mathrm{Re}(S_k^g) + c_{0k} \right) \tag{5}$$

where

$$c_{2k}, c_{1k}, c_{0k} \ \ \forall k \in \mathcal{G} \text{ - generator cost components}$$

subject to (1), (2), (3), (4).

3 *

Список литературы

[1] Ian A. Hiskens Daniel K. Molzahn. A survey of relaxations and approximations of the power flow equations. foundations and trends. *Electric Energy Systems*, 4(1–2):1–221, 2019.

[2] Steven H Low. Convex relaxation of optimal power flow—part i: Formulations and equivalence. *IEEE Transactions on Control of Network Systems*, 1(1):15–27, 2014.

[3] Javad Lavaei and Steven H Low. Zero duality gap in optimal power flow problem. *IEEE Transactions on Power Systems*, 27(1):92–107, 2012.

[4] Carleton Coffrin, Hassan L Hijazi, and Pascal Van Hentenryck. The qc relaxation: A theoretical and computational study on optimal power flow. *IEEE Transactions on Power Systems*, 31(4):3008–3018, 2016.

[5] Steven H Low. Convex relaxation of optimal power flow—part ii: Exactness. *IEEE Transactions on Control of Network Systems*, 1(2):177–189, 2014.