

SOP · Lockout/Tagout Cooling Loop A

Stop the pump, open the electrical isolator, apply a personal lock and tag, and verify zero energy before work.