

SITEIQ — SITE ASSESSMENT REPORT (SAMPLE)

PVMath · pvmath.com

Project Name	Castilla-La Mancha Demo (187 ha)
Location	Castilla-La Mancha, Spain
Coordinates	38.20000°N, 2.50000°W
Site Area	187 ha
Land Use / Mounting	Standard · Fixed Tilt
Report Date	21.06.2026
Prepared by	PVMath — Sample Report

Metric	Value	Rating
Annual GHI	1,842 kWh/m²/yr	High
In-plane irradiation	2,109 kWh/m²/yr	High
Mean slope	3.2%	Low
Max slope	4.8%	Acceptable
Flood risk	Low	Low
Est. DC capacity (1P FT)	75–105 MWp	Screening band
PVMath Score	82 / 100	Very Good

Representative screening output for a 187 ha site in southern Spain. Values match the public demo on pvmath.com. For a live report on your site, register free at siteiq.pvmath.com.

IMPORTANT DISCLAIMER

This report provides preliminary site screening for internal go/no-go and early client discussions only. Solar data from PVGIS JRC; terrain from satellite DEM (indicative unless TopoIQ-confirmed); flood risk is an elevation heuristic, not hydraulic modelling; regulatory flags are indicative OSM-based checks, not permitting diligence. PVMath does not claim bankability. A full engineering study, site survey, permitting review, and certified energy yield assessment are required before financing, EPC contract, or final investment decision.