Technical Site Visit Report

Prepared for: Sridhar Babu Y - Villa #185

PROJECT INFORMATION

Report Number	ESV-2026-0146
Project ID	1F68A6AB
Project Name	Sridhar Babu Y
Building Name	Villa #185
Billing Name	Sridhar Babu Y_La Villa Township Subsidy_4.8kWp_String
Project Sector	Residential
Project Type	With Subsidy
Sales Lead	Govindaraju
Site Address	La Ville Township, Villa #185 Sy. No. 30,31 &32, Adigara Kallahalli Sarjapura Hobli, Anekal Taluk, Bangalore, Byalahalli, 562125
GPS Coordinates	12.81834211025898, 77.80478991427228
Google Maps	https://www.google.com/maps?q=12.818342110258984,77.80478991427228
Visit Date	2026-06-16
Visited By	K Naveen
Revision	Rev 1

CLIENT INFORMATION

Client Name	Sridhar Babu Y
Contact	9886213978

PROJECT DETAILS

Solar Rooftop System Type	On-Grid
System Capacity (kWp)	4.92
Sanction Load (kW)	5

Module Make & Capacity	Premier DCR Bifacial 605
Module Length (mm)	2382
Module Width (mm)	1133
Number of Panels	8
Inverter Type	String
Inverter Brand	Deye 5 kW 1phase String
Number of Inverters	1
Mounting Structure Type	Elevated

SITE INSPECTION CHECKLIST

General

#	Question	Answer	Notes
1	Can the delivery van/truck reach the material unloading point?	Yes	-
2	Are there any obstacles at the site that could hinder material lifting?	**No**	-
3	Where will the Inverter, DCDB, ACDB, Battery, etc. be located?	The Invereter,DC DB,ACDB will be located near the main meter location.	-
4	Is a canopy required for protecting the Inverters/ACDB/DCDB?	**No**	-
5	Did you discuss the location of the earth pits with the customer?	The earth pits will be located north side passage.	-
6	Where is the Internet Router located?	Ground floor	-
7	What's the Wi-Fi strength of the router near to the String inverter/Envoy?	3 bars	-
8	Did you pin the site location in your WhatsApp when you were at the site?	Yes	-

Roof Details

#	Question	Answer	Notes
1	What type of roof is present at the site?	RCC Flat Roof	-
2	Are there any obstructions on the roof that could affect the solar installation?	details: The headrrom chajja are the obstacle that could affect the solar installation.	-
3	What is the angle of the panels? (in degrees)	10	-
4	In case of sloped roof, what is the slope angle of the roof? (in degrees)	N/A	-

#	Question	Answer	Notes
5	On how many roofs at the site are we installing solar?	1	-
6	If it is a Tiled roof, what is underneath the tiles?	N/A	-
7	If it is a Tiled roof with MS or Wooden rafters, is it Single-tiled or Double-tiled?	N/A	-
8	What type of mounting structure is planned?	Elevated	*2P3 Elevated HDGI Structure and 1P2 landscape Ballast Structure*
9	What is the orientation of the solar panels?	["South"]	-
10	How can the roof be accessed?	Staircase	-
11	Is the building currently under construction?	**No**	-
12	In an under-construction building, are existing conduit pipes available for AC, DC cables, and earthing?	N/A	-
13	What is the height of the building and how many floors does it have?	The height of the building is G+1+headroom is approximately 15 meters	-
14	Is the site photo matching with the building description?	Yes	-
15	Is there an overhead HT line passing within a 10-meter radius of the site?	**No**	-

Residential / Electrical

#	Question	Answer	Notes
1	What type of energy meter is currently installed?	Phase: Three Phase, Type: Digital	-
2	Is the Meter cubicle photo matching with the previous answer?	Yes	-
3	Has the termination point in the Main meter panel been identified?	Yes	-
4	Is the Termination Point easily visible or sealed?	Visible	-
5	Is a Lightning Arrestor (LA) already available at the site?	**No**	-
6	Is space available for CT within Energy meter panel?	**No**	-
7	In case of an Enphase system, is the distance between the farthest micro-inverter and IQ Gateway > 50m?	N/A	-
8	Provide details of the existing CT ratings (if applicable).	N/A	-
9	In Main meter panel, is empty space available for solar meter?	**No**	-
10	In Main meter panel, is empty space available to house the Enphase accessories or ACDB components?	N/A	-
11	Is there space available to dig DC, AC and LA earth pits?	Yes	-
12	In case of elevated structures, is an LA extension provided at the far end?	Yes	-
13	In case of elevated structures, is it with or without grouting?	With Grouting	-
14	Are there any challenges with respect to Installation and Maintenance activities?	**No**	-
15	Are there any safety risks associated with accessing the roof for installation?	**No**	-
16	Is space present in rooftop to store the panels?	Horizontally sleeping	-

#	Question	Answer	Notes
17	In case of sloped roof MS structure, provide the dimension of rafter to rafter, purlin to purlin.	N/A	-
18	Is ventilation available in the battery location?	N/A	-
19	Should the Inverters/ACDB/DCDB be installed on a metal grill or wall mount?	Wall Mount	-
20	Provide the dimensions for solar meter cubicle placement (L x W of wall).	length: 1500, width: 1500	-
21	Provide the dimension for earth pits location (L x W of available space).	length: 1000, width: 2000	-
22	Is LAN cable under customer scope?	**No**	-
23	Is there any shadow that affects the solar installation?	**No**	-
24	Is there any trench work to be done to carry the AC cable to the meter location?	**No**	-

PHOTO DOCUMENTATION

Cable Routing Legend

Legend	Description
	Proposed PV Module Array
	Main Meter Location
	Solar Meter
	Battery
	Inverter
	Other Equipment
	DC Cable
	AC Cable
	Material Shifting
	DC Earthing Cable
	AC Earthing Cable
	LA Cable
	DC Earth Pit
	AC Earth Pit
	LA Pit
	LA

Material Delivery Route

This route (using lifting) will be followed to carry large items (like Panels).



This route (using Staircase) will be followed to carry Small items.

Staircase Details



Meter Box

Material Storage

Proposed PV Area



2P3 HDGI Elevated structure with 2.5 m height

1P2 landscape Ballast structure with 0.45m front clearance

Cable Routing






PLATINUMM



Equipment Location



Earth Pit Location

Site Layout - Top View






3.90 m
1.35 m
3.30 m
3.44 m
2.14 m
2.55 m
4.81 m
N


4.81 m
0.63 m
2.55 m
3.41 m
1.35 m
3.90 m
N



Dimensions of 2.5m HDGI structure



Landscape Ballast Structure with0.45 m front clearnance



Due to the space consistance the structure post should keep near to the headroom chajja

Building Exterior

OBSERVATIONS & RECOMMENDATIONS

EcoSoch Scope

#	Observation
1	At the time of installation based on the site conditions to keep the landscape Ballast structure

Customer Scope

#	Observation
1	Wi-Fi up to the inverter location is under customer scope.
2	As the customer suggestions thepanel routing, cable routing,earthing locations has been considered.
3	During the site visit there is no access to climb the staircase headroom.
4	Based on the site conditions the HDGI front height should be maintained 2.50m.
5	Near the invereter location client will remove the obstacles is under customer scope.

THANK YOU

Dear Sridhar Babu Y,

Thank you for choosing EcoSoch Solar for your solar installation. We appreciate your trust in us and your commitment to sustainable energy. Our team is dedicated to ensuring a seamless installation experience and long-term performance of your solar system.

Should you have any questions or require further assistance, please do not hesitate to reach out to us.

Warm Regards,
Team EcoSoch

& Did You Know?

The Sun burns 600 million tonnes of hydrogen per second — and your panels get a share.

EcoSoch Solar Pvt. Ltd.

#940, Sha Arcade, 2nd Phase, NTI Layout, Kodigehalli, Bengaluru 560097

www.ecosoch.com | info@ecosoch.com